

THESIS

TECHNOECONOMIC ANALYSIS OF A STEAM GENERATION SYSTEM WITH CARBON  
CAPTURE

Submitted by

Luke Giugliano

Department of Mechanical Engineering

In partial fulfillment of the requirements

For the Degree of Master of Science

Colorado State University

Fort Collins, Colorado

Summer 2019

Master's Committee:

Adviser: Todd M. Bandhauer

Shantanu Jathar  
Tiezheng Tong

Copyright Luke Giugliano 2019

All Rights Reserved

## ABSTRACT

### TECHNOECONOMIC ANALYSIS OF A STEAM GENERATION SYSTEM WITH CARBON CAPTURE

Industrial steam generation consumes large amounts of natural gas (NG) and contributes significantly to CO<sub>2</sub> emissions. Existing boiler technology is relatively inefficient, and its continued adoption could potentially be hampered by carbon emissions taxes due to the difficulty in CO<sub>2</sub> separation from the dilute exhaust gas stream. This paper presents an alternative approach to steam generation that combines a membrane reactor (MR) to produce hydrogen from steam methane reforming (SMR), resulting in a concentrated CO<sub>2</sub> exhaust. The performance of the system is evaluated using a coupled thermodynamic and techno-economic analysis of an industrial-scale SMR plant to produce hydrogen in a MR used primarily for the purpose of steam generation (SG). The proposed SMR-MR-SG system converts NG to clean-burning hydrogen (H<sub>2</sub>), burns H<sub>2</sub> to generate steam, and captures and concentrates CO<sub>2</sub>. Unused NG and H<sub>2</sub> are recycled back into the system with uncaptured CO<sub>2</sub> to increase efficiency.

The SMR-MR-SG is compared to two baseline systems: a natural gas industrial boiler system (BS), and the same boiler system with integrated CO<sub>2</sub> capture (BSC). The SMR-MR-SG improves on the BS by increasing efficiency from 86% to 97% and reducing NG and water consumption by 14% and 55%, respectively. Additionally, the SMR-MR-SG uses cryogenic separation and gas recycling to completely eliminate CO<sub>2</sub> emissions with a 3.0% energy penalty, much less than comparable systems with carbon capture.

The SMR-MR-SG has a capital cost about three times the BS and twice the BSC, but makes up for it quickly with reducing operating costs. Using a conservative prediction of carbon tax, the SMR-MR-SG has a payback period of 1.86 and 1.26 years and a discounted lifetime cost reduction of 42% and 43% relative to the BS and BSC, respectively. A sensitivity analysis showed that the results are most heavily influenced by the amount of carbon tax implemented in the future, with no carbon tax corresponding to a payback period of 8.05 years relative to the BS. The results of this modelling study show that the SMR-MR-SG could be a direct replacement for common industrial boiler systems as a new, efficient, and clean steam generation system.

## ACKNOWLEDGEMENTS

I would like to thank Dr. Todd Bandhauer for pushing me to work harder, think more critically, and achieve greater accomplishments. In particular, he has taught me how to always make progress by trusting my own engineering judgement. I sincerely appreciate his great flexibility with my pursuits outside the ITS lab, be it running, tiny house living, or moving out of town. I may have had an easier time with another advisor, but I certainly would not have learned as much.

I would like to thank our collaborators, formerly of Mines but now of Worcester Polytechnic Institute: Simona Liguori, Cyrus Kian, and Jen Wilcox. These are the masterminds behind everything “membrane reactor”. To say they taught me everything I know about membrane reforming is not far from the truth. Thank you for helping to guide a frequently lost mechanical engineer in a chemical world.

The students (and former students) of the ITS lab are the heart of this experience. I could easily write pages about all that they have done for me, but this is technical writing so I will keep it short. Thank you to: Josh, for putting up with me in house and lab; John, for being my go-to “can you help me with...” guy; Shane, for his patience helping me with the many things I’ve asked of him; Derek, for showing me the ropes of thesis writing; Alex, for TIG welding along with the best of them; Katie, for her mastery of zip-ties and fiberglass insulation; James, for dedicating his life to the study of gas chromatography and smoked meats; David, for always making time to help at a minute’s notice; Zach, for the comedy, intentional or not; Caleb, for keeping me up to date on current events; Will, for removing 126 cubic inches of masonry; Jensen, for building dozens of steel menorahs. You guys made the memories I will remember.

To my family: M, DA, Swa, and Shark, thank you for answering my phone calls every day between 4:30 and 6:30pm MT. I have had nothing but support from each of you and cannot wait for all of you to move out here. Finally, I would like to thank Chrissy. My world is made brighter by your smile. Thank you for keeping me going. I thought about proposing in this thesis, but that would almost be *too* romantic. Instead, please enjoy the following ~150 pages on steam methane reforming.

## TABLE OF CONTENTS

ABSTRACT .....	ii
ACKNOWLEDGEMENTS .....	iii
LIST OF TABLES .....	vii
LIST OF FIGURES .....	viii
NOMENCLATURE .....	x
CHAPTER 1. Introduction.....	1
1.1. Background.....	1
1.2. Steam Methane Reforming .....	2
1.3. Application to Steam Generation.....	8
1.4. Research Objectives.....	11
1.5. Thesis Organization .....	12
CHAPTER 2. Literature Review.....	13
2.1. State-of-the-Art Steam Methane Reforming.....	15
2.1.1. Membrane Reactors .....	15
2.1.2. Aspects of Steam Methane Reforming .....	20
2.1.3. CO <sub>2</sub> Capture.....	25
2.1.4. Summary .....	26
2.2. Steam Methane Reforming Applications.....	27
2.3. Competitive Steam Generation Technologies .....	32
2.4. Research Needs for Steam Methane Reforming.....	35
2.5. Specific Aims of this Study .....	37
CHAPTER 3. Modeling Approach .....	39
3.1. Boiler Systems .....	45
3.2. SMR-MR-SG System .....	50
3.2.1. Model Overview .....	51
3.2.2. Assumptions and Input Parameters.....	57
3.2.3. Thermodynamic Analysis .....	63
3.2.4. Cost Calculations .....	75
3.3. CO <sub>2</sub> Capture.....	79
3.4. Technoeconomic Comparison .....	80
3.4.1. Baseline for Comparison.....	80
3.4.2. Cash Flow Analysis .....	83
CHAPTER 4. Results and Discussion .....	86

4.1.	Thermodynamic Results .....	86
4.1.1.	Process States and Energy Balances .....	86
4.1.2.	Comparison of Energy Consumption.....	89
4.2.	Technoeconomic Results .....	95
4.3.	Sensitivity Analysis .....	100
4.3.1.	Basic Analysis.....	100
4.3.2.	Monte Carlo Simulation.....	104
CHAPTER 5.	Conclusions and Recommendations for Further Work.....	111
5.1.	Recommendations for Future Work.....	112
5.1.1.	SMR-MR-SG Cycle Variants .....	112
5.1.2.	Summary .....	114
REFERENCES	.....	115
APPENDIX A.	Representative Calculation .....	122
A.1.	Thermodynamic State Points Calculation.....	125
A.2.	Energy Balance Calculation.....	134
A.3.	Capital and Operating Cost Calculation .....	137
A.4.	Cash Flow Analysis Calculation.....	139
APPENDIX B.	Heat Exchanger Sizing.....	141
B.1.	Single Phase .....	141
B.2.	Two Phase.....	145

## LIST OF TABLES

Table 2-1: Large-scale membrane reactor plants.....	19
Table 2-2: Scale of typical hydrogen consumers and producers. ....	19
Table 2-3: Boiler Inventory in the United States [40]. ....	33
Table 2-4: Summary of recent studies on membrane reforming technologies. ....	36
Table 3-1: List of major assumptions and input variables in thermodynamic model.....	40
Table 3-2: List of major thermodynamic modeling assumptions .....	41
Table 3-3: Enthalpy reference states for fluids used in Engineering Equation Solver. ....	42
Table 3-4: International currency exchange rates in January 2019. ....	45
Table 3-5: List of major input variables in technoeconomic model. ....	47
Table 3-6: Parameters for estimating capital costs using the scaling method. ....	49
Table 3-7: Temperature and pressure of states set directly by input parameters.....	69
Table 3-8: Example of heat exchanger temperatures crossing during thermodynamic model development.....	71
Table 4-1: Thermodynamic state points for SMR steam generation system. ....	87
Table 4-2: Relative thermodynamic comparison of SMR-MR-SG and boiler systems. ....	89
Table 4-3: Comparison of CO <sub>2</sub> capture and concentration energy penalties.....	93
Table 4-4: Key results of technoeconomic analysis. ....	95
Table 4-5: Input parameters varied and range of variation for sensitivity analysis.....	101
Table 4-6: Input parameters varied and PERT probability distribution parameters used in Monte Carlo simulation.....	105

Table A-1: State point descriptions for integrated steam methane reformer and steam generation system. ....	123
Table A-2: Definition of enthalpy terms used in calculations. ....	124
Table A-3: Hand calculations versus EES results to verify thermodynamic state points.....	125
Table A-4: Hand calculations versus EES results to verify energy balance parameters. ....	134
Table A-5: Hand calculations versus EES results to verify capital and operating costs. ....	137
Table A-6: Hand calculations versus EES results to verify cash flow analysis results. ....	139

## LIST OF FIGURES

Figure 1-1: Carbon emissions flow diagram for United States in 2014 [3].....	1
Figure 1-2: Simplified process flow diagram of steam methane reforming. ....	5
Figure 1-3: Industrial boiler quantity and boiler capacity by primary fuel [40].....	9
Figure 1-4: Size distribution of industrial boilers sold between 1992 and 2002 [40].....	10
Figure 1-5: Simplified steam methane reformer process flow diagram with steam generation. ..	11
Figure 2-1: Simplified process flow diagram of steam methane reforming with sweep gas.....	23
Figure 2-2: Tube-in-tube membrane reactor with sweep gas. ....	24
Figure 2-3: Simplified process flow diagram of steam methane reforming with a hydrogen turbine. .....	29
Figure 3-1: Process flow diagram for coupled SMR in a MR and steam generation system (SMR- MR-SG).....	50
Figure 3-2: Simplified process flow diagram of a coupled SMR and steam generation system. ..	53
Figure 3-3: Closest approach temperature (CAT) of fluids in a counter-flow heat exchanger. ...	54
Figure 3-4: United States natural gas industrial price history [5].....	81
Figure 4-1: Pinch points of heat exchangers in steam methane reformer steam generation cycle. .....	88
Figure 4-2: Energy flows for SMR-MR-SG system. ....	90
Figure 4-3: Energy flows for boiler system with CO <sub>2</sub> capture (BSC). ....	91
Figure 4-4: Discounted lifetime cost comparison between boiler and SMR-MR-SG systems. ...	97
Figure 4-5: Cash flow diagram comparing SMR-MR-SG to baseline steam generation systems.	99

Figure 4-6: Results of sensitivity analysis for SMR-MR-SG system compared to BS (a) and BSC (b)..... 103

Figure 4-7: Tornado chart showing Monte Carlo simulation of payback period of the SMR-MR-SG vs. BS (a) and vs. BSC (b)..... 107

Figure 4-8: Histogram showing Monte Carlo simulation of payback period of the SMR-MR-SG vs. BS (a) and vs. BSC (b)..... 109

## NOMENCLATURE

Symbol	Description	Units
$A$	Area	$\text{m}^2$
$Bo$	Boiling number	-
$C$	Heat capacity rate	$\text{kW K}^{-1}$
$C_p$	Specific heat capacity	$\text{kJ kmol}^{-1} \text{K}^{-1}$
$C_r$	Heat capacity rate ratio	-
$D$	Diameter	$\text{m}$
$dr$	Discount rate	%
$\frac{dP}{dz}$	Pressure drop with distance	$\text{Pa m}^{-1}$
$\dot{E}$	Energy flow	$\text{kW}$
$f$	Friction factor	-
$\dot{G}$	Mass flux	$\text{kg m}^{-2} \text{s}^{-1}$
$\dot{H}$	Flow enthalpy	$\text{kW}$
$h$	Enthalpy	$\text{kW kmol}^{-1}$
$ht$	Heat transfer (convection) coefficient	$\text{kW m}^{-2} \text{K}^{-1}$
$K$	Permeance	$\text{mol m}^{-2} \text{s}^{-1} \text{Pa}^{-0.5}$
$k$	Thermal conductivity	$\text{kW m}^{-1} \text{K}^{-1}$
$L$	Length	$\text{m}$
$M$	Molecular weight	$\text{kg kmol}^{-1}$
$\dot{m}$	Mass flow rate	$\text{kg s}^{-1}$
$N$	Number	-

$Nm^3$	Normal cubic meter	$Nm^3$
$n$	Number of years	-
$\dot{n}$	Molar flow rate	$kmol\ s^{-1}$
$P$	Pressure	bar
$P_H$	Heated perimeter	m
$P_W$	Wetted perimeter	m
$Pr$	Prandtl number	-
$\Delta P$	Pressure change	bar
$\dot{Q}$	Heat transfer rate	W
$q''$	Heat flux	$kW\ m^{-2}$
$R$	Thermal resistance	$K\ kW^{-1}$
$Re$	Reynolds number	-
$Re_f$	Reynolds number, superficial liquid	-
$Re_{fo}$	Reynolds number, liquid-only	-
$Re_g$	Reynolds number, superficial vapor	-
$Re_{go}$	Reynolds number, vapor-only	-
$Re_l$	Reynolds number, laminar	-
$Re_t$	Reynolds number, turbulent	-
$S$	Selectivity	-
$Su$	Suratman number	-
$T$	Temperature	$^{\circ}C$
$t$	thickness	m
$U$	Overall heat transfer coefficient	$kW\ m^{-2}\ K^{-1}$

$u$	Velocity	$\text{m s}^{-1}$
$UA$	Heat transfer conductance	$\text{kW K}^{-1}$
$\dot{V}$	Volumetric flow rate	$\text{m}^3 \text{s}^{-1}$
$\dot{W}$	Work	$\text{kW}$
$We$	Weber number	-
$X$	Fluid quality	-
$X_{LM}$	Lockhart-Martinelli parameter	-
$X_{tt}$	Turbulent-turbulent Martinelli parameter	-
$Y$	Mole fraction	-

#### Greek Symbols

$\alpha$	Thermal diffusivity	$\text{m}^2 \text{s}^{-1}$
$\varepsilon$	Heat exchanger effectiveness	-
$\eta$	Efficiency	-
$\mu$	Dynamic viscosity	$\text{Pa s}$
$\rho$	Density	$\text{kg m}^{-3}$
$\delta$	Surface roughness	$\text{m}$
$\sigma$	Surface tension	$\text{N m}^{-1}$
$\phi$	Two-phase multiplier	-

#### Subscripts and Superscripts

act	Actual	-
adj	Adjustment	-
amb	Ambient	-
avail	Available	-

avg	Average	-
boil	Boiling	-
boiler	(Baseline) boiler system	-
c	Cross-sectional	-
capt	Capture	-
CH <sub>4</sub>	Methane	-
CO <sub>2</sub>	Carbon dioxide	-
check	Check (of original calculation)	-
Churchill	Churchill correlation	-
cold	Cold fluid	-
comb	Combustion	-
comp	Compressor	-
cond	Condenser	-
conduc	Conduction	-
conv	Conversion	-
convec	Convection	-
cryo	Cryogenic separation unit	-
elec	Electricity	-
exh	Exhaust	-
export	Export	-
F	Frictional	-
f	Formation	-
Feed	Feed	-

fg	Liquid to gas phase change	-
fuel	Fuel	-
fluid	Fluid	-
gas	Gas phase	-
H	Heated	-
h	Hydraulic	-
HE	Heat exchanger	-
high	High pressure (feed) side of membrane	-
highP	High pressure	-
hot	Hot fluid	-
ht	Heat transfer	-
H <sub>2</sub>	Hydrogen	-
H <sub>2</sub> O	Water	-
i	Placeholder state number	-
ij	From gas i to gas j	-
in	In (to component)	-
input	Input	-
known	Known	-
liq	Liquid phase	-
load	Load	-
low	Low pressure (permeate) side of membrane	-
max	Maximum	-
mem	Membrane	-

membrane	Membrane only (not reactor)	-
min	Minimum	-
NG	Natural gas	-
nb	Non-boiling	-
new	New	-
N <sub>2</sub>	Nitrogen	-
o	Reference conditions	-
overall	Overall	-
O <sub>2</sub>	Oxygen	-
out	Out (to fluid)	-
per	Permeate	-
preheat	Preheating section	-
pump	Pump	-
r	Ratio	-
reac	Reaction	-
reactor	Reactor only (not membrane)	-
ret	Retentate	-
ref	Reference conditions (25°C, 1 bar)	-
reform	Reforming conditions	-
retentate	Retentate	-
sat	Saturation	-
sens	Sensible	-
sep	Separation	-

shell	Shell	-
SMR	Steam methane reformer system	-
steam	Steam	-
steamGen	Steam generation	-
supply	Supply	-
system	System	-
total	Total	-
tube	Tube	-
wall	Wall	-
water	Water	-
1	One shell pass	-
298K	Referenced to 298 K	-
$\Delta P$	Change in pressure	-
*	Modified	-

#### Abbreviations

BCE	Boiler combustion exhaust	-
BS	Boiler system	-
BSC	Boiler system with CO <sub>2</sub> capture	-
CapEx	Capital expense	k\$
CAT	Closest approach temperature	°C
CCC	Carbon capture and concentration	-
cCO <sub>2</sub>	Compressed carbon dioxide	-
CSU	Cryogenic separation unit	-


DCR	Discounted cost reduction	k\$
FV	Future value	k\$
HE	Heat exchanger	-
HHV	Higher heating value	$\text{kJ kg}^{-1}$
ICE	Internal combustion engine	-
ID	Inner diameter	m
k\$	Thousand US Dollars	k\$
LHV	Lower heating value	$\text{kJ kg}^{-1}$
M\$	Million U.S. dollars	-
MBtu	Thousand Btu	-
MMBtu	Million Btu	-
MR	Membrane reactor	-
NG	Natural gas	-
NPB	Net present benefit	k\$
NPV	Net present value	k\$
NTU	Number of transfer units	-
O&M	Operating and maintenance (excluding commodity purchases and sales)	k\$
OD	Outer diameter	m
OpEx	Operating expense	$\text{\$ yr}^{-1}$
PV	Present value	k\$
SC	Steam to carbon ratio	$\text{kmol kmol}^{-1}$
scf	Standard cubic feet (60°F, 1 atm)	scf
SMR	Steam methane reforming	-

SMR-MR- SG	Steam methane reforming in a membrane reactor steam generation system	-
ton	Short ton	ton
Val	Value	-
WGS	Water-gas shift	-

# CHAPTER 1. Introduction

## 1.1. Background

Global emissions from combustion of fossil fuels reached 32.31 Gton CO<sub>2</sub> in 2016, more than double the emission levels in 1970 [1,2]. In the United States, natural gas accounted for 27% of carbon emissions from combustion of fossil fuels in 2015, as shown in Figure 1-1 [3].



**Figure 1-1:** Carbon emissions flow diagram for United States in 2014 [3].

While the supply of non-renewable fossil fuels diminishes, the energy demands of the world continue to grow due to both global population and economic growth. In the next thirty years, the global demand for energy is expected to increase by 31%, with the global use of natural gas growing the most relative to any other energy commodity [4]. The increase in NG consumption is driven substantially by a decrease in its cost. For example, the average Henry Hub natural gas

spot price in 2018 (\$3.15 per MMBtu) is 36% of its average price in 2008 [5]. The realistic medium-term solution is not to stop using natural gas, but to use it in a cleaner and more efficient way. As regulations governing carbon emissions tighten [6], a significant and increasing tax will be placed on industrial carbon emissions in the near future. The development of efficient natural gas technology simultaneously decreases CO<sub>2</sub> emissions and provides a financial advantage.

One interesting pathway for clean and efficient natural gas consumption is the production of hydrogen. The use of hydrogen as a fuel for combustion is fundamentally clean with water as the only product. Hydrogen can be used in many ways, including in fuel cells for power generation or in electric vehicles [7]. However, hydrogen gas has low volumetric energy density and is challenging to store and transport [8]. It is also difficult to use as a standalone fuel due to lack of infrastructure and high cost [9].

A logical conclusion is to create hydrogen from natural gas. It takes advantage of the low price and availability of natural gas. Production of hydrogen from natural gas allows existing natural gas infrastructure to be used, which mitigates the need for new hydrogen infrastructure [9]. With hydrogen as a fuel, the usual emissions associated with natural gas are vastly reduced. The next section discusses a technologically and economically realistic method for producing hydrogen from natural gas.


## **1.2. Steam Methane Reforming**

The most common method of hydrogen production in the United States today is natural gas reforming, accounting for 95% of total hydrogen production [10]. A specialized subset of natural gas reforming is steam methane reforming (SMR), which uses a more refined fuel that is composed primarily or completely of methane. Although the details differ, the fundamental concepts of

natural gas reforming and steam methane reforming are the same. In the context of this study, “natural gas reforming” and “steam methane reforming” will be used interchangeably.

Currently the SMR reaction takes place in a conventional reformer in which methane reacts with high-temperature steam under very harsh operating conditions (800 - 1000°C and 1.5 - 2.0 MPa) to generate H<sub>2</sub> [11]. In order to maximize the H<sub>2</sub> yield, the intermediate product, CO, is later introduced into two high and low temperature water-gas shift (HT-WGS and LT-WGS) reactors [12,13]. The generated H<sub>2</sub> is later separated and purified via various techniques such as pressure swing adsorption (PSA), cryogenic distillation, physical scrubbing [14], or palladium (Pd)-based membrane [7,8,15]. PSA, a highly energy-intensive process, is the most common method for H<sub>2</sub> separation and purification in the industry [16,17].


In the SMR process, the steam and methane react over a catalyst, forming hydrogen and carbon monoxide via Equation (1.1) [10,18]:



It is important to note that Equation (1.1) is strongly endothermic, so a method for adding heat during the reaction is essential. Following, or often simultaneously with, this reaction, the carbon monoxide undergoes a water-gas shift reaction, converting carbon monoxide to carbon dioxide and producing more hydrogen via Equation (1.2):



Assuming both reactions go to completion in the forward direction, Equations (1.1) and (1.2) can be condensed into Equation (1.3) [19]:



Disadvantages of the current SMR process include harsh operating conditions, catalyst deactivation due to coking, blockage of reformer tubes, and high pressure drop within the reactor.


High-temperature, expensive alloy reformer tubes and a complex PSA design contribute to high capital and operational costs [13,17,20]. These drawbacks make the development of an alternative method of H<sub>2</sub> production via SMR a necessity.

Membrane reactor (MR) technology is an alternative method that can be used to perform the SMR reaction at milder operating temperatures. MR combines the advantages of catalytic reactors such as catalyst bed uniformity, and improved heat and mass transfer rates, with the advantages of selective membranes to increase methane conversion and hydrogen recovery. Specifically, by placing a metallic membrane inside the reactor, hydrogen is continuously removed from the reaction zone (retentate side) through the membrane [21]. The continuous withdrawal of H<sub>2</sub> from the permeate side shifts the reaction equilibrium further toward production of hydrogen according to Le Chatelier's principle [22]. A membrane with infinite permeability toward H<sub>2</sub> will allow for a collection of a pure stream of H<sub>2</sub> on the permeate side. Utilizing MR technology will allow for production of H<sub>2</sub> and capture of a highly concentrated CO<sub>2</sub> stream in a single unit. As a result, WGS reactors and H<sub>2</sub> purification units will be eliminated. Furthermore, high conversion values of methane to H<sub>2</sub> can be achieved at temperatures (around 400°C) that are much lower than the current industry values. Low operating temperatures result in lower energy intensity of the SMR process and higher-grade alloy steels can be replaced with lower grade and less expensive materials. MR technology will prevent coke formation and catalyst fouling in the reactor. Finally, since the partial pressure of CO<sub>2</sub> on the retentate side is much higher, more pure CO<sub>2</sub> can be captured with lower thermodynamic work [23].

Membranes used for H<sub>2</sub> separation can be divided into four categories based on the materials used in the fabrication of membranes: polymeric, metallic (dense and porous), carbon, and ceramic. Polymeric membranes are considered organic while the other three categories are

inorganic membranes [24]. Dense metallic membranes are of special interest due to their capability to produce pure H<sub>2</sub> in one single separation step with low energy penalty [25]. Palladium-based (Pd) metallic membranes are the best candidates for production of high purity hydrogen due to their ‘infinite’ selectivity towards H<sub>2</sub> permeation [26]. Pd-based separation and purification process can further be facilitated by using a sweep gas (Figure 1-2) [27–29].

Ideal products of SMR are just H<sub>2</sub> and CO<sub>2</sub>. In reality, the reaction doesn’t reach completion, so the products also contain CH<sub>4</sub>, H<sub>2</sub>O, and CO in addition to any impurities or higher hydrocarbons in the fuel. The hydrogen is separated from the rest of the products through a hydrogen-selective membrane. On the side of the membrane with the products (retentate), the partial pressure of hydrogen is high relative to on the other (permeate) side of the membrane. The pressure and concentration gradients force hydrogen through the membrane, creating a stream of pure hydrogen on the permeate side. Figure 1-2 shows the ideal steam methane reforming process, where ideal indicates the simple case of complete conversion of CH<sub>4</sub> and perfect separation of H<sub>2</sub>.



**Figure 1-2:** Simplified process flow diagram of steam methane reforming.

Steam methane reforming is not the only way to create hydrogen. In general, hydrogen is produced in two sub-processes: generation and separation [7]. One alternative method to SMR is electrolysis of water, which is a simple yet power-intensive process that uses an electrical power sources to generate hydrogen by separating water molecules. The produced hydrogen and oxygen

are separated by their separate generation on the anode and cathode of the system, respectively. After separation, another energy-intensive process is required in compression of the hydrogen gas. Electrolysis is rarely used in industrial hydrogen generation due to its significantly higher cost [30,31]. Coal gasification is another method of hydrogen production, where underground coal is converted to syngas and then refined into pure hydrogen [32]. This method promises reduced greenhouse gas emissions over traditional methane reforming, but still has significantly higher emissions than the membrane reactor technology proposed in this study.

On the other end of the complexity spectrum are protonic membrane reactors (PMR). PMRs are a specialized type of steam methane reformer which use a proton-conducting electrolyte to function as both an electrode and reforming catalyst. Produced hydrogen is simultaneously separated and compressed electrochemically through a nickel membrane. Protonic membrane reactors show promise of nearly full methane conversion, simultaneous hydrogen compression, and near zero net energy loss [33]. The downside is that they are significantly more complex and expensive, and have not been proven outside of academic investigations [33,34].

Steam methane reforming also has its drawbacks. Hydrogen-selective membranes are most often Palladium or Palladium alloys [7,8,15]. Even at typical membrane thicknesses of 10 to 50  $\mu\text{m}$ , material cost of the Pd can be prohibitive [9,33,35]. Steam is often flowed on the permeate side of the membrane to facilitate better permeation of hydrogen through the membrane [27–29]. This “sweep steam” adds complexity in that the hydrogen must then be separated from the sweep steam and often compressed before use. For example, fuel cells require nearly perfectly dry hydrogen for correct operation [36]. Steam methane reforming is used primarily for industrial hydrogen production, which only takes advantage of only one of its several outputs. In the correct

application, compressed CO<sub>2</sub>, waste heat, and low-grade steam could also be used to increase system efficiency and effectively reduce cost.

As with most competing technologies, all have their pros and cons. Steam methane reforming is the most effective method for hydrogen production from natural gas. It is better than any other method in energy efficiency, size, and cost [7,33]. It offers the opportunity to separate CO<sub>2</sub> in an integrated system, dramatically reducing carbon emissions. Even considering upstream processes, hydrogen produced through SMR and used to power fuel cell electric vehicles cuts greenhouse gas emissions and petroleum use by 50% and 90%, respectively [10]. Although steam methane reforming uses only methane as its fuel source, many sources show the efficacy of other fuels including natural gas of various compositions, methanol, ethanol, propane, and even gasoline [7,8,10]. There are complications that arise from different fuels. For example, methanol and ethanol used as fuel in membrane reforming can reverse the water gas shift reaction, reducing system efficiency [37]. This study will focus only on natural gas as a reforming fuel. As mentioned earlier, SMR is by far the most common industrial method for producing hydrogen from natural gas [10,15]. This is tangible evidence that steam methane reforming with natural gas is the best technology in this category.


Despite SMR's ubiquitous application to hydrogen production, its application to other areas in industry is somewhat limited. Hundreds of studies in the last decade have continued to develop the state-of-the-art in membrane reformer technology. While there are many promising results, the use of industrial SMR has remained more or less unchanged. There are several barriers to the acceptance of this relatively new technology, including lack of a single study unifying all desirable aspects of SMR and missing proof of additional, economically realistic, applications of SMR.

An important distinction of this study is that it aims to go beyond theoretical modeling by supplying an appropriate application of the proposed technology. In industry, new technology is seldom introduced unless it can make a solid business case. In this context, the business case is that (a) there is a logical application of SMR, and (b) SMR can be applied in a cost-effective way. Steam methane reforming is already widely used in industry for hydrogen production. Several authors, including this one, have investigated using SMR in power generation with gas turbines and combined cycle plants [18,34,38,39]. After testing the waters with modeling in several fields of industry, this study chose to focus on steam generation.

### **1.3. Application to Steam Generation**

Steam generation relies heavily on natural gas as a fuel source. Energy and Environmental Analysis, Inc (EEA) estimates that there are 163,000 industrial and commercial boilers in the U.S. These boilers consume 8,100 TBtu per year, which equates to 40% of energy use in the industrial and commercial sectors [40]. Combining the industrial and commercial sectors, Figure 1-3 shows that roughly 73% of all boiler fuel comes from natural gas. This equates to 5,900 TBtu, or 5.69 Trillion cubic feet of natural gas per year [41]. To put this into perspective, the energy in natural gas used just in U.S. steam boilers could supply about half of New York City's electricity continuously [42].

Clearly, the United States relies heavily on natural gas in steam generation. Recalling an earlier conclusion, it is imperative to work towards using natural gas in a more clean and efficient way. Steam generation provides an excellent application upon which to focus this effort. The sheer volume of energy involved in steam generation throughout the country gives potential for significant cost, energy, and emissions savings.




**Figure 1-3:** Industrial boiler quantity and boiler capacity by primary fuel [40].

Existing boiler technology is largely outdated: 76% of boilers currently operating in the United States are at least 30 years old. Of those, even the largest scale industrial boilers achieve only 80-86% efficiency [40]. It's not surprising that boilers are not updated to a newer technology; the design of boilers hasn't changed significantly in the last 30 years, they work reliably, and it would be expensive to replace them with a new technology. However, updating steam generation technology could have profoundly positive consequences. Steam methane reforming provides a realistic path to improving efficiency and reducing emissions associated with steam generation.

Steam generation is a large market. Approximately 7,200 industrial boilers are sold each year in the United States, with an estimated total of 163,000 boilers currently in operation [40]. Figure 1-4 shows the size distribution of these boilers. Boilers in the 1 – 10 MMBtu h<sup>-1</sup> account

for the largest number of boiler sales by far. The average unit size in that range is 3.5 MMBtu h<sup>-1</sup>; this size will be the focus of this study.




**Figure 1-4:** Size distribution of industrial boilers sold between 1992 and 2002 [40].

There are many possible ways to improve upon the current steam generation process, but steam methane reforming is the most effective. An important barrier to new energy technology is the additional infrastructure required to support it. SMR allows for the benefits of clean-burning hydrogen fuel without the need to move away from natural gas. At the same time, SMR mitigates many of the potential problems of hydrogen fuel, chiefly transport and storage, by taking advantage of the well-developed natural gas infrastructure.

## 1.4. Research Objectives

The goal of this study was to explore a new application of steam methane reforming: steam generation. The process lends itself to steam generation: Figure 1-5 shows a simplified process flow diagram for steam generation using SMR in a membrane reactor (SMR-MR-SG).



**Figure 1-5:** Simplified steam methane reformer process flow diagram with steam generation.

Note that the only two inputs are the same as for a traditional boiler: natural gas and water. The largest difference is that, if the system is designed and executed correctly, the only outputs are generated steam, cold nitrogen exhaust, and compressed CO<sub>2</sub>. The compressed CO<sub>2</sub> can be sold or used instead of rejected as emissions. In this configuration, there is also reduced water consumption if the generated steam from H<sub>2</sub> combustion is recycled back into the system. The concept of recycling steam and water throughout the system will be discussed further in the thermodynamic modeling sections.

The proposed system uses natural gas as a fuel as in conventional SMR, but the main product of the system is steam rather than H<sub>2</sub>. Hydrogen is generated as an intermediate product in the membrane reactor, then burned to generate steam without the carbon emissions associated with conventional natural gas combustion. Based on the results of this investigation, the new

technology could be a direct replacement for industrial steam boilers, offering better efficiency, lower cost, and reduced CO<sub>2</sub> emissions.

This study developed a coupled thermodynamic and economic model in Engineering Equation Solver (EES) to evaluate performance of the proposed system. The model was compared to two other baseline technologies: a state-of-the-art industrial boiler system, and the same boiler system with the addition of CO<sub>2</sub> capture. Results of the proposed system were compared to the two baselines on a thermodynamic and economic basis

## **1.5. Thesis Organization**

The remainder of this thesis expands on the concept of a steam methane reformer system in an industrial context. Chapter 2 provides a detailed review of the current literature, addressing state-of-the-art reforming technology and the suitability of steam generation as an application. Chapter 3 dives into the development of a thermodynamic and coupled technoeconomic model. Chapter 4 discusses the results of modeling and the highlights of the study. Finally, Chapter 5 summarizes the main points of the study and provides recommendations for future work.

Appendix A contains representative calculations which help to prove the results of the model reasonable. The calculations also served as a careful check to catch typos or other errors in the modelling program. Appendix B contains detailed calculations for sizing heat exchangers. This was necessary to determine the cost of heat exchangers in the technoeconomic analysis, but was moved to an appendix to avoid distracting the reader from the system-level analysis.

## CHAPTER 2. Literature Review

This study will focus on a practical application of steam methane reforming to industrial steam generation. Steam methane reforming is a technique to produce hydrogen from natural gas. There are other methods to produce hydrogen from natural gas, but SMR has been shown to be superior due to ultra-high efficiency and potential for carbon capture. Although SMRs produce hydrogen from natural gas (or methane), they can vary widely in the process, effectiveness, and additional features of the system. The following will explain several details of steam methane reforming, including their desirability and consequences. Next, the metrics of comparison in this study will be discussed. Following the overview, a literature review will be presented to establish what is known and what this study has to offer.

At its most basic, steam methane reforming converts methane into hydrogen according to the net reaction given by Equation (2.1):



Methane conversion is defined as the percentage of methane that is converted to hydrogen.

Methane conversion is defined in Equation (2.2):

$$\eta_{CH_4,conv} = \frac{1 - \dot{n}_{CH_4,ret}}{\dot{n}_{CH_4,feed}} \quad (2.2)$$

The ideal methane conversion is 100%, where there is no methane left in the retentate. Hydrogen recovery is defined by Equation (2.3) as the ratio of permeated hydrogen to available hydrogen on the feed side:

$$\eta_{H_2,capt} = \frac{\dot{n}_{H_2,per}}{\dot{n}_{H_2,avail}} \quad (2.3)$$

It is important to note that methane conversion and hydrogen recovery are not directly linked. For example, with perfect (100%) methane conversion, it is possible that all, none, or any amount of the hydrogen permeates through the membrane. Any produced hydrogen that does not permeate through the membrane exits the reactor in the retentate stream.

Steam methane reforming requires several processes at minimum: two chemical reactions (reforming and water-gas shift), heat transfer to support the highly endothermic reforming reaction, and separation of hydrogen from the retentate to the permeate stream. These processes may be carried out in separate steps or in parallel. This study defines an integrated membrane reactor as one where all three processes (two reactions, heat transfer, and hydrogen) are achieved in a single step and single physical device. There are many benefits of using a membrane reactor over conventional steam methane reforming such as a lower reforming temperature and a less complicated system.

Waste heat recovery is a broad term because it can vary depending on the application. In this thesis, it refers to capturing the sensible energy from the retentate, permeate, and heating streams coming out of the membrane reactor. CO<sub>2</sub> separation is defined as the separation of CO<sub>2</sub> from the rest of the retentate stream. This may be accomplished cryogenically, via compression, or by other methods. In reality, SMRs don't achieve perfect methane conversion or hydrogen recovery. Therefore, it makes sense to mix the retentate stream back into the feed. In most instances, the retentate stream contains CH<sub>4</sub>, H<sub>2</sub>, CO<sub>2</sub>, CO, and H<sub>2</sub>O (assuming imperfect water and CO<sub>2</sub> separation/condensation as well). This is referred to in this study as gas recycling.

The essence of this study is a comparison between steam methane reforming and other steam generation technologies. The comparison will be quantified both thermodynamically and economically. Thermodynamic metrics of comparison include amount of waste heat, fuel

consumption, and overall system efficiency. Economic metrics include capital cost, total cost of ownership, and payback period. To achieve a fair comparison, the systems will be set at the same scale with the same net output.

The remainder of this chapter will describe and compare literature relevant to state-of-the-art steam methane reformer technology and competitive steam generation technology. The literature will help guide and give context for the modeling approach, and discussion of SMR technologies as applied to steam generation. This review will highlight the gaps in current research, showcase the importance of filling those gaps, and explain how this study will round out the knowledge in this field.


## 2.1. State-of-the-Art Steam Methane Reforming

### 2.1.1. Membrane Reactors


In conventional steam methane reforming, methane reacts with high-temperature steam under very harsh operating conditions (800 - 1000°C and 15 - 20 bar) to generate H<sub>2</sub> in the reforming reaction given by Equation (3.24) [18]:



To maximize the H<sub>2</sub> yield, the intermediate product, CO, is later introduced into two high and low temperature water-gas shift (WGS) reactors [12,13] which perform the reaction of Equation (3.25) [18]:



These two reactions can be combined into an overall reaction, The overall SMR reaction that includes WGS is given by Equation (3.26) [18,19]:



The generated H<sub>2</sub> is later separated and purified via various techniques such as pressure swing adsorption (PSA), cryogenic distillation, physical scrubbing [14], or a palladium (Pd)-based membrane [7,8,15]. PSA, a highly energy-intensive process, is the most common method for H<sub>2</sub> separation and purification in the industry [16,17].

The harsh operating conditions of conventional SMR cause multiple challenges, including: catalyst deactivation due to coking, blockage of reformer tubes and therefore high pressure drop within the reactor, use of high-temperature resistant and expensive alloy reformer tubes for the reactor construction, complex design of the PSA system, and high capital and operational costs [13,17,20]. These drawbacks are one of the main reasons that different approaches to generate H<sub>2</sub> continue to be explored. Membrane reactors (MR) are particularly attractive because they enable simultaneous SMR and WGS reactions at milder operating conditions with continuous H<sub>2</sub> separation. In an MR, a metallic membrane is placed inside the reactor to continuously remove H<sub>2</sub> from the reaction zone (retentate side) through the membrane [21]. The continuous removal of H<sub>2</sub> from the retentate to the permeate across the metallic membrane shifts the reaction equilibrium toward production of hydrogen according to Le Chatelier's principle [22]. A membrane with 'infinite' permeability toward H<sub>2</sub> will allow for a collection of a 99.999%-purity stream of H<sub>2</sub> on the permeate side, with no H<sub>2</sub> retained on the reaction side. As a result, once excess water is removed in the SMR-WGS retentate side, a highly concentrated CO<sub>2</sub> stream can be produced in a single unit without the need for H<sub>2</sub> purification units. Membranes can be described by both their permeability and permeance. Permeability describes the rate of flux through the membrane of specific thickness, per pressure difference, per surface, and is reported in units of mol m m<sup>-2</sup> s<sup>-1</sup> Pa<sup>-0.5</sup>. Permeance is simply permeability divided by the membrane thickness, and has units of mol m<sup>-2</sup> s<sup>-1</sup> Pa<sup>-0.5</sup>.

There is a tradeoff between selectivity and permeance in membranes. Ideal selectivity is defined for a specific membrane and a pair of gases as the ratio of permeances of each pure gas under the same operating conditions, given by Equation (2.7) [43]:

$$S_{ij} = \frac{K_i}{K_j} \quad (2.7)$$

where gas  $i$  is H<sub>2</sub> in the context of Pd membranes used in SMR. The relationship between selectivity to H<sub>2</sub> and permeance of H<sub>2</sub> in dense Pd membranes is complicated in SMR because there are more than two gases on the reacting side of the membrane. It is further complicated by the interplay between H<sub>2</sub> permeation and reaction equilibrium: increased permeation drives the reaction further towards the products. In general, increased selectivity to H<sub>2</sub> reduces permeance, but the relationship is highly non-linear and also depends on temperature, pressure, and space velocity within the reactor. Based on frequent reports of infinite selectivity of H<sub>2</sub> in Pd membranes reported in literature, this study assumes a infinitely selective Pd membrane with state-of-the-art permeance.

High conversion values of methane to H<sub>2</sub> can be achieved at moderate temperatures (~400°C) that can result in lower energy intensity and enable use of less expensive materials. MR technology also prevents coke formation and catalyst fouling in the reactor. Finally, since the partial pressure of CO<sub>2</sub> in the retentate side is much higher, less work will be required for separation compared to conventional systems [23].

Membranes used for H<sub>2</sub> separation can be divided into four categories based on the materials used in the fabrication of membranes: polymeric, metallic, carbon, and ceramic. Polymeric membranes are considered organic while the other three categories are inorganic membranes [24]. Dense metallic membranes are of special interest due to their capability to produce pure H<sub>2</sub> in one single separation step with low energy penalty [25]. Palladium-based (Pd)

metallic membranes are the best candidates for production of high purity hydrogen due to their ‘infinite’ selectivity towards H<sub>2</sub> permeation [26]. The Pd-based separation and purification process can further be facilitated by using a sweep gas [27–29].

Due to the presence of the membrane, the generated H<sub>2</sub> is continually separated and transported to the permeate side. As a result, excess steam in the retentate is used to facilitate the water-gas shift reaction (Equation (2.5)) to generate additional H<sub>2</sub> that permeates through the membrane. The net reaction (Equation (2.6)) yields concentrated CO<sub>2</sub> in the retentate, which can be readily captured through removal of excess H<sub>2</sub>O.

Thousands of studies over the last two decades have shown great potential for membrane reactors in terms of improved efficiency, reduced CO<sub>2</sub> emissions, reduced size, and reduced cost versus conventional SMR plants. However, the current status of the technology is that it continues to be developed and has not reached commercialization. Two particular developers have designed and built semi-industrial scale test facilities. De Falco et al have been running a plant producing 20 Nm<sup>3</sup> h<sup>-1</sup> of hydrogen since 2011 [44]. Kurokawa et al have been testing a 40 Nm<sup>3</sup> h<sup>-1</sup> plant in Japan, using cryogenic separation of CO<sub>2</sub> to reduce emissions [47]. Table 2-1 shows several large-scale membrane reactor test facilities. Even these “semi-industrial” scale plants are very small relative to existing, conventional SMR plants. Table 2-2 gives the scale of common applications of hydrogen energy for context. The current state of membrane technology is that it continues to be investigated at progressively larger scales, but it hasn’t been fully commercialized yet. The main research goals in the membrane reactor sector are to validate MR effectiveness and stability while narrowing in on optimal operating conditions.

**Table 2-1:** Large-scale membrane reactor plants.

Developer	Location	Membrane Thickness [ $\mu\text{m}$ ]	Scale		Novelty
			Surface Area [ $\text{m}^2$ ]	Hydrogen Production [ $\text{Nm}^3 \text{h}^{-1}$ ]	
Kurokawa et al. <sup>a</sup>	Japan	N/A	N/A	40	Large scale
De Falco et al. <sup>b</sup>	Italy	3 – 25	0.13 – 0.6	20	Large scale, operation >10 yr
ECN <sup>b</sup>	The Netherlands	3 – 9	0.4	N/A	Alumina support
MRT <sup>b</sup>	Canada	8 - 15	0.6	N/A	Rolled foil or deposited film membranes
JC <sup>b</sup>	Japan	N/A	0.00283	N/A	$\text{Al}_2\text{O}_3$ support
SINTEF <sup>b</sup>	Norway	2 – 3	N/A	N/A	Macroporous substrate support
ACKTAR <sup>b</sup>	Israel	3 – 5	N/A	N/A	Steel substrate support

<sup>a</sup> Kurokawa et al. [47]  
<sup>b</sup> De Falco et al. [44]

**Table 2-2:** Scale of typical hydrogen consumers and producers.

Application	Hydrogen Consumption or Production [ $\text{Nm}^3 \text{h}^{-1}$ ]
Single $\text{H}_2$ -fueled car <sup>a</sup>	0.25
Neighborhood <sup>a</sup>	75
Commercial Scale SMR Plant <sup>a</sup>	100 – 500
Small Industrial Scale SMR Plant <sup>a,b</sup>	500 – 10,000
Large Industrial Scale SMR Plant <sup>b</sup>	10,000 – 300,000

<sup>a</sup> Schjøberg et al [45]  
<sup>b</sup> Rostrup-Nielsen [46]

Steam methane reforming, both conventional and in membrane reactors, has many aspects that have been investigated in detail individually. Examples of targeted studies include variations on thermodynamic parameters [7,8,15,19], developing a single integrated unit to reduce cost [48–52], investigating the effects of sweep gas [7,8,15,34], integrating system-supplied heat of reaction [15,34,53], and membrane fabrication techniques [27,29,54]. The following section will discuss each of these in more detail.

### 2.1.2. Aspects of Steam Methane Reforming

Conventional steam methane reforming has been studied in-depth many times. It is a common technology used for industrial hydrogen generation, typically in a tubular reforming plant [55]. Membrane reactors are a subset of SMR, and as such share many aspects including methane conversion, CO<sub>2</sub> capture, and heat transfer during reforming. On the other hand, some aspects such as sweep gas and hydrogen capture through a membrane are unique to membrane reactors. This section will survey recent literature to ascertain the state-of-the-art in membrane reactor technology and discover which questions still need to be answered.

The basic concept of steam methane reforming has been modeled thoroughly and with many variations [7,8,15,19]. However, experimental validation is much less common. Membrane reactors are not convenient nor easy to set up for experiments. The membranes are typically palladium or palladium alloys that are expensive and challenging to fabricate [7,36,39]. The systems consume and produce explosive gases at high pressures and temperatures leading to safety concerns. Furthermore, realistic applications of SMR require industrial scale implementation; scaling down to a laboratory experiment is difficult and can yield significantly different results. There are some particular areas within steam methane reforming that lack experimental validation including heat supply in a membrane reactor, heat recovery, and CO<sub>2</sub> capture.

As previously discussed, steam methane reforming requires a net endothermic reaction and subsequently a continuous heat addition to supply the heat of reaction. This is critical to a high performance system, as higher reaction temperatures are generally correlated to higher conversion rates of methane [34]. The logistics of supplying heat are overlooked in many papers. Membrane reactors with integrated heat exchange have advantages in simplicity and cost over systems with an external heater or combustor [15,34,53]. The common practice in industrial hydrogen

production is for an external furnace to the heat of reaction [53]. In the integrated reactor approach, methane conversion, hydrogen recovery, and heat transfer to support reforming all occur simultaneously in a single reactor module. This paper refers to an integrated reactor as a “membrane reactor”, as opposed to a “membrane reformer”.

Membrane reactors have more benefits besides supplying heat. They combine the reforming reaction (including the water-gas shift) and hydrogen separation into one volumetrically compact unit [48]. Integrating the reforming reaction and separation of produced hydrogen has been shown to reduce capital cost [49]. Additionally, membrane reactors reduce capital cost compared to a conventional reformer and non-membrane separator because the reactors don't require a pressure-swing adsorption system to separate hydrogen [50].

Another important facet of steam methane reforming is waste heat recovery. SMR lends itself to recovering waste heat; the outlet streams besides the desired hydrogen permeate are typically at high temperature and pressure. In addition to recovering the enthalpy of outlet streams, the fluid composition often carries energy. The permeate in particular can contain significant amounts of unburned natural gas [56–58]. This leftover natural gas can be burned to produce heat and remove it from the stream so that carbon dioxide may be separated more easily. Two useful places to use recovered waste heat are in the reactor itself to help supply the heat of reaction and in steam generation for both the reaction and sweep gas.

Another method for recovering energy from the retentate stream is to recycle the “leftover” gas into the feed. In a real-life implementation, imperfect methane conversion, hydrogen separation, and carbon dioxide sequestration leave those three gases left in the retentate stream. Instead of exhausting those net products, gas recycling creates a closed loop for methane, hydrogen, and carbon dioxide in the system. This ensures that there is no exhaust from the system

other than generated steam; everything else is simply recycled back to the feed side of the reactor for a second pass.

In reformers with an integrated reactor and membrane separator, the diffusion of hydrogen across the membrane is the rate-limiting step [7,19,22]. The driving force for hydrogen permeating through a membrane is related to the difference between the partial pressure of hydrogen on each side of the membrane; a higher pressure difference causes a faster flow of hydrogen. The feed and retentate are at a higher pressure than the permeate to force hydrogen to diffuse from the retentate to the permeate side [18]. The diffusion flow rate of hydrogen through the membrane is given by Equation (2.8) [22]:


$$\dot{n}_{\text{H}_2, \text{mem}} = K_{\text{mem}} A (P_{\text{ret}}^n - P_{\text{per}}^n) \quad (2.8)$$

where  $K_{\text{mem}}$  is the permeance of the membrane, commonly reported in units of  $\text{mol m}^{-2} \text{s}^{-1} \text{Pa}^{-0.5}$ . In layman's terms, permeance is the ability of a membrane to let a gas pass through it; a higher permeance means more gas flow for a given surface area and pressure difference. The value of  $n$  is 0.5 for dense Palladium based membranes [22,59]. It follows that, for a given membrane, there are two ways to increase diffusion of hydrogen through the membrane: increasing the partial pressure in the retentate and or decreasing the partial pressure in the permeate.

Increasing the partial pressure of the retentate-side hydrogen is most easily achieved by increasing the feed (natural gas and steam) pressure. This is beneficial because it increases hydrogen permeation rate but also because it makes subsequent separation of  $\text{CO}_2$  via compression and condensation easier. On the other hand, excessively high-pressure reactors are limited by practical concerns. Exceeding pipeline supply pressure of natural gas (approximately 65 bar) requires further natural gas compression, which hurts the overall system efficiency [34]. Steam at 65 bar will condense at  $280^\circ\text{C}$ , which can make waste heat recovery more challenging. Finally,

high pressure requires stronger materials. With expensive palladium alloy membranes in the 1-10  $\mu\text{m}$  thickness range, membrane failure due to high pressure is a real concern. On the other hand, a higher feed pressure allows a higher permeate pressure, which reduces the high energy penalty of compressing hydrogen after separation if needed [53]. The conclusion is that there is an optimal range of pressures for the feed side to balance the benefits with the additional cost and complexity. Manzolini et al. suggest an optimized cost near natural gas pipeline pressure [34].


Addressing the other half of the diffusion driving force, the partial pressure of the permeate can be lowered. This is most commonly achieved in the literature by introducing a sweep gas, as shown in Figure 2-1.



**Figure 2-1:** Simplified process flow diagram of steam methane reforming with sweep gas.

Sweep gas is a gas, often steam, that is introduced on the permeate side to facilitate hydrogen permeation. Hydrogen permeation is increased through two separate mechanisms. Assuming total permeate pressure is the same with or without sweep gas, the addition of sweep gas lowers the partial pressure of hydrogen by diluting the permeate stream. Second, the sweep gas carries momentum with it that helps move hydrogen away from the membrane and to the permeate outlet of the reactor, lowering the amount of hydrogen and thus the partial pressure local to the membrane. Figure 2-2 shows one possible configuration for a physical tube-in-tube type membrane reactor incorporating sweep gas. A less common but effective method for enhancing

hydrogen permeation is to burn some of the permeate. Similar to the sweep gas, this reduces the concentration of hydrogen while introducing more steam (from combustion), effectively reducing the partial pressure of hydrogen [18]. Furthermore, the heat from the combusted permeate can be used to supply heat to the reforming reaction. Manzolini et al. writes that about 25% of the permeated hydrogen needs to be burned to sustain the reforming reaction [34]. This integrated heat source both enhances hydrogen permeation and increases overall system efficiency.



**Figure 2-2:** Tube-in-tube membrane reactor with sweep gas.

Hydrogen permeation through the membrane and methane conversion on the feed/retentate side are intimately linked. A large advantage of membrane reformers over other devices that implement steam methane reforming is that the thermal equilibrium of the reforming reaction (Equation (2.1)) can be shifted further towards the products due to the removal of products (i.e., hydrogen diffusing through the membrane), yielding a higher methane conversion percentage [53]. The two parameters improve together: if hydrogen is removed faster, the reforming reaction tends to move further towards the products. If the reaction equilibrium is shifted towards the products, the partial pressure of hydrogen on the retentate side increases, increasing the concentration

gradient and driving force for hydrogen diffusion through the membrane. This effect has been modeled and validated thoroughly in literature [7,8,15,34].

A more straight-forward method of improving methane conversion and hydrogen recovery is to reduce the thickness of the membrane. Recalling Equation (2.8), the flow rate of hydrogen through the membrane is inversely proportional to its thickness. An additional benefit is financial; the cost of membranes is driven by the material cost of precious metals (Pd, Au, Ag), so using less material reduces membrane capital cost. State-of-the-art membranes are palladium alloys with thicknesses under  $3\mu\text{m}$  thickness [60,61]. There is a need for mechanical strength to support the pressure difference between the feed and permeate sides, which can be over 100 bar difference. Membranes are often deposited on a porous, ceramic or metallic substrate to provide mechanical support. An ideal membrane support offers no resistance to hydrogen (or other gas) permeation. The membrane may be attached or deposited on the support material by several methods including electroless plating [27,29,54].

### **2.1.3. CO<sub>2</sub> Capture**

Transitioning from methods to increase conversion and permeation efficiencies, carbon dioxide separation and storage is a key component of most SMR systems. Carbon dioxide is present in the retentate stream in a significant concentration, along with H<sub>2</sub>O, H<sub>2</sub>, and CH<sub>4</sub>. This assumes that the water-gas shift has converted all of the CO and that pure methane (as opposed to natural gas) is used as a fuel. The concentration of carbon dioxide in the retentate (after hydrogen separation) is typically above 30% by mole. If the products were perfectly separated, the H<sub>2</sub>O would be recycled, CO<sub>2</sub> compressed and stored, CH<sub>4</sub> recycled into the feed, and H<sub>2</sub> either recycled to the feed or burned to produce heat. There are three popular methods of separating CO<sub>2</sub> from the retentate stream.

The first method of separating CO<sub>2</sub> is by introducing air or oxygen into the retentate stream and combusting it. This eliminates the CH<sub>4</sub> and H<sub>2</sub>, producing more steam and CO<sub>2</sub> [18,34]. The steam can easily be then be condensed out by cooling, leaving only CO<sub>2</sub> gas. Depending on the retentate pressure, the CO<sub>2</sub> can then be compressed, creating a high purity, compressed CO<sub>2</sub> stream for storage [34]. The second method is to liquefy the CO<sub>2</sub>. The water is first condensed out of the other gases, which can be done easily and effectively by dropping the temperature while holding temperature constant. Then, additional cooling and or compression liquefies the CO<sub>2</sub>, which can be separated from the remaining CH<sub>4</sub> and H<sub>2</sub>. The heat duty of water and CO<sub>2</sub> cooling can be recovered in a heat exchanger to increase the overall system efficiency. The third method of separating CO<sub>2</sub> is to pass it through a CO<sub>2</sub>-selective membrane [8]. This method is simple and passive, but does not achieve as high separation percentages as the first two.

Particularly in steam methane reforming systems with high feed and retentate pressures, carbon dioxide sequestration can be accomplished with little economic or thermodynamic penalty relative to other carbon-free technology [53]. CO<sub>2</sub> capture and hydrogen separation can be combined into one integrated reactor to mitigate the need for additional equipment or size [51,52]. Carbon capture ratios up to 100% have been modeled and validated [34]. Carbon dioxide sequestration is important, as SMR is branded as a “clean” technology of the future. The strategies for CO<sub>2</sub> sequestration discussed here have been proven to be effective with an overall system efficiency loss of less than 1 percentage point [22].

#### **2.1.4. Summary**

Section 2.1 has discussed the state-of-the-art in steam methane reforming. The technology is relatively new but has been investigated in detail in the literature. Reactors have been developed with integrated thermal management to supply heat for the reforming reaction. Methods of waste

heat recovery and gas recycling have been modeled, optimized, and validated. There are many ways to increase methane conversion and hydrogen recovery, most of them with tradeoffs in cost and complexity. The details and methods of carbon dioxide sequestration have been analyzed and compared.

The next section will investigate commercial and industrial applications of steam methane reforming. It will address both existing and proposed technologies, evaluating the feasibility of each. Then, steam generation will be introduced as a proposed application of steam methane reforming that optimizes its thermodynamic and economic potential.

## **2.2. Steam Methane Reforming Applications**


While steam methane reforming has been studied extensively, it has been limited in number of practical applications. The only significant industrial or commercial practice of steam methane reforming is in plant-scale hydrogen production. Although SMR has the capability of capturing CO<sub>2</sub>, SMR used for hydrogen production is usually associated with greenhouse gas emissions due to insufficient CO<sub>2</sub> capture [62]. Academic studies have investigated SMR's use in electricity generation via several methods. It has also explored on-board (small scale, mobile system) hydrogen production for automotive applications, but none of these have implanted at scale beyond academia. This section will cover commercial, industrial, and academic applications of steam methane reforming, then compare them to a proposed new application: steam generation via SMR.

Hydrogen production via steam methane reforming is a tried and true process. It works well thermodynamically and is cost effective. However, it only utilizes part of potential of SMR. The main product of steam methane reforming is high purity hydrogen, but there are other products as well. Compressed, high purity CO<sub>2</sub> is a common byproduct. It is valuable to capture CO<sub>2</sub> instead of releasing it to the environment as exhaust, but even more value can be derived from selling it

or using it directly. Steam is an integral part of the SMR process. In certain configurations, a system can produce net steam by generating more water than it consumes. Again, heat can be recovered and the water can be recycled, but it would be more beneficial to choose an application where steam is desired. Hydrogen is usually carried by a sweep gas, which is often steam. The hydrogen can be separated and compressed for the end goal of hydrogen production, but there are other pathways with more direct use of the fluid streams and less thermodynamic losses. Steam methane reforming is a promising technology but is not currently being utilized to its fullest potential.

One potential application for steam methane reforming is electricity production. For an apples to apples comparison, SMR should be compared to other electricity generation technologies that don't exhaust carbon dioxide: solar electric, wind turbines, hydroelectric, etc. There are limitless variations of process flows to incorporate SMR and electricity generation. This review will focus on the two most common in literature: hydrogen turbines and fuel cells.

On a fundamental level, most studies involving SMR and hydrogen turbines consist of a few main components: a membrane reformer (converts NG to H<sub>2</sub>), turbine (converts H<sub>2</sub> to shaft work and heat), waste heat recovery (moves heat from turbine exhaust to steam and NG heating), and a condenser (separates out water and CO<sub>2</sub>). A conceptual process flow for such a system is shown in Figure 2-3.



**Figure 2-3:** Simplified process flow diagram of steam methane reforming with a hydrogen turbine.

Hydrogen turbines coupled to a SMR can be used for several purposes, including generating electricity or providing shaft work to another process. Generating electricity using a hydrogen turbine is a seemingly appropriate application for SMR. The high energy content exhaust can be used to supply the heat of the reforming reaction. The permeate can be combusted in either the same or a different turbine, with or without sweep gas, to provide additional heat or power [63]. Combusting the remaining hydrogen and methane in the permeate stream is also an inexpensive method of capturing CO<sub>2</sub> [34]. After combustion, the only products are CO<sub>2</sub> and water. The water is easily condensed out at ambient temperatures, leaving nearly pure CO<sub>2</sub>.

One study located a steam methane reformer downstream of a coupled gas turbine for the co-production of hydrogen and power, effectively raising the system's efficiency by 10% [63]. In that scenario, the exhaust of the turbine was again used as the heat source for reforming. However, the reforming reaction requires about 80% of the system's heat duty [64], leaving insufficient heat for high efficiency waste heat recovery. Jordal et al. found that steam methane reforming integrated into a combined cycle can capture 100% CO<sub>2</sub>, but with an overall thermal efficiency of only 47.9% [59]. Furthermore, hydrogen turbines are uncommon. The development of a hydrogen turbine for

this specific application would be prohibitively expensive [63]. One study of electricity generation via SMR showed that it resulted in a 30% increase in the price of electricity compared to a conventional natural gas combined cycle without CO<sub>2</sub> capture [34]. This result is not used as a direct comparison but rather to show that SMR implemented in electricity generation significantly increases the operating costs. Another possible application of SMR is coupled to fuel cells.

As “clean” technologies such as fuel cells evolve, the demand for clean vehicle fuels increases. Hydrogen is an attractive fuel, either used directly for combustion or for electricity generation. For example, a fuel cell vehicles running on hydrogen can be 3 times more efficient than an internal combustion engine vehicle with only water vapor as exhaust [22]. The demand for hydrogen as a potential alternative automotive fuel is constantly increasing [65]. Specifically, Sanusi et al. predict that demand for hydrogen in the transportation sector could reach 275 million ton per year by 2050 [62].

The largest problem with hydrogen as a fuel is the transport and storage of the volatile and non-dense fuel. On-board hydrogen production via steam methane reforming has been proposed as a solution [9]. An on-board reformer would provide a compact and efficient hydrogen source relative to hydrogen storage or a separate reactor and membrane separator [7]. A coupled SMR and fuel cell would work well together: fuel cells require the near-pure hydrogen that can be achieved through Pd-alloy membrane separation [8]. Small scale membrane reactors have even been proposed as a means of reducing fuel cost [53]. One study modeled a steam methane reformer with CO<sub>2</sub> capture, potentially producing hydrogen as low as \$30 per GJ [62]. For reference, a consumer price of \$2.50 per gallon of gasoline comes out to \$20.7 per GJ. Stated another way, assuming hydrogen has the same combustion efficiency, the consumer cost of hydrogen would be roughly equivalent to a gasoline price of \$3.63 gal. This competitive price is intriguing. However,

the system producing hydrogen achieved an overall efficiency below 40%, did not fully capture CO<sub>2</sub> emissions, and added significantly complexity. One experimental on-board SMR system for hydrogen production achieved 2.65 L volume, 129 kW hydrogen energy production, but again a low efficiency at 44% [37]. In the near future, it is likely that the added complexity in capital cost and maintenance will outweigh the potential benefits of coupled on-board SMR and fuel cells.

New technology, especially that proposed in academia, often fails to be implemented due to lack of economic benefit. For a new application of steam methane reforming to be feasible, it must not only break-even but far out-compete current technology. While there are many factors that go into this, high thermodynamic efficiency and modern emissions control are two important considerations. With that in mind, consider industrial steam generation, an industry that has persisted for several centuries. Steam generation is fundamentally simple: a fuel is burned to produce hot exhaust, and that exhaust is used to heat and boil water. Of course efficiency has improved greatly since the need for steam began, but overall system efficiency has plateaued in the last 20-30 years around 86% [66–69]. With steam being such a widely used commodity, fuel prices increasing, and a recent push to quickly regulate combustion emissions, it is a logical time to propose an alternative steam generation technology.

Steam methane reforming applied to a steam generation application is a perfect fit. SMR requires significant amounts of high temperature (roughly 400 – 600 °C) heat to preheat reactants and replace the enthalpy of the reforming reaction. This results in still relatively high temperature heat that is often exhausted in hydrogen production applications, wasting energy and lowering system efficiency. In low-pressure steam applications (roughly 15 bar pressure), the saturation temperature of water is less than 200 °C, meaning that the otherwise waste heat can be easily used to preheat and boil water. Remaining waste heat can be recovered in low temperature preheating

of reactants. High purity permeated hydrogen can be burned with no CO<sub>2</sub> emissions to provide excess heat. The heat from hydrogen combustion can be split towards multiple sinks, providing heat for steam generation as well as for the reforming reaction [53]. Additionally, the SMR process usually produces excess steam due to the combustion of hydrogen [63]. Near-perfect methane conversion rates of 98% [64] and permeated hydrogen purity above 99.9% [35] can be supplemented by recycling of unconverted fuel to further raise system efficiency and reduce overall fuel consumption compared to a traditional boiler used for steam generation.

The next section will survey literature to identify competitors in the steam generation industry. This thesis will focus on low-pressure, natural gas fired steam boilers. Specifically, competitive technologies will be compared based on overall efficiency, lifetime cost, carbon dioxide emissions, and system complexity.

### **2.3. Competitive Steam Generation Technologies**

Steam methane reforming applied to steam generation is an excellent fit from a thermodynamic perspective. Arguably the more important question is whether it can compete economically with existing technology for steam generation. This section will summarize competing technologies in the steam generation industry and justify a choice for the most appropriate system to compare to SMR.

There are countless methods of generating steam. The only truly essential component is a high temperature source that can transfer heat to water. In order to narrow the window of investigation into alternative technology, several constraints are imposed. First, the system must generate low-pressure steam, where low pressure steam typically refers to saturated steam between 10 and 20 bar absolute [40]. Another constraint is that the system must use natural gas as its primary fuel. As explained in the Introduction, natural gas is inexpensive, has robust infrastructure,

and is already heavily used. Natural gas is the most common energy source for boilers, which are the most common equipment for producing steam [40]. Comparing systems with the same fuel also allows for a more leveled comparison. Finally, the system size must be appropriate. Table 2-3 shows the current boiler inventory in the United States.

The most common size of boiler has a fuel input of between 1 and 10 MMBtu hr<sup>-1</sup>. Therefore, the scale of any suggested competitive technologies must be within or close to this range. The last constraint is that the primary export of the system should be steam. There are many ways to utilize waste heat that are out of the scope of this paper. For example, some combined heat and power (CHP) applications use engines, small turbines, or fuel cells that produce power from the waste heat [40]. In order to limit the number of possible alternative technologies to a manageable number, no systems that export fuel, work, or electricity will be considered.

**Table 2-3:** Boiler Inventory in the United States [40].

<b>Number of Units</b>			
<b>Unit Capacity</b>	<b>Manufacturing Boilers</b>	<b>Commercial Boilers</b>	<b>Total</b>
<10 MMBtu/hr	23,495	93,650	117,145
10-50 MMBtu/hr	12,380	21,850	34,230
50-100 MMBtu/hr	3,570	3,040	6,610
100-250 MMBtu/hr	2,210	1,120	3,330
>250 MMBtu/hr	1,360	130	1,490
<b>Total</b>	<b>43,015</b>	<b>119,790</b>	<b>162,805</b>
<b>Total Units &gt;10 MMBtu/hr</b>	<b>19,520</b>	<b>26,140</b>	<b>45,660</b>

<b>Fuel Input Capacity (MMBtu/hr)</b>			
<b>Unit Capacity</b>	<b>Manufacturing Boilers</b>	<b>Commercial Boilers</b>	<b>Total</b>
<10 MMBtu/hr	102,306	301,202	403,508
10-50 MMBtu/hr	277,810	463,685	741,495
50-100 MMBtu/hr	243,128	208,980	452,108
100-250 MMBtu/hr	327,327	140,110	467,437
>250 MMBtu/hr	616,209	33,639	649,848
<b>Total</b>	<b>1,566,780</b>	<b>1,147,617</b>	<b>2,714,397</b>
<b>Total Units &gt;10 MMBtu/hr</b>	<b>1,464,474</b>	<b>846,415</b>	<b>2,310,889</b>

Within these constraints, the only alternative to SMR is a natural gas fired boiler system. This is a logical outcome: boiler technology has been developed over several centuries and is simple and robust. At its most simple, a boiler burns a fuel to create hot exhaust, and heat is transferred from the exhaust to water to produce steam. Boiler efficiency is typically defined in the “Input-Output” method: efficiency is the ratio of the heat delivered to the water to the heat supplied to the system from fuel [66]. In a simple boiler, a significant amount of energy leaves the system in the still moderately hot exhaust. Modern, more efficient boilers use several methods to capture more heat and raise thermodynamic efficiency [66]. Optimized heat exchangers create increased surface area to yield more heat transfer from the exhaust. Precise air/fuel controls help control combustion of the fuel to achieve complete combustion. Heat recovery devices such as feed water heaters take advantage of low temperature exhaust to preheat incoming water, reducing the load on the main burner. With all the stops pulled, a high efficiency, natural gas fired steam boiler in the 1 – 10 MMBtu h<sup>-1</sup> size range has a peak efficiency of 83-86% [66–69].

Boilers have been in widespread use for hundreds of years; why replace them? Natural gas boilers are typically associated with high levels of emissions including NO<sub>x</sub>, SO<sub>2</sub>, particulate matter, volatile organic compounds, and CO<sub>2</sub> [70]. The efficiency of even state-of-the-art boiler systems has plateaued around 86%, which includes expensive heat recovery equipment. There are challenges associated with trace amounts of Sulphur in natural gas; acid condensates can form during combustion, fouling heat exchangers and contributing to acid rain.

This section has identified literature sufficient to conclude that a high efficiency natural gas fired boiler is an appropriate comparison for the proposed SMR steam generation system. In the Technoeconomic Comparison section, 3.4, a detailed analysis and comparison will be explained. It will establish a baseline for comparison using a fixed mass and state of steam, provide

data for a technoeconomic comparison, and quantitatively prove whether SMR is an economic competitor to other steam generation technologies.

The literature review presented here shows that there are significant gaps in current work on steam methane reforming. While there have been many detailed studies of specific facets of SMR such as enhancing hydrogen recovery or recycling gas to increase efficiency, no one study has unified all the major factors discussed here. In academia, steam methane reforming is confined to a narrow application window in plant scale hydrogen production, on-board scale hydrogen production, and electricity generation. In industry, that window is even narrower, with the only significant application of SMR being hydrogen production. There is an opportunity to fully utilize the net exports of SMR in the appropriate context of steam generation, but it has not been addressed in literature. Furthermore, for the applications that have been studied, there is insufficient analysis to prove that a given technology is can be implemented in a cost-effective way. This study aims to fill these gaps in the literature by developing an integrated steam methane reforming and steam generation system. A detailed thermodynamic and technoeconomic analysis determine whether the proposed technology has a favorable economic case over existing technology.

## **2.4. Research Needs for Steam Methane Reforming**

The literature review presented here shows that there are several key areas of research lacking exploration. Many studies have shown novel designs or aspects of membrane reformers, but only Martin et al. [18] and Manzolini et al. [34] unify all of the discussed aspects of steam methane reforming in a single study (Table 2-4). No papers were found that apply SMR to steam generation as the primary goal.

Steam methane reforming is a proven technology, but only in the limited application of hydrogen production. SMR naturally aligns well with the requirements and goals of steam

generation. This new application shows the potential for higher system efficiency and reduced cost, but a focused study is needed to prove those points from a thermodynamic and technoeconomic perspective.

**Table 2-4:** Summary of recent studies on membrane reforming technologies.

	<b>a</b>	<b>b</b>	<b>c</b>	<b>d</b>	<b>e</b>	<b>f</b>	<b>g</b>	<b>h</b>	<b>i</b>	<b>j</b>	<b>k</b>	<b>This Study</b>
Thermodynamic Modeling	✓	✓	✓	✓	✗	✓	✓	✓	✓	✓	✓	✓
Technoeconomic Modeling	✓	✗	✓	✓	✗	✗	✗	✗	✗	✗	✗	✓
Methane as fuel	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓
Heat Exchange within Reactor	✓	✗	✓	✓	✗	✓	✗	✓	✓	✗	✗	✓
Waste Heat Recovery	✓	✓	✓	✓	✗	✗	✗	✓	✗	✗	✗	✓
Sweep gas	✓	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓
Hydrogen Recovery	✓	✓	✓	✓	✓	✓	✓	✓	✗	✓	✓	✓
CO <sub>2</sub> Separation	✓	✓	✓	✓	✗	✗	✗	✗	✗	✗	✗	✓
Recycled Gas	✗	✗	✓	✓	✗	✗	✗	✗	✗	✓	✓	✓
Application to Steam Generation	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✗	✓

<b>a:</b> Spallina et al. [53]	<b>g:</b> Mokheim et al. [73]
<b>b:</b> Malerod-Fjeld et al. [33]	<b>h:</b> Sheintuch [74]
<b>c:</b> Martin et al. [18]	<b>i:</b> Vigneault and Grace [75]
<b>d:</b> Manzolini et al. [34]	<b>j:</b> Eveloy [76]
<b>e:</b> Gallucci et al. [71]	<b>k:</b> De Falco et al. [77]
<b>f:</b> Shigarov et al. [72]	

This literature review focused on membrane reactors and steam generation. It shows that there are several specific needs for further research in the field:

- Create and analyze a thermodynamic model for an integrated steam methane reformer steam generation system that combines all aspects of the technology described in Table 2-4.

- Explore the options for carbon capture in steam methane reforming, taking into account the high CO<sub>2</sub> concentration in the retentate and other effects of incorporating steam generation.
- Perform a technoeconomic analysis of steam methane reforming applied to steam generation to determine economic feasibility.
- Compare the proposed steam generation system to existing technology – i.e. a high efficiency natural gas boiler.
- Investigate the possibility of adding carbon capture onto existing boilers instead of introducing an entirely new system for steam generation.
- Put the results of carbon capture in context using data from existing power and energy conversion plants.
- Using the developed models, perform a sensitivity analysis to help guide future research on steam generation via steam methane reforming.

## **2.5. Specific Aims of this Study**

This literature review has identified several key gaps in current research on steam methane reforming. Many key aspects of steam methane reforming have been studied separately, but there is a lack of modeling and validation for a system that integrates all aspects. Additionally, most literature addresses theoretical improvements and understanding of the technology without offering a specific application. The goal of this study is to fill those gaps through execution of the following:

- Develop and refine a detailed thermodynamic model of an integrated steam methane reformer system, combining state-of-the-art technology in multiple aspects of the technology.

- Choose the best technology for CO<sub>2</sub> capture in the proposed steam generation system based on minimizing energy consumption and costs.
- Couple the thermodynamic model to a technoeconomic analysis at a relevant industrial scale to determine economic performance of the proposed system.
- Discuss the relative merits of the proposed system against a baseline for steam generation: industrial natural gas boilers that are currently in widespread use.
- Develop a model for a boiler system with integrated carbon capture as an alternative to the proposed steam generation system.
- Collect and discuss energy penalties and technologies associated with carbon capture in existing systems, including power plants and conventional steam methane reforming.
- Develop a sensitivity analysis to help discuss important factors that drive thermodynamic and economic performance.

## CHAPTER 3. Modeling Approach

The literature review showed that there are several key points missing from the current literature on steam methane reforming. Specifically, there are many more thermodynamic modeling studies than technoeconomic investigations. Furthermore, few studies combine all aspects of SMR found in Table 2-4: methane conversion, hydrogen recovery, heat exchange within the reactor, waste heat recovery, carbon dioxide sequestration, recycled gas, and an integrated membrane reactor. Also, the literature generally focuses on the technology itself, rather than practical methods of implementation, whereas this study has selected and analyzed a proposed application in steam generation.

The modeling effort in this study develops and compares models for three NG-fueled steam generation systems: a high efficiency boiler system (BS), the same boiler system with carbon capture (BSC), and the SMR-MR-SG. The models were developed using Engineering Equation Solver (EES) version 10.441-3D,50 allowing relevant equations to be solved simultaneously with embedded thermophysical properties. The thermodynamic models incorporate chemical reactions, thermodynamic states, energy balances, and heat exchanger design variables necessary to estimate system performance. For a direct, levelized comparison, the boiler and SMR-MR-SG systems were sized to produce (export) the same mass flow rate of steam at a set temperature and pressure of 200°C and 15 bar, respectively, corresponding to a typical low-pressure steam system [40]. The condensate return rate is the mass of liquid water that returns from steam export; a rule of thumb is 80% return for steam generation plants [78].

Table 3-1 shows the key assumptions and input parameters to the thermodynamic model.

**Table 3-1:** List of major assumptions and input variables in thermodynamic model.

<b>Description</b>	<b>Value</b>	<b>Units</b>
<i>Membrane Reactor</i>		
Methane conversion efficiency	65	%
Hydrogen capture efficiency	90	%
Permeated hydrogen purity	100	%
Reforming reaction temperature	400	°C
Membrane reactor pressure (retentate)	15	bar <sup>1</sup>
Membrane reactor pressure (permeate)	2	bar
Steam to carbon ratio of reaction steam	3	-
Steam to carbon ratio of sweep steam	1	-
<i>Boiler Systems</i>		
Boiler Efficiency	86	%
<i>Energy Balance</i>		
Closest approach temperature of heat exchangers	5	°C
Ambient temperature	15	°C
Ambient pressure	1	bar
Mole fraction of N <sub>2</sub> in air	0.79	-
Mole fraction of O <sub>2</sub> in air	0.21	-
<i>Steam Generation</i>		
Exported steam temperature	200	°C
Exported steam pressure	15	bar
Condensate return rate	80	%
<i>Other</i>		
CO <sub>2</sub> capture efficiency	90	%
Separated CO <sub>2</sub> purity	100	%
Compressed CO <sub>2</sub> pressure	75	bar

<sup>1</sup> All pressures are absolute (not gauge).

Several qualitative assumptions were also made in the thermodynamic model (Table 3-2).

**Table 3-2:** List of major thermodynamic modeling assumptions

<b>Component</b>	<b>Major Assumptions</b>
Membrane Reactor	No carbon monoxide in products (water-gas shift goes to completion) Instantaneous reactions Adiabatic to environment Isothermal and isobaric zones (i.e. feed, sweep, heating fluid) “Natural gas” is pure methane for chemical reactions
Boiler Systems	Complete combustion of NG
Heat Exchangers	Isobaric heat exchangers Adiabatic to environment Counter-flow arrangement Carbon steel, shell and tube type Cold fluid is in outer shell
Fluids	Real gas properties; ideal gas interactions Negligible pressure drop throughout system
Other	Complete, stoichiometric combustion of hydrogen Water condensers remove 100% of water Components and piping are adiabatic to environment Condensate from export steam returns at ambient conditions

Each stream in the systems was characterized by total molar flow rate in  $\text{kmol s}^{-1}$  and mole fraction of each of six species ( $\text{H}_2$ ,  $\text{CH}_4$ ,  $\text{H}_2\text{O}$ ,  $\text{CO}_2$ ,  $\text{N}_2$ ,  $\text{O}_2$ ). Total molar flow rate and mole fraction are defined by Equations (3.1) and (3.2), respectively:

$$\dot{n}_{\text{total}} = \dot{n}_{\text{H}_2} + \dot{n}_{\text{CH}_4} + \dot{n}_{\text{H}_2\text{O}} + \dot{n}_{\text{CH}_4} + \dot{n}_{\text{N}_2} + \dot{n}_{\text{O}_2} \quad (3.1)$$

$$y_i = \frac{\dot{n}_i}{\dot{n}_{\text{total}}} \quad (3.2)$$

The thermodynamic model used energy balances based on sensible and formation enthalpies. Real fluid thermophysical properties (as opposed to ideal gas properties) were used to increase model accuracy and to allow integration of two-phase scenarios (e.g., water boiling and  $\text{CO}_2$  liquifying). Real fluid properties were evaluated using a temperature and partial pressure, as opposed to just the temperature needed to evaluate ideal gas properties.

Six fluids were considered in the model:  $\text{CH}_4$ ,  $\text{H}_2$ ,  $\text{H}_2\text{O}$ ,  $\text{CO}_2$ ,  $\text{N}_2$ , and  $\text{O}_2$ . Due to chemical reactions in each of the analyzed systems, it was useful to develop a standardized measure of

energy for each stream. Flow enthalpy,  $\dot{H}$ , was calculated for each thermodynamic state as a measure of relative energy. The flow enthalpy of each fluid (e.g., H<sub>2</sub>) was calculated as the sum of sensible and formation enthalpy, multiplied by flow rate (Equation (3.3)):

$$\dot{H}_{\text{fluid}} = \dot{n}_{\text{total}} \cdot y_{\text{fluid}} \cdot (h_{\text{sens,fluid}} + h_{\text{f,fluid}}^o) \quad (3.3)$$

where  $\dot{n}_{\text{total}}$  is the total molar flow rate of a stream of fluids including all species and  $y_{\text{fluid}}$  is the mole fraction of the particular fluid. The total flow enthalpy of a mixture (i.e., a fluid stream) was calculated as the sum of each fluid's flow enthalpy using Equation (3.4):

$$\dot{H}_{\text{total}} = \dot{H}_{\text{H}_2} + \dot{H}_{\text{CH}_4} + \dot{H}_{\text{H}_2\text{O}} + \dot{H}_{\text{CO}_2} + \dot{H}_{\text{N}_2} + \dot{H}_{\text{O}_2} \quad (3.4)$$

Since several different fluids were involved, particularly in the SMR-MR-SG system, it was important that the reference state be at the same temperature and pressure for all fluids. The purpose of aligning reference states was to ensure that the energy balances using flow enthalpy differences were accurate when changes in species occurred from one state to the next. The built-in thermophysical properties in Engineering Equation Solver (EES) have several different reference states, as shown in Table 3-3.

**Table 3-3:** Enthalpy reference states for fluids used in Engineering Equation Solver.

<b>Fluid</b>	<b>Fluid Type</b>	<b>Reference Sensible Enthalpy [kJ kg<sup>-1</sup>]</b>	<b>Reference Temperature [°C]</b>	<b>Reference Pressure [bar]</b>
Hydrogen	Real	3,932	25	1.01325
Methane	Real	-0.9889	25	1.013
Water	Real	0	0	X = 0
Carbon Dioxide	Real	0	25	1.013
Nitrogen	Real	0	-273.15	1.01325
Oxygen	Real	0	25	1.01325

An adjustment was made in the calculation of enthalpy for each fluid. A new reference state of 15°C and 1 bar was chosen for all fluids. Effectively, the adjustment made it such that the sensible enthalpy of any fluid at the chosen reference state of 15°C and 1 bar would be zero. The

adjustment also standardized the enthalpy of formation reference of each fluid to the new reference state. First, the pressure and temperature were adjusted to match the new reference state. The temperature and pressure adjustments were calculated by Equations (3.5) and (3.6):

$$T_{\text{adj}} = T_{\text{ref,new}} - T_{\text{ref,fluid}} \quad (3.5)$$

$$P_{\text{adj}} = P_{\text{ref,new}} - P_{\text{ref,fluid}} \quad (3.6)$$

where  $T_{\text{ref,new}}$  and  $P_{\text{ref,new}}$  were equal to the reference state: 15°C and 1 bar, respectively. For example, “Nitrogen” in Table 3-3 had  $T_{\text{ref,fluid}}$  equal to -273.15°C and  $P_{\text{ref,fluid}}$  equal to 1.01325 bar. Then, each of the fluids required an additional adjustment to set the sensible enthalpy to zero at the new reference state. The sensible enthalpy of each fluid was ultimately evaluated as in Equation (3.7):

$$h_{\text{sens,fluid}} = h_{\text{fluid}}(T = T_{\text{fluid}} + T_{\text{adj}}, P = P_{\text{fluid}} + P_{\text{adj}}) + h_{\text{adj}} \quad (3.7)$$

Similar to the lower heating value (LHV) method of Spallina et al. [53], flow enthalpy of each state was used as the primary metric for calculating changes in energy between states, even with a change in chemical composition. A brief example is included to explain the concept of flow enthalpy in energy balances. Consider H<sub>2</sub> combustion in a boiler: H<sub>2</sub> is combusted with air (N<sub>2</sub> and O<sub>2</sub>) to produce heat, and the heat is transferred to liquid water to boil it into steam. For simplicity, assume a 100% efficient boiler, such that all extracted heat from combustion enters the water. The flow enthalpy of the combustion reactants is given by the sum of hydrogen and air as in Equation (3.8):

$$\dot{H}_{\text{reactants}} = \dot{H}_{\text{H}_2} + \dot{H}_{\text{N}_2} + \dot{H}_{\text{O}_2} \quad (3.8)$$

where the flow enthalpy of each reactant H<sub>2</sub>, N<sub>2</sub>, and O<sub>2</sub> are evaluated at their particular temperature, partial pressure, and mole fraction according to Equation (3.3). Assuming complete stoichiometric combustion, the flow enthalpy of the products is given by Equation (3.9):

$$\dot{H}_{\text{products}} = \dot{H}_{\text{H}_2\text{O}} + \dot{H}_{\text{N}_2} \quad (3.9)$$

The net energy produced in the combustion is simply the difference in flow enthalpy, given by Equation (3.10):

$$\dot{Q}_{\text{boiler}} = \dot{H}_{\text{products}} - \dot{H}_{\text{reactants}} \quad (3.10)$$

Referring to the definition of flow enthalpy in Equation (3.3), the calculated  $\dot{Q}_{\text{boiler}}$  includes the heat of combustion due to the chemical reaction (enthalpy of formation) as well as energy involved in change in temperature and pressure (sensible enthalpy). Assuming 100% efficiency, all of the heat from combustion is transferred to the water as in Equation (3.11):

$$\dot{Q}_{\text{boiler}} = \dot{Q}_{\text{water}} \quad (3.11)$$

On the water side of the boiler, the flow enthalpy in and out of the boiler are calculated in the same way because there is no change in species. Flow enthalpy is calculated using Equations (3.12) and (3.13):

$$\dot{H}_{\text{water,in}} = \dot{H}_{\text{H}_2\text{O}} \quad (3.12)$$

$$\dot{H}_{\text{water,out}} = \dot{H}_{\text{H}_2\text{O}} \quad (3.13)$$

Then, the heat entering the water is given by the difference in flow enthalpy, given by Equation (3.14):

$$\dot{Q}_{\text{water}} = \dot{H}_{\text{water,out}} - \dot{H}_{\text{water,in}} \quad (3.14)$$

In the case of Equation (3.14), the enthalpy of formation in each term cancels because flow rate and species have remained the same. The difference is that  $\dot{H}_{\text{H}_2\text{O}}$  in Equation (3.12) is evaluated at liquid water state (e.g., 15°C and 15 bar), but  $\dot{H}_{\text{H}_2\text{O}}$  in Equation (3.13) is steam (e.g., 200°C and 15 bar). Thus, Equation (3.14) captures only the change in sensible enthalpy because there is no change in enthalpy of formation.

Capital and O&M costs were translated to 2019 dollars using the United States Department of Labor’s historical inflation calculator [79]. All prices were based on United States dollars. International currencies were converted using conversion rates as of January 2019, shown in Table 3-4.

**Table 3-4:** International currency exchange rates in January 2019.

Currency	Symbol	Value relative to USD
US Dollar	\$	1.00
Euro	€	1.13
Sterling Pound	£	1.29

The assumptions are discussed in their appropriate sections below. First, the thermodynamic and technoeconomic analysis of the two boiler systems is discussed. Then, the same for the SMR-MR-SG system follows. The justification and details of CO<sub>2</sub> capture methods are presented in the third subsection. The final subsection addresses the method of technoeconomic comparison of the three systems using a discounted cash flow model.

### 3.1. Boiler Systems

The flow rate of steam was calculated from a boiler with a 3.5 MMBtu hr<sup>-1</sup> (1,026 kW) fuel input based on LHV, which is the most common industrial boiler size over the last 27 years [40]. A high efficiency, natural gas fired steam boiler of this size has a peak efficiency of 86% [66–69]. The definition of boiler efficiency can change between industry, academia, and the consumer world. The different definitions vary in whether they include heat loss from the boiler, throughout piping systems, and heat recovery equipment. In this paper, boiler efficiency was defined in a system-wide thermodynamic sense, as the ratio of heat going into steam to fuel heat input. Boiler efficiency is given by Equation (3.15) [80]:

$$\eta_{\text{boiler}} = \frac{\dot{m}_{\text{steam}} \cdot (h_{\text{steam,export}} - h_{\text{water,supply}})}{\dot{E}_{\text{fuel}}} \quad (3.15)$$

The subscripts *export* and *supply* are used to avoid confusion, especially in the SMR-MR-SG system. Export refers to the set mass flow rate of steam at 200°C and 15 bar absolute. Supply refers to the ambient-temperature and -pressure, liquid water supply to the system. The mass flow rates of the water supply are not equal between the three systems because the SMR-MR-SG system consumes water in reforming and generates water in hydrogen combustion.

Assuming a water supply at 15°C and 1 bar absolute, and an overall boiler system efficiency of 86%, a simple energy balance gives the water mass flow rate for the boiler system (Equation (3.16)):

$$\dot{E}_{\text{fuel}} \cdot \eta_{\text{boiler}} = \dot{m}_{\text{steam}} (h_{\text{steam,export}} - h_{\text{water,supply}}) \quad (3.16)$$

The mass flow rate of the export steam was used to set the scale of the three thermodynamic models.

High efficiency boilers employ several methods to increase efficiency, including feed water pre-heating, boiler insulation, and exhaust economizing, all of which contribute to capital and operating and maintenance (O&M) costs [69]. The peak 86% efficiency includes implementation of all these components. Additional heat recuperation could increase efficiency beyond 86% at the expense of increasing costs and reduced lifetime due to corrosion and fouling issues in exhaust condensation. In the Results and Discussion section, this study shows that the additional cost has a minimal return when increasing efficiency beyond 86%.

A list of assumed values for the techno-economic analysis is presented in Table 3-5.

**Table 3-5:** List of major input variables in technoeconomic model.

Parameter	Value	Units
<i>Commodity Pricing</i>		
Natural gas purchase price	4.1	\$ 1000 scf <sup>-1</sup>
Electricity purchase price	0.0688	\$ kWh <sup>-1</sup>
CO <sub>2</sub> sale price	20	\$ ton <sup>-1</sup>
Water purchase price	0.282	\$ m <sup>-3</sup>
<i>Cash Flow Analysis</i>		
Discount rate	12	%
Lifespan	20	yr
Carbon tax	50.5	\$ ton <sub>CO<sub>2</sub></sub> <sup>-1</sup>
Scale (boiler fuel input)	3.5	MMBtu h <sup>-1</sup>
<i>Boiler Systems</i>		
System capital cost	35,000	\$ per MMBtu h <sup>-1</sup>
Boiler efficiency	86	%
System O&M Cost	0.95	\$ MMBtu <sup>-1</sup>
MEA CapEx	1.178	M\$ per kg <sub>CO<sub>2</sub></sub> s <sup>-1</sup>
MEA O&M Cost	0.141	\$ kmol <sub>CO<sub>2</sub></sub> <sup>-1</sup>
<i>SMR Steam Generation System</i>		
Membrane thickness	2.8	μm
Membrane permeance	6.48x10 <sup>-3</sup>	mol m <sup>-2</sup> s <sup>-1</sup> Pa <sup>-0.5</sup>
Membrane cost (no reactor)	1,076	\$ m <sup>-2</sup>
System O&M Cost	5	% of total CapEx
CSU CapEx	0.440	M\$ per kg <sub>CO<sub>2</sub></sub> s <sup>-1</sup>
CSU O&M Cost	4	% of CSU CapEx

The capital cost for the high efficiency natural gas boiler system was calculated using \$35,000 per MMBtu h<sup>-1</sup> (\$119.42 per kW) of fuel input [70] by Equation (3.17):

$$CapEx_{BS} = \frac{\$35,000}{MMBtu h^{-1}} \cdot 3.5 MMBtu h^{-1} \quad (3.17)$$

Note that the selected boiler scale of 3.5 MMBtu h<sup>-1</sup> for this study and the capital cost of \$35,000 per MMBtu h<sup>-1</sup> are neat multiples by coincidence; one was not calculated using the other. The O&M cost (excluding commodity consumption) of the baseline system was calculated using a cost of \$0.95 per MMBtu ( \$0.003242 per kWh) of fuel input [70] using Equation (3.18):

$$OpEx_{BS} = \left( \frac{\$0.95}{MMBtu} \right) (3.5 MMBtu h^{-1}) (F_{load}) (8760 h yr^{-1}) \quad (3.18)$$

where  $F_{load}$  is the load factor, or the percentage of time the plant is in operation, as opposed to offline for maintenance, defined by Equation (3.19) [69]:

$$F_{load} = \frac{\text{Operational hours per year}}{\text{Total hours per year}} \quad (3.19)$$

As validation of the calculated values, other sources suggested an alternative method of cost estimation. For an industrial steam generation system the O&M, capital cost, and fuel cost should equal 1%, 3%, and 96% of the lifetime cost, respectively [69,81,82]. Using the cost per MMBtu methods, the O&M, capital cost, and fuel cost came out to 0.7%, 3.2%, and 61%, respectively. The reason for the disparity in fuel cost percentage is that this study included the cost of carbon tax and water supply in addition to fuel.

The BSC is the same as the BS but with the addition of CCC components: a condenser, amine absorber, and compressor for dehydration of exhaust, CO<sub>2</sub> separation, and CO<sub>2</sub> compression, respectively. The costs of the BSC were calculated as the sum of the BS costs plus the additional costs of CCC. The capital cost of the amine absorber was calculated using Equation (3.20) [83]:

$$CapEx_{MEA} = \left( 1.178 \frac{\$ \cdot kg_{CO_2}}{s} \right) (\dot{m}_{CO_2, BSC}) \quad (3.20)$$

Several authors make use of a scaling factor to predict capital cost at a different scale [22,84,85]. For example, if the price of a 100 kW compressor is known but a cost estimate is required for a 500 kW compressor, the scaling factor can be used to estimate the price of the unknown component. The scaling equation is given by Equation (3.21):

$$\text{Cost}_{\text{new}} = \text{Cost}_{\text{known}} \left( \frac{\text{Scale}_{\text{new}}}{\text{Scale}_{\text{known}}} \right)^R \quad (3.21)$$

where the exponent  $R$  varies depending on the component. Scale indicates the relevant size of the component (e.g., 3 kW for a compressor). Table 3-6 contains values that require a scaling method.

**Table 3-6:** Parameters for estimating capital costs using the scaling method.

Component	Base Cost [k\$]	Base Scale	Scaling Exponent ( $R$ )
Membrane reactor cost (no membrane)	14.1	4.79 kg <sub>H<sub>2</sub></sub> h <sup>-1</sup>	0.85 <sup>a</sup>
Heat Exchanger Costs	462	1 m <sup>2</sup>	0.5 <sup>b</sup>
Boiler	44.0	2 MW	0.67 <sup>a</sup>
Water Pump	1.2	90 L h <sup>-1</sup>	0.7 <sup>c</sup>
Water Condensers	0.7988	1 kW	0.38 <sup>d</sup>
CO <sub>2</sub> Cryogenic Separator	475	0.6 ton <sub>CO<sub>2</sub></sub> h <sup>-1</sup>	0.7 <sup>a</sup>
CO <sub>2</sub> Compressor	3,000	6 MW	0.7 <sup>c</sup>

<sup>a</sup> *Sjardin et al.* [22]

<sup>b</sup> *Brown* [86]

<sup>c</sup> *Remer and Chai* [87]

<sup>d</sup> *Brundett* [88]

Calculating the capital costs of the remaining BSC components, the compressor capital cost was calculated using Equation (3.22) [22]:

$$\text{CapEx}_{\text{comp}} = \$3,000,000 \cdot \left( \frac{\dot{W}_{\text{comp}}}{6 \text{ MW}} \right)^{0.7} \quad (3.22)$$

The cost of water condensers was estimated by adjusting for both international currency and inflation because it was reported in 1987 Sterling Pounds. Using 1 £<sub>1987</sub> = 1.68 \$<sub>1987</sub> [89] and adjusting for inflation (1 \$<sub>1987</sub> = 2.23 \$<sub>2018</sub>) [79] gives an overall conversion of 1 £<sub>1987</sub> = 3.75 \$<sub>2018</sub>.


The capital cost was of the condenser then calculated by Equation (3.100) [88]:

$$\text{CapEx}_{\text{cond,BSC}} = 3.75 \frac{\$_{2018}}{\pounds_{1987}} \cdot 213 \pounds_{1987} \cdot \left( \dot{Q}_{\text{cond,BSC}} \right)^{0.38} \quad (3.23)$$

where  $\dot{Q}_{\text{cond,BSC}}$  is the heat duty of the condenser required to condense all water from the exhaust prior to CO<sub>2</sub> capture.

### 3.2. SMR-MR-SG System

The SMR-MR-SG system is shown in Figure 3-1. In this Chapter, a numbered subscript (e.g., T<sub>4</sub>) or a number in text (e.g., #4) refers to the state points of the system in Figure 3-1.




**Figure 3-1:** Process flow diagram for coupled SMR in a MR and steam generation system (SMR-MR-SG).

The system uses NG as a fuel (#1) to produce steam (#9). The NG is combined with steam (#10) and superheated to the reforming temperature of 400°C to form the MR feed (#14). The MR converts the feed to CO<sub>2</sub> and H<sub>2</sub> while separating H<sub>2</sub> through the membrane into the permeate stream (#22). The H<sub>2</sub> is combusted in a boiler to provide heat for SG (#8) and the reforming


reaction (#24). Waste heat is captured in recuperative heat exchangers (HE 2 through HE 5). Water is condensed from the boiler exhaust (#28) and retentate (#17) for recycling. A cryogenic separation unit (CSU) separates CO<sub>2</sub> from the retentate stream (#18). The unreacted CH<sub>4</sub>, unpermeated H<sub>2</sub>, and un-captured CO<sub>2</sub> are recycled back into the feed (#21). It is important to note that the H<sub>2</sub>-fueled boiler in the SMR-MR-SG is a simple boiler without integrated heat recuperation and economizing, whereas the *boiler systems* of the BS and BSC have additional components that increase efficiency but add cost.

### 3.2.1. Model Overview


Steam methane reforming reacts steam and methane over a catalyst to form hydrogen and carbon dioxide. In a membrane reactor, the hydrogen is separated from the chemical products in real-time. The chemical reaction occurs in two steps: steam methane reforming, given by Equation (3.24) [18]:



and water-gas shift, given by Equation (3.25) [18]:



These two reactions can be combined into an overall reaction, given by Equation (3.26) [18,19]:



The heat of reaction given in Equation (3.3) is the sum of the two reaction steps. It's important to note that this is a highly endothermic reaction, the implication being that a physical reactor must have a significant and constant supply of heat to operate correctly.

The goal of the thermodynamic analysis was to provide an accurate model for a fluid process coupling steam methane reforming and steam generation. Specifically, the process flow diagram of Figure 3-1 was developed and then modeled in detail. The desired outputs were the

fully defined state points, including flow rates of each gas, mole fractions, temperature, pressure, enthalpy, and phase if applicable. On a system level, the flow and states of each input and output was calculated, as well as the heat duty of each heat exchanger.

The secondary goal of the thermodynamic model was to be able to couple it directly to a technoeconomic model. The technoeconomic model models the SMR-MR-SG and compares it to the BS and BSC to determine its economically feasibility. The technoeconomic comparison will be discussed in the next major section, 3.4. A sensitivity analysis is detailed in section 4.3 to show the effects of input parameters, thermodynamic and economic, on technoeconomic outputs.


The thermodynamic model was purposefully kept to a system level as much as possible. Many models and experiments have varied pressure, temperature, and steam to carbon ratio in order to optimize methane conversion and hydrogen recovery [7]. That was not the focus of this thesis, so parameters were assumed based on recent literature and the model proceeded. On the other hand, topics such as heat balances within the membrane reactor and heat exchangers in the system were lacking in literature [15]. Those aspects that were not well developed in the literature were given more attention.

In the ideal SMR process, the reactions given in Equations (3.24) through (3.26) go to completion, i.e., the only remaining species are  $H_2$  and  $CO_2$ . In reality, only a percentage of the  $CH_4$  is reacted, the water-gas shift reaction does not completely consume all  $CO$ , and not all  $H_2$  is separated. The net effect is that the products contain  $CH_4$ ,  $H_2O$ ,  $CO$ ,  $CO_2$ , and  $H_2$ .

The primary tool used for modeling was the program Engineering Equation Solver (EES). There are two large advantages to EES in the context of thermodynamic modeling. First, it has integrated thermophysical properties. Instead of spending time finding and interpolating from tables, built-in functions were used to evaluate all properties. Unlike most other programming

languages, EES has built-in iteration algorithms that allow equations to be solved simultaneously. This was enormously helpful in modeling flows of molecules, heat, and mass that are all interlinked, often in a non-linear way. An in-depth representative calculation verifying the accuracy of EES is presented in Appendix A.


The thermodynamic model was developed to support the key constraints of steam generation and steam methane reforming. A boiler was necessary to create high temperature fluid capable of both generating steam and supplying heat to the reforming reaction. A system was needed to separate CO<sub>2</sub> and water from the retentate stream. Waste heat recovery was not strictly necessary, but essential to producing a high overall efficiency. Similarly, recycling of gas (CH<sub>4</sub>, H<sub>2</sub>, and CO<sub>2</sub>) and recycling of water was not necessary, but cleaned emission composition while increasing overall efficiency. Note that more water is produced than consumed in the reforming reaction. Combined with water recycling, the mass flow of export steam is greater than the water supply mass flow. Figure 3-2 shows the essentials of the system together in a conceptual process flow diagram.



**Figure 3-2:** Simplified process flow diagram of a coupled SMR and steam generation system.

The next step was to add enough complexity to the system to accurately model fluid flows, chemical reactions, and heat exchangers. The process required many iterations. In general, the

challenge was to recover sufficient heat to supply the reforming reaction while respecting the limitations of real heat exchangers. In counter-flow heat exchangers, the hot fluid outlet temperature cannot be colder than the cold fluid inlet. Similarly, the cold fluid outlet temperature cannot be warmer than the hot fluid inlet temperature. Counter-flow heat exchangers were used instead of parallel flow in all modeling because they allow temperatures to “cross”: the hot fluid outlet can be colder than the cold fluid outlet [90]. The closest approach temperature (CAT) was introduced at this point. All these concepts are depicted in Figure 3-3.



**Figure 3-3:** Closest approach temperature (CAT) of fluids in a counter-flow heat exchanger.

The introduction of the closest approach temperature complicated the process flow diagram further. Part of the difficulty was that there was no single goal; it could be to minimize waste heat, minimize natural gas input required, or maximize the overall system efficiency. Several iterations on a detailed process flow diagram yielded Figure 3-1, which is a compromise between waste heat recovery, natural gas input, and system efficiency. This system supplies just enough heat for generating the required amount of export steam, preheating reactants, and supplying the heat of

reaction to the membrane reactor. Steam was chosen for sweep gas composition; it is convenient due to the large amount of steam in the system already, and literature shows a marked improvement in hydrogen permeation using steam instead of other gases such as nitrogen [71].

The system uses NG as a fuel (#1) to produce steam (#9). The NG is combined with steam (#10) and superheated to the reforming temperature of 400°C to form the MR feed (#14). The MR converts the feed to CO<sub>2</sub> and H<sub>2</sub> while separating H<sub>2</sub> through the membrane into the permeate stream (#22). The H<sub>2</sub> is combusted in a boiler to provide heat for SG (#8) and the reforming reaction (#24). Waste heat is captured in recuperative heat exchangers (e.g., HE 2). Water is condensed from the boiler exhaust (#28) and retentate (#17) for recycling. A cryogenic separation unit separates CO<sub>2</sub> from the retentate stream (#18). The unreacted CH<sub>4</sub>, un-permeated H<sub>2</sub>, and un-captured CO<sub>2</sub> are recycled back into the feed (#21). It's important to note that the boiler in the SMR-MR-SG is a simple boiler, whereas the *boiler systems* in the BS and BSC have complicated economizing and heat recuperation components.

In addition to producing process steam, the SMR-MR-SG system creates a concentrated CO<sub>2</sub> stream on the retentate side of the reactor (#16). Because some of the incoming methane is not reacted and some of the generated hydrogen remains in the retentate, the CO<sub>2</sub> must go through a purification process. Recent studies argue that a cryogenic separation unit (CSU) is the most energy- and cost-effective way to separate CO<sub>2</sub> from a high concentration CO<sub>2</sub> stream [22,91]. The CSU will be discussed in more detail in the CO<sub>2</sub> capture section.

The inputs and outputs of the system in Figure 3-1 are shown in bolded boxes. Inputs include natural gas as the fuel source (#1), liquid water to be heated into steam (#4), and air for hydrogen combustion in the boiler (#23). Outputs of the system are steam for export (#9), compressed CO<sub>2</sub> (abbreviated cCO<sub>2</sub>) for sale (#20), and ambient temperature nitrogen as exhaust

(#30). The steam export is the same temperature, pressure, and flow rate as the high efficiency boiler system being used as a benchmark for comparison. Where the steam goes or what it is used for is not the focus of this thesis; the focus is how to generate the export steam in a more efficient, clean, and cost-effective way than the current technology. Stream (#33) is the condensate return, or the cold water left over from some steam consuming application.

Continuing through the system, the membrane reactor is shown on the far right, inside the large dashed box. The unit is shown as two separate components (reactor and separator) for modeling purposes, but is intended to be one physical unit. Stream (#24) to (#25) is high temperature exhaust from the boiler; it provides heat for the reforming reaction. Stream (#14) is the feed, consisting primarily of  $\text{CH}_4$  and  $\text{H}_2\text{O}$ , but also with lesser amounts of  $\text{H}_2$  and  $\text{CO}_2$  that have been recycled. Stream (#12) is the sweep gas, in this case pure steam, superheated to the reforming temperature. Stream (#15) is an intermediate within the reactor, representing the feed after the reforming reaction but before hydrogen permeating through the membrane. In reality, the reforming reaction happens simultaneously with the hydrogen removal; again, this was a technique for modeling. Stream (#22) is the low pressure permeate, which includes all the sweep steam from Stream (#12) plus the permeated hydrogen. Stream (#16) is the retentate: everything left over on the high-pressure side of the membrane.

Following Stream (#22), the hydrogen is combusted stoichiometrically with air in the boiler. The boiler is purposefully inefficient in the sense that only about 50% of the heat from combustion goes into the steam, with the rest leaving in the exhaust. The reason for this is that a significant amount of energy is required in the exhaust to heat the membrane reactor and preheat the reactants. Heat exchanger 1 (HE 1) supplies the heat of reaction for the steam methane reforming reaction. HE 2 superheats sweep steam from the export steam temperature to the

reforming temperature. HE 3 superheats the feed entering the membrane reactor. HE 4 preheats the supply natural gas and recycled gases. HE 5 captures the low temperature energy from the exhaust by preheating water before it enters the steam boiler. HE 7 condenses and recycles water out of the exhaust, leaving only nitrogen to be exhausted to the environment.

Following the retentate, Stream (#16), its high temperature energy is recovered in HE 5, also preheating water for the boiler. HE 6 condenses and recycles water out of Stream (#17), leaving Stream (#18) dry. This is an important step that allows the cryogenic separator to achieve low temperatures without freezing water. Most of the CO<sub>2</sub> in stream (#18) is liquefied and separated into Stream (#19), with the remaining gases (CH<sub>4</sub>, H<sub>2</sub>, and CO<sub>2</sub>) being recycled into the fuel stream via Stream (#21).

Returning to the beginning, Stream (#1) is a compressed natural gas supply that provides energy to the system. Stream (#2) is the combination of (#1) and (#21), now including recycled CH<sub>4</sub>, H<sub>2</sub>, and CO<sub>2</sub>. Stream (#10) is the steam required for the reforming reaction. The flow rate of Stream (#10) is defined by the steam to carbon ratio (SC) which typically has a value between 2.5 and 3.5 in literature. The following section will go into detail of the thermodynamic analysis of the SMR-MR-SG process flow diagram shown in Figure 3-1.

### **3.2.2. Assumptions and Input Parameters**

The thermodynamic model was based on a set of important inputs and assumptions that were supplied by literature. All assumptions and calculations are guided by results in the published literature, including experimental results generated by the author and collaborators on the project. These results include: heat exchanger area, membrane surface area, methane conversion, hydrogen permeation, capital costs, NG and CO<sub>2</sub> market pricing, and carbon taxes [14,23,29,43,92]. Some assumptions, such as the methane conversion, were made as temporary assumptions pending

experimental validation in a future study by this author. The quantifiable assumed and input variable are shown in Table 3-1.

In this analysis, it was assumed that the natural gas supplied to the system is composed of pure methane with no impurities. Although this assumption introduced some error, it greatly simplifies the chemistry. Literature shows that true natural gas reforming can achieve similar fuel conversion as with pure methane, with conversion of higher hydrocarbons above 85% [12]. Furthermore, palladium-based membranes are not poisoned by CO<sub>2</sub> or higher hydrocarbons, which shows that natural gas of varying composition is a possible option, even if experimental work is performed with pure methane [48]. Future studies will incorporate relevant impurities.

The key assumptions for the MR include reactor temperature, methane conversion, hydrogen permeability, operating pressures, and steam-carbon feed and sweep ratios. Prior studies have shown that a reactor temperature of 400°C provides sufficient reaction stability [53]. Operating at this low temperature also provides a key advantage over traditional SMR by enabling sufficient heat recuperation in the reactor from the boiler exhaust (#24). The use of low-temperature MR technology also has a significantly longer life expectancy than conventional SMR.

Methane conversion varies widely throughout literature. It is a strong function of reforming temperature and pressure, although the relationship is not well defined. For example, experimental studies with reforming temperatures between 450 and 500°C and pressures from 1 to 20 bar showed an average methane conversion of 75.1% with a standard deviation of 18.5% [14]. This study used a conservative value of 65%, which is close to various estimates [12] and highlights the efficacy of unconverted methane recycling.

To yield 100% H<sub>2</sub> permeation, an unreasonably large amount of membrane surface area would be needed. Thus, it is assumed that only 90% of the generated H<sub>2</sub> permeates through the membrane (i.e., hydrogen capture equals 90%), and the un-permeated H<sub>2</sub> gas is recycled through the retentate. Hydrogen capture is defined as the molar ratio of permeated to available hydrogen (i.e., the percentage of hydrogen that goes through the membrane), given by Equation (3.27):

$$\eta_{\text{H}_2, \text{capt}} = \frac{\dot{n}_{\text{H}_2, \text{avail}}}{\dot{n}_{\text{H}_2, \text{perm}}} = \frac{\dot{n}_{15, \text{H}_2}}{\dot{n}_{22, \text{H}_2}} \quad (3.27)$$

With all other system parameters fixed, the value of hydrogen capture effectively sets the required membrane surface area. The purity of permeated hydrogen has been consistently shown to be above 99.9% in defect-free palladium based membranes [14,34,35]. Thus, it was assumed that only H<sub>2</sub> permeates through the membrane.

H<sub>2</sub> permeation in a MR is driven by a concentration gradient across the membrane. There are two primary variables that adjust the concentration gradient: feed and permeate pressure difference, and sweep steam (#12) flow rate. A high feed to permeate pressure ratio increases the driving force for H<sub>2</sub> permeation through the membrane. There is a wide variety of values in literature for reforming pressure. Practical limits at atmospheric pressure and NG pipeline pressure (~70 bar) can be imposed to avoid unnecessary complexity. Higher pressure systems have tradeoffs: although hydrogen permeation is improved, steam takes more energy to boil, CO<sub>2</sub> can liquefy prematurely, and physical components must be designed to withstand high pressure. Higher pressures add cost in terms of both fuel and infrastructure, compromise the safety of the process, and increase the operating costs. In this study, a high side pressure of 15 bar and a permeate pressure of 2 bar appeared to be a good compromise among these competing variables, providing a sufficient diffusion gradient while avoiding additional complexity.

The H<sub>2</sub> partial pressure can be reduced and thus improve the driving force for H<sub>2</sub> permeation by two methods: reducing total pressure on the permeate side, and increasing the flow rate of sweep steam (#12) to dilute the H<sub>2</sub>. The amount of sweep steam is defined by a steam to carbon ratio (SC), which is typically defined in literature as the molar ratio of sweep steam to methane in the feed [9,64], given by Equation (3.28):

$$SC_{\text{sweep}} = \frac{\dot{n}_{\text{steam,sweep}}}{\dot{n}_{\text{CH}_4,\text{feed}}} = \frac{\dot{n}_{12}}{\dot{n}_{14,\text{CH}_4}} \quad (3.28)$$

In a recent study on a MR, the SC for sweep steam was varied between 1.0 and 5.0 [64]. It was found that the addition of more sweep gas increases the H<sub>2</sub> permeation rate at the expense of increased heat duty to generate additional steam. Thus, a SC ratio for the permeate steam was fixed at 1.0 in the present study based on the most effective value reported by De Falco et al. [64].

The SC for the reaction is defined similarly, using the steam flow rate in the feed instead [9,64], as in Equation (3.29):

$$SC_{\text{reac}} = \frac{\dot{n}_{\text{steam,feed}}}{\dot{n}_{\text{CH}_4,\text{feed}}} = \frac{\dot{n}_{10}}{\dot{n}_{14,\text{CH}_4}} \quad (3.29)$$

The SC for the reaction varies from 2 to 5 in the literature, with a most common base value of 3.0, which was used in the present study [9,64,93]. This sets steam as the limiting reagent in the reforming reaction, facilitating higher methane conversion.

Permeance is a characteristic of the hydrogen-separating membrane and represents the ability of gaseous hydrogen atoms to penetrate and permeate through a membrane of a specific thickness. Peters et al. reported one of the best permeability values to date at  $4.1 \times 10^{-8} \text{ mol m}^{-1} \text{ s}^{-1} \text{ Pa}^{-0.5}$  with a membrane thickness of  $2.8 \mu\text{m}$  [12,92,94], at the same 400°C reforming temperature as this study. The permeance was calculated as the permeability divided by the membrane thickness.

For the heat exchangers, the closest approach temperature (CAT) is defined as the minimum temperature difference in a counter-flow heat exchanger between the hot fluid outlet and the cold fluid inlet (Figure 3-3). Similar to the pressure difference across the membrane reactor, larger values of CAT reduce the capital cost by increasing the driving force for heat transfer, which reduces the surface area required. However, these higher CATs reduce energy recovery, and lower system efficiency. This study assumes a CAT of 5°C.

Ambient conditions of 15°C and 1 bar were chosen as realistic for an implemented plant. The molar concentrations of nitrogen and oxygen in air were given by Cengel et al. [95]. It was assumed that no other species were present in the ambient air.

This study focused on low-pressure steam boilers as opposed to hot water boilers or high-pressure boilers. Oak Ridge National Laboratory defines low-pressure steam boilers as producing steam at 350 - 400°F (177 - 204°C) and 125 - 250 psig (8.6 to 17.2 bar) [40]. The exported steam temperature and pressure of 200°C and 15 bar were selected within those limits as a realistic output of a low-pressure natural gas fired steam boiler. The values are towards the upper limits to provide additional driving force for hydrogen permeation and closer match the reforming temperature of 400°C. The reforming pressure, which is nominally the same as the feed and retentate pressures, was chosen to match the steam export pressure. This simplified the system significantly by avoiding several different steam pressures. In a typical steam generation application such as district heating, steam is used to supply heat, and the cool water returns to be recycled in the steam generation plant. The amount of cool water that returns is approximately 80% of the export steam by mass [78].

There are several methods of separating CO<sub>2</sub> from the retentate stream in the SMR-MR-SG system. Recent literature agrees that cryogenic separation is the most cost-effective way to

separate CO<sub>2</sub> from the retentate stream [22,91]. In the thermodynamic cycle proposed in Figure 3-1, the CO<sub>2</sub> is processed in three steps: liquification via cryogenic cooling to -51°C, distillation to separate the liquid CO<sub>2</sub> from the gases, and compression to 75 bar to raise the liquid above its critical pressure for storage [91]. State-of-the-art cryogenic separation can achieve 99.9% CO<sub>2</sub> purity after separation with a 90% CO<sub>2</sub> capture efficiency [91]. Chiesa et al. have shown examples of cryogenic CO<sub>2</sub> separation after water condensation for the purpose of separating CO<sub>2</sub> from exhaust gases [96].

Chemical reactions have a propensity to become extremely complicated with increasing model fidelity. This study focused on a system level view and thus simplified chemistry to a single reforming reaction. It is possible in steam methane reforming to have carbon monoxide in the retentate stream if the water-gas shift reaction doesn't go to completion. It was assumed that any carbon monoxide formed was converted to carbon dioxide immediately. No chemical reaction rates were considered; it was assumed that all reactions occurred infinitely fast. The membrane reactor was assumed adiabatic to the environment, which could be closely mirrored in a physical system with sufficient insulation. Each zone in the membrane reactor was treated as isobaric, isothermal, and otherwise homogenous. Solsvik et al. proved that isobaric and isothermal conditions can be assumed for the permeation zone without significantly hurting the accuracy of the model accuracy [15]. This study uses natural gas and methane interchangeably. In the thermodynamic analysis, all properties and reactions involving natural gas are evaluated using pure methane.

Heat exchangers were modeled as isobaric and adiabatic to the environment, assuming they would be well insulated in an industrial plant. They were modeled in a counter-flow arrangement to maximize amount of heat recovery from low temperature fluids. For estimating capital costs,

the heat exchangers were modeled as carbon steel, shell and tube type heat exchangers with the cold fluid in the outer shell.

Fluids were assumed to have real fluid properties. This was important as water and carbon dioxide exist as both liquids and gases in the proposed system. For consistency, all fluids were modeled as real fluids as opposed to ideal gases. The fluids were treated as ideal in that a mixture of gases did not interact with itself except for the intended reforming reaction. Properties of a mixture of gases were calculated as the molar weighted average of the properties. Fluids were assumed to have negligible pressure drops throughout the system.

The combustion of hydrogen was assumed to be complete and stoichiometric. This defined the flow rate of the ambient air inlet as well as the combustion of the combustion exhaust. Water condensers were assumed to be 100% effective at removing water and only water. In general, the system was assumed to be adiabatic to the environment except where components (condensers, compressor, pump, and cryogenic unit) explicitly rejected heat. This section outlined the inputs and assumptions that drove the thermodynamic model. The next section will discuss the development of the model in detail.

### **3.2.3. Thermodynamic Analysis**

This section will explain the development process and methodology of the thermodynamic analysis of the SMR-MR-SG system shown in Figure 3-1. The conceptual modeling process was as follows: the export steam (#9) temperature, pressure, and mass flow rate were set based on input parameters. The heat duty required to generate the export steam set the flow rate of hydrogen needed for combustion, which then set the size of the membrane reactor. Working iteratively, the flow rates of the entire system were set. Then, an energy balance on each component set enthalpies of flows. Analyzing the temperatures in each heat exchanger, further adjustments were made to

prevent temperatures from crossing in heat exchangers. This set final state points (temperature, pressure, quality if applicable, flow rate, mole fractions, and flow enthalpy) of each stream.

The ultimate goal of this study was to compare the proposed SMR-MR-SG against the state-of-the-art in steam generation: high-efficiency natural gas fired boiler systems, with and without CO<sub>2</sub> capture. The SMR-MR-SG system scale was set by using the same steam export mass flow rate as the BS and BSC systems.

The first step in developing the model was to define flow rates and mole fractions for every stream. The state of (#9) was set completely by the input parameters for export steam: temperature, pressure, and mass flow rate. A simple mass balance, Equation (3.30), balanced the flow of steam:

$$\dot{n}_{8,H_2O} = \dot{n}_{9,H_2O} + \dot{n}_{10,H_2O} + \dot{n}_{11,H_2O} \quad (3.30)$$

This equation was under defined at this point: the flow rate at 9 was known, but two more equations were needed. The reaction steam (#10) and sweep steam (#11) could be defined by the steam to carbon ratios in the input parameters, but the “carbon” part of the ratio (i.e., the flow rate of methane in (#14)) was not yet known. Hence, the model development advanced using placeholders, or approximate values entered as inputs until enough information was available to solve for the true value. Putting in placeholders for the reaction steam (#10) and sweep steam (#11) flow rates allowed the model to solve for flow (#8). Defining a boiler efficiency as the ratio of heat into steam to heat from fuel, the flow enthalpy of hydrogen (#22) was calculated using Equation (3.31):

$$\eta_{\text{boiler},H_2} = \frac{\dot{Q}_{\text{boiler,steam}}}{\dot{Q}_{\text{boiler,fuel,input}}} = \frac{\dot{H}_8 - \dot{H}_7}{\dot{H}_{22} + \dot{H}_{23} - \dot{H}_{24,\text{amb}}} \quad (3.31)$$


where  $\dot{H}_{24,\text{amb}}$  is the flow enthalpy of the boiler exhaust at ambient temperature and pressure. This is the same definition as the previously discussed boiler efficiency for evaluating system performance, with the exception that the fuel in the SMR-MR-SG’s boiler is H<sub>2</sub>. Also, the boiler

efficiency in the SMR-MR-SG system was set lower at approximately 50% in order to balance required heat for steam generation with required heat for the membrane reactor and preheating reactants. Boiler efficiency was another placeholder parameter at this point, so the value was set at 50% with a note to solve for the actual value later.

Continuing to work backwards, the flow rate of (#22) was calculated from the flow enthalpy of (#22). Using the known permeation rate of H<sub>2</sub> through the membrane, the flow rate of stream (#15) was set by Equation (3.32):

$$\dot{n}_{15,H_2} \cdot \eta_{H_2,capt} = \dot{n}_{22,H_2} \quad (3.32)$$

The flow rates of the permeate (#16) and intermediate reaction step (#15) were set using the known chemical reactions and extent of methane conversion. Again, placeholders had to be introduced temporarily due to circular dependencies. For instance, some amount of H<sub>2</sub> was present in stream (#14) due to the recycled gases at (#21), but the amount wasn't known yet. The net chemical reaction relating stream (#14) to (#15) is given by Equation (3.33):



This chemical reaction was translated into EES via Equations (3.34) through (3.37):

$$\dot{n}_{15,CH_4} = \left(1 - \eta_{CH_4,conv}\right)\dot{n}_{14,CH_4} \quad (3.34)$$

$$\dot{n}_{15,H_2O} = \dot{n}_{14,H_2O} - \left(2 \cdot \eta_{CH_4,conv}\right)\dot{n}_{14,CH_4} \quad (3.35)$$

$$\dot{n}_{15,CO_2} = \dot{n}_{14,CO_2} + \left(1 \cdot \eta_{CH_4,conv}\right)\dot{n}_{14,CH_4} \quad (3.36)$$

$$\dot{n}_{14,CH_4} \cdot 4 \cdot \eta_{CH_4,conv} + \dot{n}_{14,H_2} = \dot{n}_{15,H_2} \quad (3.37)$$

Continuing to work backwards, the flow rate of methane in the feed (#14) allowed steam flow rates at the feed (#14) and sweep steam (#12) to be set using the definition of the two steam to carbon

ratios in Equations (3.29) and (3.28). Most flow rates were set in a more straightforward way: the flow rate and composition of the sweep steam after (#12) and before pressure drop (#11) are equal; the superheated feed (#14) and feed before superheating (#13) are also equal. The flow rate and composition of the retentate (#16) was set as what was left from 15 after hydrogen permeation through the membrane, using Equations (3.38) through (3.41):

$$\dot{n}_{16,\text{CH}_4} = \dot{n}_{15,\text{CH}_4} \quad (3.38)$$

$$\dot{n}_{16,\text{H}_2} = \dot{n}_{15,\text{H}_2} - \dot{n}_{22,\text{H}_2} \quad (3.39)$$

$$\dot{n}_{16,\text{H}_2\text{O}} = \dot{n}_{15,\text{H}_2\text{O}} \quad (3.40)$$

$$\dot{n}_{16,\text{CO}_2} = \dot{n}_{15,\text{CO}_2} \quad (3.41)$$

Following the permeate stream (#16), flow and composition were unchanged from (#16) to (#17) through HE 5. All water was condensed out from the retentate (#17) in the water condenser (HE 6), with the condensed water in stream (#32) and the remaining gases in the dehydrated retentate (#18). This was represented by Equations (3.42) through (3.45):

$$\dot{n}_{32,\text{H}_2\text{O}} = \dot{n}_{17,\text{H}_2\text{O}} \quad (3.42)$$

$$\dot{n}_{18,\text{CH}_4} = \dot{n}_{17,\text{CH}_4} \quad (3.43)$$

$$\dot{n}_{18,\text{H}_2} = \dot{n}_{17,\text{H}_2} \quad (3.44)$$

$$\dot{n}_{18,\text{CO}_2} = \dot{n}_{17,\text{CO}_2} \quad (3.45)$$

From there, the dehydrated retentate (#18) was cryogenically cooled, liquefying and separating most of the CO<sub>2</sub> to the captured CO<sub>2</sub> (#19) while the remaining gases left via the recycled gas stream (#21). In EES, this process was described by Equations (3.46) through (3.49):

$$\dot{n}_{19,\text{CO}_2} = \eta_{\text{CO}_2,\text{sep}} \cdot \dot{n}_{18,\text{CO}_2} \quad (3.46)$$

$$\dot{n}_{21,\text{CO}_2} = \dot{n}_{18,\text{CO}_2} - \dot{n}_{19,\text{CO}_2} \quad (3.47)$$

$$\dot{n}_{21,H_2} = \dot{n}_{18,H_2} \quad (3.48)$$

$$\dot{n}_{21,CH_4} = \dot{n}_{18,CH_4} \quad (3.49)$$

The composition and molar flow of the captured CO<sub>2</sub> before (#19) and after compression (#20) are identical; stream (#20) is just at an increased pressure.

Working backwards from the feed prior to superheat (#13), the steam in (#13) comes from the reaction steam (#10); all other gases are supplied from the preheated mixed gas supply (#3). In EES, this was modeled with Equations (3.50) through (3.53)

$$\dot{n}_{10,H_2O} = \dot{n}_{13,H_2O} \quad (3.50)$$

$$\dot{n}_{3,CH_4} = \dot{n}_{13,CH_4} \quad (3.51)$$

$$\dot{n}_{3,H_2} = \dot{n}_{13,H_2} \quad (3.52)$$

$$\dot{n}_{3,CO_2} = \dot{n}_{13,CO_2} \quad (3.53)$$

With the composition and flow of the cold mixed gas supply (#2) set equal to the preheated mixed gas supply (#3), and the recycled gases (#21) known, the natural gas supply (#1) was set as the difference in methane between the two streams, calculated using Equation (3.54):

$$\dot{n}_{1,CH_4} + \dot{n}_{21,CH_4} = \dot{n}_{2,CH_4} \quad (3.54)$$

Although it doesn't show up here, the recycled hydrogen in the recycled gases (#21) does reduce the makeup methane required from the natural gas supply (#1) by reducing the amount of methane that is needed for conversion from the superheated feed (#14) to the reformed products before separation (#15).

The composition of the ambient air (#23) was set from input parameters; the flow rate was set using the chemical reaction for combustion of hydrogen, Equation (3.55):



This reaction assumed that the nitrogen present in the ambient air (#23) and the steam present in the permeated hydrogen (#22) did not participate in the chemical reaction. The nitrogen and steam were considered in the energy balance which later set the heat duty of the boiler and the temperature of the boiler exhaust (#24). Translating Equation (3.55) into EES, the ambient air (#23) flows were set using Equations (3.56) and (3.57):

$$\dot{n}_{23,O_2} = \frac{1}{2} \dot{n}_{22,H_2} \quad (3.56)$$

$$\dot{n}_{23,N_2} = \left( \frac{y_{23,N_2}}{y_{23,O_2}} \right) \dot{n}_{23,O_2} \quad (3.57)$$

The flow of the exhaust was also set based on Equation (3.55), translated into EES as Equations (3.58) and (3.59):

$$\dot{n}_{24,H_2O} = (1) \dot{n}_{22,H_2} + \dot{n}_{22,H_2O} \quad (3.58)$$

$$\dot{n}_{24,N_2} = \dot{n}_{23,N_2} \quad (3.59)$$

The flow of the boiler exhaust through the system was simple to set, with the flow and composition being equal from (#24) through (#29). In the water condenser (HE 7), the water is removed from the boiler exhaust (#29), expressed by Equations (3.60) and (3.61):

$$\dot{n}_{31,H_2O} = \dot{n}_{29,H_2O} \quad (3.60)$$

$$\dot{n}_{30,N_2} = \dot{n}_{29,N_2} \quad (3.61)$$

Working backwards from the boiler, the flow and composition of the total generated steam (#8), preheated boiler feed (#7), pressurized water supply (#6), and ambient water supply (#5) are equal. The flows of water from each condenser (#31) and (#32) were previously set by the amount of water in the boiler exhaust (#29) and retentate (#17), respectively. A mass balance on the water tank set the amount of makeup water (#4) needed using Equation (3.62):

$$\dot{n}_{4,H_2O} + \dot{n}_{31,H_2O} + \dot{n}_{32,H_2O} = \dot{n}_{5,H_2O} \quad (3.62)$$

With molar flow rates and compositions set at each set, the next step was to set temperatures, pressures, and enthalpies. Assuming all molar flow rates and compositions are known, flow enthalpy is a function of temperature, and pressure; knowing any two of temperature, pressure, and flow enthalpy set the third.

The temperature of most streams and the pressure of all streams were fixed based on input parameters, as shown in Table 3-7. From the known temperature and pressure and pressure of each state, the flow enthalpy could be calculated.

**Table 3-7:** Temperature and pressure of states set directly by input parameters.

State	T	P	State	T	P
1	$T_{amb}$	$P_{ref,high}$	18	$T_{amb}$	$P_{ref,high}$
2	$T_{amb}$	$P_{ref,high}$	19	$T_{cryo}$	$P_{ref,high}$
3	$T_{steamGen}$	$P_{ref,high}$	20	$T_{cryo}$	$P_{cCO_2}$
4	$T_{amb}$	$P_{amb}$	21	$T_{amb}$	$P_{ref,high}$
5	$T_{amb}$	$P_{amb}$	22	$T_{reform}$	$P_{ref,low}$
6	$T_{amb}$	$P_{steamGen}$	23	$T_{amb}$	$P_{amb}$
7	?	$P_{amb}$	24	?	$P_{ref,low}$
8	$T_{steamGen}$	$P_{steamGen}$	25	?	$P_{ref,low}$
9	$T_{steamGen}$	$P_{steamGen}$	26	?	$P_{ref,low}$
10	$T_{steamGen}$	$P_{steamGen}$	27	?	$P_{ref,low}$
11	$T_{steamGen}$	$P_{steamGen}$	28	?	$P_{ref,low}$
12	$T_{reform}$	$P_{ref,low}$	29	$T_{amb} + CAT$	$P_{ref,low}$
13	$T_{steamGen}$	$P_{ref,high}$	30	$T_{amb}$	$P_{amb}$
14	$T_{reform}$	$P_{ref,high}$	31	$T_{amb}$	$P_{amb}$
15	$T_{reform}$	$P_{ref,high}$	32	$T_{amb}$	$P_{amb}$
16	$T_{reform}$	$P_{ref,high}$	33	$T_{amb}$	$P_{amb}$
17	$T_{amb} + CAT$	$P_{ref,high}$			

The goal of the next phase of the model development was to balance the heat duty in the heat exchangers, membrane reactor, and boiler with the change in flow enthalpy of each stream to set the remaining temperatures in Table 3-7. As with previous sections, this was an iterative process, where placeholders were temporarily set, and the final set of equations was solved simultaneously.

Returning to the H<sub>2</sub> boiler in the SMR-MR-SG system, an energy balance was performed to balance three heat flows: total heat input to the boiler in the form of hydrogen, heat out to steam, and heat out to exhaust. The three were related by Equation (3.31) as well as Equations (3.63) through (3.65):

$$\dot{Q}_{\text{boiler,fuel,input}} = \dot{Q}_{\text{boiler,steam}} + \dot{Q}_{\text{boiler,exh}} \quad (3.63)$$

$$\dot{Q}_{\text{boiler,fuel,input}} = \dot{H}_{22} + \dot{H}_{23} - \dot{H}_{24,\text{amb}} \quad (3.64)$$

$$\dot{Q}_{\text{boiler,steam}} = \dot{H}_8 - \dot{H}_7 \quad (3.65)$$

where  $\dot{H}_{24,\text{amb}}$  is the flow enthalpy of the boiler exhaust at ambient temperature and pressure. The energy balance on HE 1 was expressed as a difference of enthalpies as in Equations (3.66) and (3.67):

$$\dot{Q}_{\text{HE1}} = \dot{H}_{22} + \dot{H}_{16} - \dot{H}_{14} - \dot{H}_{12} \quad (3.66)$$

$$\dot{Q}_{\text{HE1}} = \dot{H}_{24} - \dot{H}_{25} \quad (3.67)$$

Similarly, the energy balance on heat exchanger 2 was performed by Equations (3.68) and (3.69):

$$\dot{Q}_{\text{HE2}} = \dot{H}_{12} - \dot{H}_{11} \quad (3.68)$$

$$\dot{Q}_{\text{HE2}} = \dot{H}_{25} - \dot{H}_{26} \quad (3.69)$$

The energy balance on heat exchanger 3 was calculated by Equations (3.70) and (3.71):

$$\dot{Q}_{\text{HE3}} = \dot{H}_{14} - \dot{H}_{13} \quad (3.70)$$

$$\dot{Q}_{\text{HE3}} = \dot{H}_{26} - \dot{H}_{27} \quad (3.71)$$

The energy balance on heat exchanger 4 was calculated by Equations (3.72) and (3.73):

$$\dot{Q}_{\text{HE4}} = \dot{H}_3 - \dot{H}_2 \quad (3.72)$$

$$\dot{Q}_{\text{HE4}} = \dot{H}_{27} - \dot{H}_{28} \quad (3.73)$$

The energy balance on HE 5 was different than the previous heat exchangers due to it being a three-fluid heat exchanger. It was assumed that there was no interaction between the two hot fluids (#16-17) and (#28-29). In other words, the increase in heat from the pressurized water supply (#6) to the preheated boiler feed (#7) was calculated as the sum of heat loss from the retentate (#16) to (#17) and from the boiler exhaust (#28) to (#29). The energy balance was calculated using Equations (3.74) through (3.77):

$$\dot{Q}_{HE5,total} = \dot{Q}_{HE5,ret} + \dot{Q}_{HE5,exh} \quad (3.74)$$

$$\dot{Q}_{HE5,total} = \dot{H}_7 - \dot{H}_6 \quad (3.75)$$

$$\dot{Q}_{HE5,ret} = \dot{H}_{16} - \dot{H}_{17} \quad (3.76)$$

$$\dot{Q}_{HE5,exh} = \dot{H}_{28} - \dot{H}_{29} \quad (3.77)$$

where the subscript *ret* refers to the retentate (#16-17) and *exh* refers to the boiler exhaust (#28-29). The temperature and pressure of every state was now set, but not at quite the correct value: the next section of the model ensured that no temperatures crossed within heat exchangers.

The inlet and outlet temperatures at each heat exchanger were checked. If temperatures crossed, that was a problem that needed to be resolved. For example, the temperatures in HE 2 *at this point in the model development, before it was revised* are shown in Table 3-8.

**Table 3-8:** Example of heat exchanger temperatures crossing during thermodynamic model development.

	Inlet temperature [°C] (State Point)	Outlet temperature [°C] (State Point)
<b>Cold Fluid</b>	200 (#11)	400 (#12)
<b>Hot Fluid</b>	390 (#25)	365.1 (#26)

Here, the hot fluid inlet is less than the cold fluid outlet. Heat can only flow naturally from a hot to cold temperature, so this represented an impossible condition. Since both cold fluid temperatures were set permanently by model inputs, the problem was resolved by setting the hot inlet to the cold outlet, plus the closest approach temperature (CAT). This is shown in Equation (3.78):

$$T_{26} = T_{14} + CAT \quad (3.78)$$

Adjustments like Equation (3.78) were made until no heat exchanger temperatures crossed. The adjustments in the boiler exhaust temperature worked their way back upstream (#26, #25, #24, etc.), effectively varying the H<sub>2</sub> boiler efficiency iteratively until both the energy balances and temperature constraints were satisfied.

At this point, every thermodynamic state in the system was fully defined. Next, several calculations were made to evaluate parameters of interest such as overall efficiency and mass flow rate of imports and exports. Some additional parameters were also calculated as inputs to the technoeconomic model, such as total electrical work input.

The natural gas energy input was calculated with an enthalpy difference rather than lower heating value (LHV) for consistency with the rest of the program. The energy input was based on the stoichiometric, complete combustion of methane, given in Equation (3.79):



The heat supplied by the natural gas supply (#1) was calculated based on the difference of flow enthalpy (#1) and the ambient combustion products, shown in Equation (3.80):

$$\dot{Q}_{NG,in} = \dot{H}_1 - \dot{H}_{1,comb,amb} \quad (3.80)$$

where  $\dot{H}_1$  was evaluated based on the known flow  $\dot{n}_{1,CH_4}$  and the hypothetical amount of oxygen needed to fully combust the methane, at temperature and pressure (#1).  $\dot{H}_{1,comb,amb}$  was evaluated

based on the molar flows of H<sub>2</sub>O and CO<sub>2</sub> calculated by Equation (3.79), at ambient temperature and pressure. As a check, the heat input from natural gas was also calculated using the higher heating value (HHV) in Equation (3.81):

$$\dot{Q}_{\text{NG,input,check}} = \dot{m}_{1,\text{CH}_4} \cdot \text{HHV}_{\text{CH}_4} \quad (3.81)$$

The heat from Equation (3.81) matched the heat from the heat from Equation (3.80) to within 1.7% difference. The HHV was used instead of the LHV because the energy from steam condensation was accounted for and utilized in the SMR-MR-SG system.

Likewise, a check was performed to ensure that the energy balance in the boiler was accurate. Equation (3.82) evaluated the heat input to the H<sub>2</sub> boiler using the higher heating value (HHV) of hydrogen:

$$\dot{Q}_{\text{boiler,fuel,input}} = \dot{m}_{22,\text{H}_2} \cdot \text{HHV}_{\text{H}_2} \quad (3.82)$$

Again, this check showed less than 2% deviation from Equation (3.63). Values for higher heating value were supplied internally by EES.

The work output of the water pump and CO<sub>2</sub> compressor were calculated based on enthalpy changes, as in Equations (3.83) and (3.84):

$$\dot{W}_{\text{pump,out}} = \dot{H}_6 - \dot{H}_5 \quad (3.83)$$

$$\dot{W}_{\text{comp,out}} = \dot{H}_{20} - \dot{H}_{19} \quad (3.84)$$

The efficiencies of the pump, compressor, and cryogenic unit set the electrical input required for the SMR-MR-SG system based on the calculated work out to the fluid, as in Equations (3.85) and (3.86):

$$\eta_{\text{pump}} = \frac{\dot{W}_{\text{pump,out}}}{\dot{W}_{\text{pump,elec,in}}} \quad (3.85)$$

$$\eta_{\text{comp}} = \frac{\dot{W}_{\text{comp,out}}}{\dot{W}_{\text{comp,elec,in}}} \quad (3.86)$$

The work of the cryogenic CO<sub>2</sub> separation unit was evaluated based on Xu et al.'s model in Equation (3.87) [91]:

$$\dot{W}_{\text{cryo,elec,in}} = (425 \text{ MJ kg}_{\text{CO}_2}^{-1}) (\dot{n}_{9,\text{CO}_2}) (M_{\text{CO}_2}) \quad (3.87)$$

The actual work imparted to the fluid by the CSU was calculated by Equation (3.88):

$$\dot{W}_{\text{cryo,out}} = \dot{H}_{18} - \dot{H}_{19} - \dot{H}_{21} \quad (3.88)$$

The total electrical work into the system was calculated as the sum of the work inputs for pump, compressor, and CSU via Equation (3.89):

$$\dot{W}_{\text{elec,in,total}} = \dot{W}_{\text{pump,elec,in}} + \dot{W}_{\text{comp,elec,in}} + \dot{W}_{\text{cryo,elec,in}} \quad (3.89)$$

The actual energy delivered to the fluid for the purpose of CO<sub>2</sub> separation and compression was defined by Equation (3.90):

$$\dot{Q}_{\text{CO}_2,\text{export}} = \dot{H}_{20,\text{amb}} - \dot{H}_{20} \quad (3.90)$$

where  $\dot{H}_{20,\text{amb}}$  was calculated the same way as  $\dot{H}_{20,\text{amb}}$  except at ambient temperature and pressure.

The pressure was dropped in the sweep steam from 15 bar (#10) to 2 bar (#11) without recovering energy from the expansion. The energy lost was calculated by Equation (3.91):

$$\dot{Q}_{\text{sweep},\Delta P} = \dot{H}_{11,\text{highP}} - \dot{H}_{11} \quad (3.91)$$

where  $\dot{H}_{11,\text{highP}}$  was calculated the same as  $\dot{H}_{11}$ , but at a pressure of 15 bar instead of 2 bar. This is a source of waste heat that could be captured by a small steam turbine. However, the energy lost in the sweep steam expansion is approximately 0.2% of the natural gas input. The additional complexity and expense of adding a small turbine would vastly outweigh the potential energy savings.

An overall boiler efficiency for the SMR-MR-SG was used as the most direct comparison to the benchmark natural gas boiler, and was defined by Equation (3.92):

$$\eta_{\text{overall,boiler}} = \frac{\dot{Q}_{\text{steam,export}}}{\dot{Q}_{\text{NG,in}} + \dot{W}_{\text{elec,in}}} \quad (3.92)$$

where overall boiler efficiency is a simple indication of the percentage of utilized energy from the fuel input. This is different than the H<sub>2</sub> boiler efficiency, which characterized just the H<sub>2</sub> boiler within the SMR-MR-SG system.

### 3.2.4. Cost Calculations

The capital cost of the SMR-MR-SG system was calculated as the sum of its components. Install factors for all three systems were neglected due to the comparative nature of the study. The capital cost of the membrane reactor was calculated based on its surface area. The thickness of the Pd-alloy membrane largely drives surface area, and hence the cost, of the membrane. A thicker membrane obviously requires more Pd-alloy, but the effect is further compounded: for a given hydrogen flux, a thicker membrane requires more surface area. As mentioned in the literature review, membrane thicknesses as low as 0.93 μm have been achieved with no defects [60,61,94,97]. This study used a conservative thickness of 2.8 μm, corresponding to a state-of-the-art permeance of 6.48x10<sup>-3</sup> mol m<sup>-2</sup> s<sup>-1</sup> Pa<sup>-0.5</sup>, calculated from the permeability of 4.1×10<sup>-8</sup> mol m<sup>-1</sup> s<sup>-1</sup> Pa<sup>-0.5</sup> divided by membrane thickness [12,92,94].

The membrane surface area was calculated using H<sub>2</sub> permeating flux through the membrane, H<sub>2</sub> partial pressure on both sides of the membrane, and membrane thickness. Assuming that solution-diffusion is the governing transport mechanism for hydrogen flux, the surface area is calculated by rearranging Equation (2.8) into Equation (3.93) [22]:

$$A_{\text{mem}} = \frac{\dot{n}_{\text{H}_2,\text{mem}}}{K_{\text{mem}} \left( P_{\text{ret}}^n - P_{\text{per}}^n \right)} \quad (3.93)$$

The dependent factor  $n$  is a parameter that correlates the permeating flux with the driving force. When the membrane is defect-free and it shows ‘infinite’ perm-selectivity towards  $H_2$ ,  $n$  assumes a value of 0.5. Note that any degradation factor requiring additional membrane surface area because of recycled gas is implicit in the thermodynamic model. Additional recycled gas (from inefficiency in methane conversion, hydrogen recovery, or carbon dioxide capture) dilutes the hydrogen on the feed side of the membrane, changing the partial pressure of hydrogen and thus the driving force for permeation. Therefore, an increase in amount of recycled gas does have an effect on the required membrane surface area and thus on the capital cost. The effect is not necessarily negative; un-permeated hydrogen can be recycled, which increases driving force through the membrane.

This study uses a combination of “best-case” values of MR parameters from literature. It is assumed that, at a larger scale implementation of the SMR-MR-SG, scaling factors would allow for reduced material and fabrication costs. For example, a tube in tube configuration for a membrane reactor is useful for laboratory scale experiments, but new designs to increase surface area to volume ratio are necessary at the industrial scale [48].

The capital cost of Pd-based membranes is significantly affected by both material cost and fabrication method. The material cost of Palladium is relatively unpredictable, ranging between \$3,500 and \$45,000 per kg over the last 20 years [98]. Recently, novel fabrication techniques have rapidly dropped Pd membrane costs down to as low as \$100 per  $ft^2$  (\$1,076 per  $m^2$ ) [50,99,100]. The membrane cost was calculated by Equation (3.94):

$$CapEx_{\text{membrane}} = A_{\text{mem}} \cdot \frac{\$1,076}{m^2} \quad (3.94)$$

The reactor (i.e., the membrane reactor minus the membrane) cost was calculated using a scaling factor and a known cost of \$14,100 corresponding to  $4.79 \text{ kg}_{H_2} \text{ h}^{-1}$  [22] via Equation (3.95):

$$CapEx_{\text{reactor}} = \$14,100 \cdot \left( \frac{\dot{m}_{\text{H}_2}}{4.79 \text{ kg h}^{-1}} \right)^{0.7} \quad (3.95)$$

The cost of each heat exchanger was calculated based on its required heat transfer area using the method of Brown [86]. The calculations to determine required heat transfer area were completed using the epsilon-NTU method described by Bergman et al. [90]. The working units of flow were  $\text{kmol s}^{-1}$  rather than the more customary  $\text{kg s}^{-1}$  due to the modeling of chemical reactions throughout the model. As a result, fluid properties were in molar units (e.g., units of specific heat were  $\text{kJ kmol}^{-1} \text{K}^{-1}$ ). The process of calculating required heat exchanger surface areas is described in detail in APPENDIX B to avoid distraction from the cost calculations. The capital cost of each heat exchanger was calculated directly from the heat transfer surface area (in square feet), using Equation (3.96):

$$CapEx_{\text{HE}} = (\$462) \cdot \left( A_{\text{ht,hot}} \cdot \frac{10.76 \text{ ft}^2}{\text{m}^2} \right)^{0.5} \quad (3.96)$$

Heat exchanger 5 was more complicated for two reasons: it involved flow boiling, and it used three fluids (instead of two). Heat exchanger 5 was split up into two sections: preheating liquid water to saturation temperature, and boiling from saturated liquid to two-phase with  $0 < X < 1$ . Each section of the heat exchanger was sized independently, and a cost for each was calculated using Equation (3.96). The separate parts of heat exchanger 5 (preheating and boiling) were added and multiplied by a factor of 1.5 to account for the added complexity of a three-fluid heat exchanger [101]. The total capital cost of heat exchanger 5 was calculated by Equation (3.97):

$$CapEx_{\text{HE5,total}} = 1.5 \cdot (CapEx_{\text{HE5,preheat}} + CapEx_{\text{HE5,boil}}) \quad (3.97)$$

The capital cost for the  $\text{H}_2$  boiler within the SMR-MR-SG system was calculated using Equation (3.98) [22]:

$$CapEx_{\text{boiler}} = \$44,000 \cdot \left( \frac{\dot{Q}_{\text{boiler,input}}}{2MW} \right)^{0.67} \quad (3.98)$$

Similarly, the capital cost of the water pump was calculated by Equation (3.99) [22]:

$$CapEx_{\text{pump}} = \$1,200 \cdot \left( \frac{\dot{V}_{\text{water}}}{90 L h^{-1}} \right)^{0.7} \quad (3.99)$$

The capital cost of each condenser was calculated by Equation (3.100) [88]:

$$CapEx_{\text{cond}} = 3.75 \frac{\$_{2018}}{\pounds_{1987}} \cdot 213 \pounds_{1987} \cdot (\dot{Q}_{\text{cond}})^{0.38} \quad (3.100)$$

The capital cost of the cryogenic CO<sub>2</sub> separator was calculated using Equation (3.101) [22]:

$$CapEx_{\text{Cryo}} = \$475,000 \cdot \left( \frac{\dot{m}_{\text{CO}_2}}{0.6 \text{ t}_{\text{CO}_2} h^{-1}} \right)^{0.7} \quad (3.101)$$

Similarly, the cost of the CO<sub>2</sub> compressor was calculated using Equation (3.102) [22]:

$$CapEx_{\text{comp}} = \$3,000,000 \cdot \left( \frac{\dot{W}_{\text{comp}}}{6 \text{ MW}} \right)^{0.7} \quad (3.102)$$

The operating cost of the cryogenic CO<sub>2</sub> separator, CO<sub>2</sub> compressor, and water pump were calculated based on their required input work and the cost of electricity using Equations (3.103) through (3.105):

$$OpEx_{\text{Cryo}} = \dot{W}_{\text{cryo,in}} \cdot \text{Price}_{\text{elec}} \quad (3.103)$$

$$OpEx_{\text{comp}} = \dot{W}_{\text{comp,in}} \cdot \text{Price}_{\text{elec}} \quad (3.104)$$

$$OpEx_{\text{pump}} = \dot{W}_{\text{pump,in}} \cdot \text{Price}_{\text{elec}} \quad (3.105)$$

The operating and maintenance cost of the membrane reactor system in \$ yr<sup>-1</sup> was assumed to be 5% of the total capital expense in \$ [50], calculated in Equation (3.106):

$$OpEx_{\text{SMR,system}} = 0.05 \cdot CapEx_{\text{SMR,system}} \quad (3.106)$$

This operating expense includes the cost of replacing membranes approximately every three years [22]. The cost of procurement, assembly, and installation can add an additional 42.5% on top of the base capital cost [101,102]; these costs weren't considered for all three systems because similar values would be anticipated for similar system functions

### **3.3. CO<sub>2</sub> Capture**

In the SMR-MR-SG system, the combination of high pressure (15 bar) and high CO<sub>2</sub> concentration (53.1%) in the dehydrated retentate (#18) allows an extremely low energy penalty for CO<sub>2</sub> capture via cryogenic separation [91]. Cryogenic separation uses a series of simple, industry proven steps (i.e., refrigeration and distillation) to cool the gas mix until CO<sub>2</sub> liquifies, then separate CO<sub>2</sub> out by distillation. In addition to achieving a low energy penalty, cryogenic separation has been shown to achieve 99.9% CO<sub>2</sub> purity after separation with a 90% CO<sub>2</sub> capture efficiency [91].

A large difference between the SMR-MR-SG and the BSC is the concentration of CO<sub>2</sub> prior to capture: 53.1% in the SMR-MR-SG retentate versus 11.5% in the BSC exhaust. The penalty for CCC using a CSU increases exponentially with decreasing CO<sub>2</sub> concentration due to lowered phase transition temperature and increasingly expensive cold-tolerant equipment. Thus, cryogenic separation is not a reasonable choice for the BSC because of its low CO<sub>2</sub> concentration. Additionally, attempting cryogenic separation on low CO<sub>2</sub> concentration gas would result in high levels of impurities, preventing the CO<sub>2</sub> from being sold [91].

The most effective method of CO<sub>2</sub> separation from the BSC is a form of amine scrubbing: monoethanolamine absorption (MEA) [103]. MEA is a mature technology used for removing CO<sub>2</sub> from flue gas or other low temperature, low concentration sources via chemical absorption. It can capture 90% of CO<sub>2</sub> with 98% purity in the product, but at great cost: the energy penalty of MEA

for the BSC is  $3.9 \text{ MJ kg CO}_2^{-1}$ , 818% more than the cryogenic penalty of  $0.425 \text{ MJ kg CO}_2^{-1}$  in the SMR-MR-SG. The large difference in energy penalty is due to the disparity in  $\text{CO}_2$  concentration in the gas to be separated.

Both  $\text{CO}_2$  separation systems, CSU and MEA, add additional capital, O&M and operating cost in the form of electricity purchased from the grid. However, the most profound difference between the two is the large energy penalty of MEA. Technoeconomic modeling assumed that the entire energy penalty of CCC in each system was incurred in additional electricity usage.


### **3.4. Technoeconomic Comparison**

A technoeconomic model was developed to determine whether the proposed SMR-MR-SG system could compete economically with a state-of-the-art steam boiler, with and without  $\text{CO}_2$  capture. The technoeconomic model was also utilized to perform a sensitivity analysis, detailed in Section 4.3. Membrane reactor technology studies often include sensitivity analyses, but they are rarely tied to economics. This technoeconomic model, coupled with the thermodynamic model from the previous section, provides a useful tool for directing future research on a financially beneficial route.

#### **3.4.1. Baseline for Comparison**

The three systems were compared economically using a discounted cash flow model. Commodity costs were defined using historical data and forecasts. The electricity, NG, and water prices were set at the current industrial costs, with historical variations accounted for in the sensitivity analysis. This paper defines “purchase price” as the price a plant would pay to acquire the commodity and “sale price” as the amount of money a plant would receive for selling a commodity to another entity. All prices were considered at the industrial scale, as opposed to commercial or residential.

The purchase price of natural gas has fluctuated significantly in the last 20 years, as shown in Figure 3-4:



**Figure 3-4:** United States natural gas industrial price history [5].

The most recently published annual average natural gas price of \$4.10 per 1000scf was used in the technoeconomic analysis. The wide variance in price is accounted for in the sensitivity analysis, Section 4.3. The variation in NG composition and energy content was addressed by converting the price per 1000 standard cubic foot (scf) to a mass basis at standard conditions (60°F and 1 atm) using the conversion factor in Equation (3.107) [104]:

$$1000 \text{ scf}_{\text{NG}} = 19.68 \text{ kg}_{\text{NG}} \quad (3.107)$$

This conversion factor was calculated using the density of pure methane at the standard conditions. This is consistent with the thermodynamic model, which assumes natural gas is pure methane for all chemical and energy calculations.

Electricity was used in the SMR-MR-SG and BSC systems primarily for carbon dioxide separation and compression. The average industrial purchase price of electricity in the U.S. in 2017 was \$0.0688 per kWh [105]. The SMR-MR-SG and BSC systems also generate liquified CO<sub>2</sub> for export. The sale price of CO<sub>2</sub> was also set based on the current industry price, with predictions of a strong decrease in future price due to surplus from CO<sub>2</sub> capture technologies [106]. The implicit

assumption is that all captured CO<sub>2</sub> can be readily sold at the assumed market price of \$20 per ton. Alternatively, the CO<sub>2</sub> could be used directly for another in-house application instead of purchasing CO<sub>2</sub>, effectively reducing the operating cost by the same \$20 per ton.

Carbon tax is a financial cost imposed on a plant that produces CO<sub>2</sub> emissions, incentivizing reduced emissions. A mid-case prediction of carbon tax came in at an average of \$50.50 per ton of CO<sub>2</sub> between 2020 and 2050 [107]. This study assumed that, rather than the consumers of electricity being responsible for carbon emissions due to electricity generation, the electricity plant would pay the direct costs. The same was assumed for NG: the tax on carbon emissions due to the production and refinement of NG would be paid by the third party producers. This assumption is consistent with the thermodynamic models where each system pays a carbon tax only on the CO<sub>2</sub> emissions that it produces directly. The social cost implications will be discussed in the technoeconomic results, section 4.24.1.

Steam generation plants require a supply of water to generate steam. The cost of water was set at \$0.282 per m<sup>3</sup> ( $\$2.828 \times 10^{-3}$  per kg) [22]. It was assumed that process steam was a required commodity, and the system that can produce it with the least cost was most beneficial. Thus, no sale price of steam is considered, and the three systems are compared based on relative cost of steam production.

The annual discount rate and lifespan were chosen based on a similar technoeconomic analysis of MRs by Sjardin et al. [22]. A 20-year lifespan is reasonable for industrial boilers, but not for MRs. A typical MR has a life span of 1.3 - 4.7 years [22], but the O&M cost for the SMR-MR-SG includes the cost of replacing the MR every three years as well as regular maintenance on the rest of the system [22]. The load factor determines how many hours per year each system operates. The International Energy Agency suggests a load factor of 90.5% [69].

### 3.4.2. Cash Flow Analysis

The economic comparison used a discounted cash flow analysis. Operating expenses and income due to sale or purchase of commodities were calculated for each system. The price of natural gas was converted from standard cubic feet to kilograms based on the conversion of Equation (3.107), rearranged into Equation (3.108):

$$\text{Price}_{\text{NG}} = \left(4.10 \text{ \$ } 1000 \text{ scf}^{-1}\right) \left(\frac{1000 \text{ scf}}{19.68 \text{ kg}}\right) \quad (3.108)$$

The cost associated with consumption of natural gas, water, and electricity, as well as taxed exhaust of carbon dioxide were calculated for each system as applicable. The value of each cost or revenue is just a positive magnitude here for simplification; the proper signs will be applied in the net income calculations below. Equations (3.109) through (3.112) show the operating cost and revenue calculations that were applied to each system:

$$\text{Rev}_{\text{CO}_2 \text{ sale}} = (\dot{m}_{\text{cCO}_2})(t_{\text{operating}})(\text{Price}_{\text{cCO}_2}) \quad (3.109)$$

$$\text{OpEx}_{\text{NG}} = (\dot{m}_{\text{NG}})(t_{\text{operating}})(\text{Price}_{\text{NG}}) \quad (3.110)$$

$$\text{OpEx}_{\text{water}} = (\dot{m}_{\text{water}})(t_{\text{operating}})(\text{Price}_{\text{water}}) \quad (3.111)$$

$$\text{OpEx}_{\text{elec}} = (\dot{W}_{\text{elec}})(t_{\text{operating}})(\text{Price}_{\text{elec}}) \quad (3.112)$$

$$\text{OpEx}_{\text{CO}_2, \text{tax}} = (\dot{m}_{\text{CO}_2, \text{exh}})(t_{\text{operating}})(\text{Price}_{\text{CarbonTax}}) \quad (3.113)$$

Next, the total operating cost for each system was calculated in \$ yr<sup>-1</sup> using Equations (3.115) and (3.114):

$$\text{OpEx}_{\text{SMR, total}} = O \& M_{\text{SMR, system}} + \text{OpEx}_{\text{SMR, NG}} + \text{OpEx}_{\text{SMR, water}} + \text{OpEx}_{\text{SMR, elec}} \quad (3.114)$$

$$\text{OpEx}_{\text{BS, total}} = O \& M_{\text{BS, system}} + \text{OpEx}_{\text{BS, NG}} + \text{OpEx}_{\text{BS, CO}_2 \text{ tax}} + \text{OpEx}_{\text{BS, water}} \quad (3.115)$$

$$\text{OpEx}_{\text{BSC, total}} = O \& M_{\text{BSC, system}} + \text{OpEx}_{\text{BSC, NG}} + \text{OpEx}_{\text{BSC, CO}_2 \text{ tax}} + \text{OpEx}_{\text{BSC, water}} \quad (3.116)$$

The net income per year is given by revenues minus expenses, calculated in Equations (3.117) through (3.119):

$$Income_{SMR,net} = Rev_{SMR,CO_2\ sale} - OpEx_{SMR,total} \quad (3.117)$$

$$Income_{BS,net} = -OpEx_{BS,total} \quad (3.118)$$

$$Income_{BSC,net} = Rev_{BSC,CO_2\ sale} - OpEx_{BSC,total} \quad (3.119)$$

With all variations of input parameters, the SMR system had the highest capital cost but the lowest operating costs due to its high efficiency. Therefore, the metrics used to quantify the desirability of the SMR-MR-SG system relative to the other systems were the payback period, net present value (NPV), and discounted cost reduction (DCR). The payback period is defined as the time in years when the SMR-MR-SG surpasses the other systems in value. For a lifetime longer than the payback period, the SMR-MR-SG system is more desirable. The NPV represents the lifetime cost of each system, accounting for the time value of money. The DCR is the difference in NPV of the SMR-MR-SG versus each of the other two systems, normalized by original (higher) cost.

In the discounted cash flow analysis, the future value (FV) of each system was calculated each year as the sum of revenues minus expenses. In year 0, the capital expense was the only transaction, given in Equations (3.120):

$$FV_0 = CapEx_{total} \quad (3.120)$$

The future value for each subsequent year was equal to the net income, shown in Equations (3.121)

:

$$FV_n = Income_{net} \quad (3.121)$$

The equation used for present value at each year is given by Equation (3.122):

$$PV_n = \frac{FV_n}{(1 + dr)^n} \quad (3.122)$$

where  $n$  is the year number and the discount rate ( $dr$ ) was assumed to be 12% based on a similar technoeconomic study by Sjardin et al. [22]. The NPV was calculated as the sum of present values of each year, as in Equation (3.123):

$$NPV = \sum_{n=0}^{lifespan} PV_n \quad (3.123)$$

DCR relative to the BS is defined as the percent reduction in NPV, given in Equation (3.124):

$$DCR_{BS} = \frac{NPV_{BS} - NPV_{DCR}}{NPV_{BS}} \quad (3.124)$$

The DCR relative to the BSC is defined similarly. DCR is a key parameter: it shows the economic benefit of the SMR-MR-SG, normalized by discounted lifetime cost of the BS or BSC. The results of the technoeconomic are presented in section 4.2. The following chapter will explain results of the coupled models and discuss the implications.

## CHAPTER 4. Results and Discussion

The coupled thermodynamic and technoeconomic model described in Chapter 3 fully defined the SMR-MR-SG process flow cycle shown in Figure 3-1. Most academic studies of membrane reformer and steam methane reforming technology focuses on a small aspect of the thermodynamic performance. This work performed a system level analysis with an emphasis on economic feasibility. This chapter will discuss the thermodynamic results first, highlighting the performance of the SMR-MR-SG system, the relative energy use of each of the three SG systems, and possible variations on the SMR-MR-SG cycle. The technoeconomic results follow, with a comparison of the three systems' lifetime costs. Finally, a sensitivity analysis discusses the key assumptions and parameters that have large effects on the model.

### 4.1. Thermodynamic Results

#### 4.1.1. Process States and Energy Balances

The full list of state points corresponding to the process flow diagram of Figure 3-1 is shown in Table 4-1. The state points were significantly influenced by the temperature and pressure of the export steam. This is a development in SMR and MR technology: traditional systems optimize reforming and H<sub>2</sub> separation, while this study focused on the steam generation process and worked in a SMR-MR system around those constraints.

**Table 4-1:** Thermodynamic state points for SMR steam generation system.

State No.	T °C	P bar	$\dot{H}$ kW	$\dot{n}_{total}$ mol s <sup>-1</sup>	$y_{H_2}$ -	$y_{CH_4}$ -	$y_{H_2O}$ -	$y_{CO_2}$ -	$y_{N_2}$ -	$y_{O_2}$ -
1	15	15	-75.8	1.01	0	1	0	0	0	0
2	15	15	-153.6	2.11	0.212	0.735	0	0.053	0	0
3	200	15	-138.8	2.11	0.212	0.735	0	0.053	0	0
4	15	1	-451.7	1.62	0	0	1	0	0	0
5	15	1	-6798.5	24.37	0	0	1	0	0	0
6	15	15	-6798	24.37	0	0	1	0	0	0
7	198.3	15 (X=0.369)	-6278.4	24.37	0	0	1	0	0	0
8	200	15	-5615.4	24.37	0	0	1	0	0	0
9	200	15	-4186.9	18.17	0	0	1	0	0	0
10	200	15	-1071.4	4.65	0	0	1	0	0	0
11	200	2	-355.5	1.55	0	0	1	0	0	0
12	400	2	-344.1	1.55	0	0	1	0	0	0
13	200	15	-1208.2	6.76	0.066	0.229	0.688	0.017	0	0
14	400	15	-1152.6	6.76	0.066	0.229	0.688	0.017	0	0
15	400	15	-918.3	8.77	0.51	0.062	0.3	0.128	0	0
16	400	15	-1026.6	4.74	0.094	0.114	0.555	0.236	0	0
17	20	15	-1208.3	4.74	0.094	0.114	0.555	0.236	0	0
18	15	15	-475	2.11	0.212	0.257	0	0.531	0	0
19	-51.14	7.959	-414.8	1.01	0	0	0	1	0	0
20	15	75	-408.5	1.01	0	0	0	1	0	0
21	15	15	-77.8	1.1	0.406	0.492	0	0.102	0	0
22	400	2	-236	5.58	0.722	0	0.278	0	0	0
23	15	1	261.7	9.59	0	0	0	0	0.79	0.21
24	912.6	2	-637.4	13.16	0	0	0.424	0	0.576	0
25	429.9	2	-871.4	13.16	0	0	0.424	0	0.576	0
26	405	2	-882.8	13.16	0	0	0.424	0	0.576	0
27	281.4	2	-938.4	13.16	0	0	0.424	0	0.576	0
28	247.8	2	-953.3	13.16	0	0	0.424	0	0.576	0
29	20	2	-1291.1	13.16	0	0	0.424	0	0.576	0
30	15	1	262.2	7.58	0	0	0	0	1	0
31	15	1	-1556.5	5.58	0	0	1	0	0	0
32	15	1	-735	2.63	0	0	1	0	0	0
33	15	1	-4055.2	14.53	0	0	1	0	0	0

After adjusting temperatures to avoid pinch points by a margin of the CAT, the temperature changes in each heat exchanger are shown in Figure 4-1.



#### 4.1.2. Comparison of Energy Consumption

Key results of the thermodynamic analysis are shown in Table 4-2.

**Table 4-2:** Relative thermodynamic comparison of SMR-MR-SG and boiler systems.

Parameter	Units	BS System			BSC System	
		SMR-MR-SG System	Result	SMR-MR-SG Improvement	Result	SMR-MR-SG Improvement
Equivalent boiler efficiency	%	97.0	86	12.8%	72.4	34.0%
Water Use	ton yr <sup>-1</sup>	1,014	2,276	55.4%	809	-25.3%
Energy Use	kW	910	1,026	11.3%	1,218	25.2%
Natural Gas Use	ton yr <sup>-1</sup>	883	1,026	13.9%	1,026	13.9%
Electricity Use	kW	27	0	-	192	85.9%
CO <sub>2</sub> Emissions	ton yr <sup>-1</sup>	0	1,791	-	179	-
cCO <sub>2</sub> Sale	ton yr <sup>-1</sup>	1,541	0	-	1,612	-0.4%


The improvement of the SMR-MR-SG over the BS for each parameter was calculated as the change in value divided by the baseline (BS or BSC), shown in Equation (4.1):

$$\text{Improvement} = \frac{Val_{\text{SMR}} - Val_{\text{BS}}}{Val_{\text{BS}}} \quad (4.1)$$

The appropriate sign was applied to the numerator of Equation (4.1) depending on the value in question. The improvement relative to the BSC was calculated similarly. Equivalent boiler efficiency refers to the system-level definition of output energy (export steam) divided by input energy. The SMR-MR-SG shows large improvements over both the BS and BSC in efficiency (12.8% and 34.0% improvement) and thus total energy use (11.3% and 25.2%), respectively. Water use is improved by 55.4% over the BS, but the SMR-MR-SG uses 25.3% more water than the BSC. This is because the BSC has the water-recycling benefits of CCC (i.e., the exhaust is completely dehydrated before CO<sub>2</sub> separation), plus there is no need for excess steam for reforming. The SMR-MR-SG is the only system to achieve zero CO<sub>2</sub> emissions. This is made

possible not by perfect CO<sub>2</sub> capture technology, but by recycling un-captured CO<sub>2</sub> back through the MR feed.

The flow of energy through the SMR-MR-SG system is shown in Figure 4-2.



**Figure 4-2:** Energy flows for SMR-MR-SG system.

The thickness of each line indicates relative amounts of energy flow. The energy in each stream is calculated as a difference in flow enthalpy, where flow enthalpy is the sum of sensible and formation enthalpy, weighted by flow rate as in Equation (4.2):

$$\dot{H}_{\text{fluid}} = \dot{n}_{\text{total}} \cdot y_{\text{fluid}} \cdot (h_{\text{sens,fluid}} + h_{\text{f,fluid}}^{\circ}) \quad (4.2)$$

For example, the 882 kW in the Steam Export is calculated as  $\dot{H}_9 - \dot{H}_{9,\text{amb}}$  where the subscript *amb* refers to the 15°C and 1 bar of the water tank (#5). This difference in flow enthalpy method captures the total energy, chemical and sensible, added to each stream throughout the system. The 6.1 kW in the Water and Air Supply is necessary because a non-trivial amount of energy is

extracted from water during reforming (Equation (3.24)) and from air during H<sub>2</sub> combustion, in the form of increased mass flow rate. The 615 kW of Recycled Heat is calculated as the sum of the heat duty of recuperative heat exchangers (HE 1 through 5), which is also calculated from differences in flow enthalpy. A large amount of the Steam Generation (25.4%) is diverted to recycled heat: this is the reaction and sweep steam used in the MR.

The NG supply and steam export lines are nearly the same size, indicating that over 99% of available energy from NG is used for the end goal: generating steam. The equivalent boiler efficiency of the SMR-MR-SG system (97.0%) is the steam export (882 kW) divided by the sum of the input energy (i.e., NG supply (883 kW) plus electricity (26.9 kW) equals 910 kW). Another way to visualize the high efficiency of the SMR-MR-SG system is by comparing the large amount of utilized energy (steam export at 882 kW) versus small amount of consumed energy (waste heat at 8.8 kW and CO<sub>2</sub> capture at 24.0 kW).

For comparison, the energy flow of the BSC is shown in Figure 4-3.




Figure 4-3: Energy flows for boiler system with CO<sub>2</sub> capture (BSC).

Both energy flow figures use the same steam export energy (882 kW) to allow for a direct comparison. The water and air supply term is not included in the BSC energy flow because there is no reforming reaction. The input energy in the BSC (NG and electricity at 1,026 + 192 = 1,218 kW) is 33% higher than the SMR-MR-SG. Again, efficiency is calculated as steam export (882 kW) divided by input energy (1,218 kW), which results in a 72.4% efficiency for the BSC system. This is simply the BS efficiency of 86%, reduced by the CCC energy penalty.

The large difference in efficiency between the SMR-MR-SG and BSC is due to more effective heat recovery and lower CCC energy penalty in the SMR-MR-SG. Heat recovery could be improved in the BSC; this will be addressed below in the techno-economic subsection. The CCC energy penalty is defined by Equation (4.3):

$$P_{CCC} = \frac{\dot{E}_{out,w/CCC} - \dot{E}_{out,w/o CCC}}{\dot{E}_{out,w/o CCC}} \quad (4.3)$$

The CCC energy penalty indicates the reduction in net output power of the plant due to CCC, normalized by the original output power. The SMR-MR-SG and BSC have CCC energy penalties of 3.0% and 16.4%, respectively. This is a key point: the high CO<sub>2</sub> concentration in the SMR-MR-SG retentate (#18) allows the use of CSU, whereas the BSC system requires MEA for CO<sub>2</sub> capture due to low CO<sub>2</sub> concentration in the exhaust. Cryogenic separation is simple and efficient, with most of the energy penalty incurred running a refrigeration cycle. On the other hand, MEA is more complex, requiring electricity for solvent regeneration (accounting for 55% of MEA energy consumption), CO<sub>2</sub> compression, process pumping, and blowers [83]. These factors add up to make the CCC energy penalty via MEA over 9 times more than via CSU.

Table 4-3 shows a comparison of state-of-the-art technologies that use a fossil fuel source and capture CO<sub>2</sub> to put these energy penalties into context.

**Table 4-3:** Comparison of CO<sub>2</sub> capture and concentration energy penalties.

System	Fuel	Method of CO <sub>2</sub> Capture	Energy Output Type	CO <sub>2</sub> Capture Energy Penalty
SMR-MR-SG ( <b>This Work</b> )	NG	Cryogenic Separation	Steam	3.0%
Boiler w/ CO <sub>2</sub> Capture (BSC, <b>This Work</b> )	NG	Amine Absorber	Steam	16.4%
Membrane Reformer <sup>a</sup>	NG	Cryogenic Separation	Hydrogen	5.4%
Combined heat and power plant <sup>b</sup>	NG	Ionic Liquid	Steam and Electricity	8.0%
Steam boiler <sup>c</sup>	NG	Adsorption	Steam	14.4%
Conventional SMR <sup>d</sup>	NG	Pressure-Swing Adsorption	Hydrogen	18.9%
Natural Gas Combined Cycle <sup>e</sup>	NG	Amine Absorber	Electricity	14.7%
Integrated gasification combined cycle <sup>e</sup>	Coal / Syngas	Selexol 2 <sup>nd</sup> Stage	Electricity	21.4%
Pulverized Coal (supercritical) <sup>e</sup>	Coal	Amine Absorber	Electricity	27.6%
Pulverized Coal (subcritical) <sup>e</sup>	Coal	Amine Absorber	Electricity	28.9%

<sup>a</sup> Kurokawa *et al.* [47]

<sup>b</sup> N. China Elec. Power Univ. [108]

<sup>c</sup> Saeys *et al.* [109]

<sup>d</sup> Petrakopoulou [110]

<sup>e</sup> NETL [111]

All the technologies listed in Table 4-3 capture approximately 90% of the CO<sub>2</sub> produced by the plant and concentrate it to a level suitable for storage or direct use. Separation of CO<sub>2</sub> occurs post-combustion or -reforming in all cases, as that has been shown to be more efficient than before or during combustion [109]. The energy penalty for the natural gas boiler was calculated using a figure of 568 kWh per ton CO<sub>2</sub> [109]. Assuming pure methane as fuel and an 86% boiler efficiency, the amount of NG burned to generate a ton of CO<sub>2</sub> can be found using the combustion reaction of CH<sub>4</sub>. Then, the energy output can be calculated from the lower heating value and used to calculate the energy penalty. In conventional SMR, pressure-swing adsorption is the only realistic, commercially available option for CCC [112].

Several coal fired plants were considered to show that the CCC energy penalty is significantly worse than in natural gas fired plants. As an interesting aside, the addition of CCC almost doubles water usage in coal and NG power plants [111], while the SMR-MR-SG reduces water consumption relative to the baseline boiler system by 55.5%.

The system with the energy penalty closest to the SMR-MR-SG system is a membrane reformer with cryogenic separation of CO<sub>2</sub> developed by Kurokawa et al [47]. The authors report a 3% energy penalty resulting in over 90% CO<sub>2</sub> capture in reactor off-gas, but only a 50% reduction in total CO<sub>2</sub> emissions. The penalty of 5.4% was extrapolated by setting total CO<sub>2</sub> emissions to 90%. The SMR-MR-SG achieves a much lower energy penalty than Kurokawa's system by recycling un-captured CO<sub>2</sub> via stream (#21). After water is removed from the retentate (#18), the majority of the remaining gas is CO<sub>2</sub>. Rather than focus on maximizing CO<sub>2</sub> separation with diminishing returns of capture efficiency versus cost, only ~90% of CO<sub>2</sub> is captured via the CSU, and the rest (#21) is mixed with the natural gas supply (#1). Diluting the feed with CO<sub>2</sub> reduces methane conversion and hydrogen capture, but the effect is minimal at 90% CO<sub>2</sub> capture. With CO<sub>2</sub> recycling, the SMR-MR-SG system has 100% effective CO<sub>2</sub> capture because the CO<sub>2</sub> is recycled until it is captured.

One major difference between the SMR-MR-SG and most other systems in Table 4-3 is that the SMR-MR-SG produces heat for steam, while others produce electricity or hydrogen. In these cases, heat is an intermediate product and the additional energy conversion from heat to energy output is a source of energy loss that is avoided in the SMR-MR-SG. This is an important point to consider when developing energy systems that utilize NG: co-location of end use and NG consumption could be critical in providing economic benefit for systems that capture carbon.

The safety and practicality of a H<sub>2</sub>-fueled boiler in the SMR-MR-SG is a topic that needs to be addressed because H<sub>2</sub> boilers are uncommon in industry. In general, H<sub>2</sub> combustion is very fast and produces higher temperatures than other fuel combustion. This is somewhat mitigated by dilution of H<sub>2</sub> by the sweep steam: the fuel entering the boiler is 72% H<sub>2</sub> and 28% H<sub>2</sub>O. The amount of sweep steam could easily be increased to further dilute the H<sub>2</sub> without significantly harming system performance. One study of a boiler used in a cogeneration plant showed stable, safe combustion with up to 51% H<sub>2</sub> [113].

## 4.2. Technoeconomic Results

The key results of the technoeconomic analysis for each of the three systems are shown in Table 4-4. The capital cost of the SMR-MR-SG system is 2.7 and 1.7 times greater than the BS and BSC systems, respectively. This is quickly made up for by a large difference in commodity expenses: the SMR-MR-SG's expenses are 45% and 66% less than the BS and BSC systems, respectively.

**Table 4-4:** Key results of technoeconomic analysis.

Parameter	Units	Boiler System (BS)	Boiler System w/ CO <sub>2</sub> Capt. (BSC)	SMR-MR-SG
Capital Cost	k\$	122.5	193.1	335.6
O&M Cost	k\$ yr <sup>-1</sup>	26.4	31.6	14.8
Commodity Expenses (w/ carbon tax)	k\$ yr <sup>-1</sup>	206.4	330.3	112.7
Income from cCO <sub>2</sub>	k\$ yr <sup>-1</sup>	0	29.2	27.9
Net present value	k\$	-1,861	-1,907	-1,079
<i>Relative Values</i>				
Payback period (SMR vs. X)	yr	1.89	1.26	--
Discounted Cost Reduction (SMR vs. X)	--	42.0%	43.4%	--


The net benefit of the SMR-MR-SG over its lifetime is shown by its larger (i.e., less negative) *NPV*. It is assumed that steam generation is necessary for an industrial process (e.g., distributed heating), and that the most beneficial system is the one with the least cost. Short

payback periods versus both boiler systems show that an investment in SMR-MR-SG instead of a boiler would yield financial benefit in under 2 years.

The capital cost of the CSU in the SMR-MR-SG system was very high relative to other components, making up 59.9% of the total system capital cost. To ensure that this estimate was reasonable, another source was used to verify the calculation of the CSU CapEx. Xu et al. reported a total cryogenic system cost of \$29.872M at a scale of 76.18 kg s<sup>-1</sup> captured CO<sub>2</sub>, with a scale factor of 0.67 [91]. The calculated cost using Xu's method differed from the calculation in this study by only 0.8%.

The capital expense of the SMR-MR-SG could be reduced by pursuing less expensive CSU development. Alternatively, higher values of methane conversion and hydrogen permeation would create a higher concentration of CO<sub>2</sub> in the retentate. For example, setting both parameters to 95% would increase the CO<sub>2</sub> concentration in the dehydrated retentate (stream #18) to 81%. Depending on the application that the captured CO<sub>2</sub> is intended for, very high values of methane conversion and hydrogen permeation might produce a CO<sub>2</sub> concentration high enough that it does not require separation, eliminating the CSU. Future investigations will explore this possibility.

The cost breakdown of each system is shown in Figure 4-4.




**Figure 4-4:** Discounted lifetime cost comparison between boiler and SMR-MR-SG systems. All costs are discounted over the 20-year lifespan – i.e., the numbers indicated are the *NPV* for each expense. The *NPV* of each system is indicated by the dashed lines. Note that carbon tax increases cost significantly in the BS and slightly in the BSC, while the sale of cCO<sub>2</sub> decreases cost in the BSC and SMR-MR-SG systems. While the carbon tax helps the economic case of the SMR-MR-SG system significantly, it is not necessary for it to generate revenue during the lifetime of a representative BS system. Assuming no carbon tax is implemented, the dark grey bars disappear from Figure 4-4, reducing the BS lifetime cost by 36%, but leaving it more expensive than the SMR-MR-SG. Eliminating the carbon tax changes payback period versus the BS system from 1.89 to 8.05 years.

An interesting effect of carbon capture is that it reduces the lifetime cost of the SMR-MR-SG system. This is the result of a two-fold effect of CO<sub>2</sub> capture: without it, there is a large cost increase due to carbon tax, plus the lost revenue from sale of cCO<sub>2</sub>. This is partially offset by avoiding the capital cost of the CSU, but the difference in operating costs far outweighs the capital cost. This is not true for most other systems (i.e., BSC system), because the energy and economic penalties are much higher.

The efficiency of the boiler systems could be improved beyond 86% by adding additional heat exchangers and more complicated system flow paths to capture low temperature heat. A hypothetical BSC with higher efficiency (BSC-H) could have a 97% efficiency to match the SMR-MR-SG with an optimistic increase in capital cost of only 10% [66,68]. The effect on the BSC column of Figure 4-4 would be that the light blue, capital expense, would increase by \$19k while the green, fuel cost, would decrease by \$116k. The BSC-H discounted lifetime cost would be reduced to \$1,810k, still 68% more expensive than the SMR-MR-SG. The MEA energy and economic penalties for CO<sub>2</sub> capture in the BSC are very high and increases in boiler efficiency only slightly offsets the cost of CCC. The same hypothetical, high-efficiency scenario was analyzed for the BS system (BS-H) with a similar result: the discounted lifetime cost of the BS-H is \$1,757k, which is a significant improvement, but not enough to make the BS-H more beneficial than the SMR-MR-SG (\$1,079k).

A discounted cash flow diagram is presented in Figure 4-5.



**Figure 4-5:** Cash flow diagram comparing SMR-MR-SG to baseline steam generation systems.

The payback period of the SMR-MR-SG versus the boiler systems are defined as the intersection of the corresponding lines: 1.26 and 1.89 years for the BSC and BS, respectively. Analyzing the hypothetical higher efficiency boiler systems from above resulted in payback period of 1.23 and 2.02 for the BSC-H and BS-H, respectively. The high capital expense of the SMR-MR-SG is shown by its low starting point at year 0. The flatter slope of the SMR-MR-SG indicates its reduced operating costs. A payback period of less than 2 years relative to both boiler systems is encouraging as it presents a reduced financial risk.

Although the SMR-MR-SG system presents a strong economic benefit over the two boiler systems, there are possible scenarios where it is less economically desirable. For example, if CO<sub>2</sub> cannot be sold (i.e., has a sale price of \$0) and no carbon tax is implemented, the BS has a slightly lesser cost than the SMR-MR-SG. An example of the BSC being less expensive than the SMR-MR-SG is more difficult to imagine: in one possible scenario, electricity price is extremely low at

\$0.04 per kWh, the sale price of CO<sub>2</sub> triples to \$60 per ton, carbon tax is not implemented, and the load factor drops to 80%. In this case, the BSC is about 5% less expensive than the SMR-MR-SG over a 20 year lifespan. These worst-case scenarios are possible, but extremely unlikely. In section 4.3.2, a Monte Carlo analysis will be presented to simulate thousands of possible conditions and generate confidence levels for the stated economic benefit of the SMR-MR-SG.

There are significant CO<sub>2</sub> emissions associated with the production of NG and electricity, as well as with the combustion of NG. The direct costs of emissions due to carbon tax have been addressed in section 3.4.1. There is also an indirect cost of CO<sub>2</sub> emissions, quantified by the social cost of carbon, which represents the economic cost to society as a whole per unit of CO<sub>2</sub> emissions [114]. Conservative estimates put the social cost of carbon at \$52 per ton of CO<sub>2</sub> by the year 2030 [114], corresponding to an 11% increase in effective operating costs for the BS.

In addition to operational CO<sub>2</sub> emissions, there are emissions associated with production of components and construction of industrial plants. The percentage of lifecycle CO<sub>2</sub> emissions coming from component production and plant construction can be as high as 1.5% [115], with most of the remaining 98.5% due to operational CO<sub>2</sub> emissions. This is significant, but due to the similarity of the three steam generation systems in this study, the CO<sub>2</sub> emissions from component production and plant construction were not included in the model.

### **4.3. Sensitivity Analysis**

#### **4.3.1. Basic Analysis**

A basic sensitivity analysis was performed by adjusting one model parameter at a time and noting the results on the payback period relative to the BS and BSC. The parameters and ranges of variation are shown in Table 4-5 and are applied to every system when applicable – i.e., the membrane thickness doesn't change the BS. The ranges in commodity prices were based on


historical and locational variation. CO<sub>2</sub> sale price and carbon tax were varied using conservative and aggressive predictions [106,107]. Economic parameters including discount rate, lifespan, and load factor were modeled after a similar technoeconomic sensitivity analysis [22].

**Table 4-5:** Input parameters varied and range of variation for sensitivity analysis.

Parameter	Units	Low Value	Base Value	High Value
Natural gas purchase price	\$ 1000scf <sup>1</sup>	2	4.1	10
Electricity purchase price	\$ kWh <sup>-1</sup>	0.04	0.0688	0.17
Water purchase price	\$ m <sup>-3</sup>	0.141	0.282	0.564
CO <sub>2</sub> sale price	\$ ton <sup>-1</sup>	0	20	50
Carbon tax	\$ ton <sup>-1</sup>	0	50.5	100
Discount rate	-	0.06	0.12	0.18
Lifespan	yr	15	20	25
Load factor	%	80	90.5	95
Reforming temperature	C	300	400	600
Methane conversion	--	0.45	0.65	0.85
Hydrogen capture	--	0.8	0.9	0.99
Reforming pressure, feed	bar	10	15	20
Reforming pressure, permeate	bar	1.5	2	2.5
SC, reaction	--	2	3	4
SC, sweep	--	0.5	1	2
Membrane thickness	μm	1	2.8	10
Membrane permeance	mol m <sup>-2</sup> s <sup>-1</sup> Pa <sup>-0.5</sup>	3.24x10 <sup>-3</sup>	6.48x10 <sup>-3</sup>	1.30x10 <sup>-2</sup>
Membrane reactor capital cost	\$ m <sup>-1</sup>	538	1,076	2152
Operating and Maintenance Cost	% of CapEx	2.5	5	10
Cryo CapEx	\$ h ton <sup>-1</sup>	582	873	1309


There is a wide range of MR parameters in literature that set the ranges for reforming temperature, methane conversion, hydrogen capture, reforming pressures, and SC ratios. Similarly, membrane production technology is evolving quickly, allowing membrane thickness, permeance, capital cost, and O&M cost to be estimated for best- and worst-case scenarios. Finally, the capital cost of CSU is both a function of the technology cost and the efficiency of the MR to produce a high concentration of CO<sub>2</sub>.

The results of the sensitivity analysis relative to the BS and BSC are reported in




(b)

Figure 4-6. Note that the scale in payback period is very different for the BS and BSC figures: the SMR MR-SG system pays back very quickly when compared to the BSC system.



(a)



(b)

**Figure 4-6:** Results of sensitivity analysis for SMR-MR-SG system compared to BS (a) and BSC (b).

The largest effect was that of the carbon tax on the SMR-MR-SG versus BS payback period: 326% increase with no carbon tax or 43% decrease with doubled carbon tax. Referring to Figure 4-4, eliminating the carbon tax would eliminate the dark grey bar on the BS, leaving only a small difference in lifetime cost between the BS and the SMR-MR-SG. However, the SMR-MR-SG still shows a lower cost with no carbon tax.

For both boiler systems, the CSU capital cost had a significant impact simply because it accounted for a large portion of the SMR-MR-SG capital cost. A reduction in CSU capital cost by a factor of 1.5 resulted in payback period decrease of 35% and 49% for the BS and BSC, respectively. Eliminating the sale of CO<sub>2</sub> had a significant effect on the BS payback period (32% increase), but not the BSC (2% increase). This is because a very similar amount of CO<sub>2</sub> production in the SMR-MR-SG and BSC systems meant that a change in CO<sub>2</sub> sale price changed the lifetime cost of both systems in roughly equally fashions.

Electricity cost has a significant impact on the relative merits of the BSC system: increasing electricity price to \$0.17 per kWh (147% increase) resulted in a 52% decrease in payback period. This is due to the high electricity demand of the MEA system use for CCC. The relative size of the energy cost can be seen easily by the large yellow bar in the BSC column of Figure 4-4. On the other hand, electricity price was one of the most widely varied parameters due to a large variation in local electricity price throughout the U.S.

The thermodynamic reforming properties have relatively small influence over the system's economic performance. Part of this may be due to the recycling aspect of the system. For example, better methane conversion is not critical to improving efficiency, as the "leftover" is just recycled rather than wasted. Also, the true impact of the thermodynamic parameters may have been lost: a high-fidelity sensitivity analysis would adjust one parameter and then completely redesign the system to support that change. For example, if the reforming temperature could be set to 250°C and the export steam adjusted to 250°C, at least two heat exchangers could be eliminated from the system, reducing complexity. However, this could make it more difficult to capture low temperature waste heat because smaller temperature differences would reduce heat exchanger efficiency. The thermodynamic parameters in the model affect one another enough that it is not trivial to predict response to a parameter change, and future studies will address this challenge.

#### **4.3.2. Monte Carlo Simulation**

A Monte Carlo simulation was performed to validate the basic sensitivity analysis, investigate the effects of varying multiple parameters simultaneously, and provide additional information on the probability distribution of different outcomes. The simulation was performed in Microsoft Excel, using ModelRisk add-in software, version 6.1.3 [116]. The Monte Carlo simulation varied input variables using a PERT probability distribution based on the most likely,


minimum, and maximum values of each parameter. The ranges used for each variable are shown in Table 4-6. Only economic parameters were varied, as the complexity of the thermodynamic model prevented straightforward variation. Furthermore, the basic sensitivity analysis showed a low sensitivity to thermodynamic parameters.

**Table 4-6:** Input parameters varied and PERT probability distribution parameters used in Monte Carlo simulation.


<b>Parameter</b>	<b>Units</b>	<b>Most Likely Value</b>	<b>Low</b>	<b>High</b>
Natural Gas Price	\$ / 1000scf	\$4.10	\$2.00	\$10.00
Electricity Price	\$ / kWh	\$0.0688	\$0.0400	\$0.1700
Water Price	\$ / kg	\$0.002282	\$0.001141	\$0.004564
CO2 Sale Price	\$ / ton	\$20.00	\$0.00	\$50.00
Carbon Tax	\$ / ton	\$50.50	\$0.00	\$100.00
Discount Rate	-	0.12	0.06	0.18
Load Factor	-	0.905	0.800	0.950
Cryo CapEx	\$	\$201,230	\$160,984	\$251,538
Membrane Reactor CapEx	\$	\$51,376	\$41,101	\$64,220
SMR O&M Cost	% of CapEx	5	2.5	7.5

The Monte Carlo simulation was run with 10,000 points to evaluate payback period of the SMR-MR-SG versus the BS and BSC. Tornado charts (Figure 4-7) are used to show the range of payback periods within a confidence interval of 95%, sorted by most impactful input parameter.

The trends shown in the Monte Carlo simulation generally agree with the basic analysis, but ranges differ. For example, for the SMR-MR-SG versus the BS, the carbon tax is the single most influential input according to both analyses, but the Monte Carlo simulation predicts a range of 1.42 to 4.29 years, greatly reduced from the range of 1.08 to 8.05 years predicted by the basic analysis. This is likely due to the PERT probability distribution: it's more likely that carbon tax is implemented at about its predicted value, rather than not at all or much higher than predicted.



(a)




(b)


**Figure 4-7:** Tornado chart showing Monte Carlo simulation of payback period of the SMR-MR-SG vs. BS (a) and vs. BSC (b).

Considering the SMR-MR-SG versus the BSC, electricity price was still the largest driver, followed by the cryogenic unit capital cost. The tornado charts generated by the Monte Carlo simulation validate the trends of the basic sensitivity analysis and provide more accurate ranges of payback periods.

Another useful figure generated by the Monte Carlo simulation was a histogram of payback period for the SMR-MR-SG versus the two boiler systems. In particular, Figure 4-8 shows the probability distribution of each payback period, with a 95% confidence interval shown.



(a)



(b)

**Figure 4-8:** Histogram showing Monte Carlo simulation of payback period of the SMR-MR-SG vs. BS (a) and vs. BSC (b).

Based on these histograms, a concise summary of the sensitivity analysis can be formed: accounting for the variability and probability distribution of input parameters, the SMR-MR-SG system shows a payback period of  $2.74 \pm 1.42$  yr versus the BS and  $1.26 \pm 0.51$  yr versus the BSC with 95% confidence. It is also worth noting that, in all 10,000 repetitions of the Monte Carlo simulation, the SMR-MR-SG had a finite payback period, i.e., it was the least expensive option

every time. This chapter has presented and discussed the results of modeling and the sensitivity analysis. The following chapter will summarize the conclusions of this study and provide guidelines for future work.

## CHAPTER 5. **Conclusions and Recommendations for Further Work**

The current study investigated a steam generation system using steam methane reforming in a membrane reactor (SMR-MR-SG). A techno-economic model was developed using an enthalpy-based energy balance method with a discounted cash flow analysis. The SMR-MR-SG was compared to a high efficiency NG boiler system, with (BSC) and without CO<sub>2</sub> capture (BS), and evaluated as an alternative technology for steam generation.

Modeling results show an increase of boiler efficiency from 86% to 97.0% is possible for the SMR-MR-SG system, with a reduction of water and NG use of 55% and 14% relative to the BS system, respectively. The combination of gas recycling and a cryogenic separation unit (CSU) effectively reduced CO<sub>2</sub> emissions to zero with a 3.0% energy penalty, substantially lower than other representative systems with carbon capture.

The economic benefit of the SMR-MR-SG is derived largely from CO<sub>2</sub> capture and concentration. This eliminates the cost of carbon tax on emissions while also raising revenue from sale of CO<sub>2</sub>. Additionally, the co-location of products (CO<sub>2</sub> and steam) with the SMR-MR-SG plant effectively eliminates export costs relative to other plants with carbon capture, yielding significant economic advantage.

The capital cost of the new system is ~3 times higher than the conventional boiler without CO<sub>2</sub> capture, but the payback period is a short 1.89 years if a reasonable carbon tax system is employed. Payback period showed the highest sensitivity to carbon tax: eliminating it complete increasing payback period to 8.05 years relative to the BS system, but still leaving the SMR-MR-SG desirable over the other two systems. Other factors with large impacts on payback period were

CSU capital cost, CO<sub>2</sub> sale price, and electricity cost. The SMR-MR-SG showed a reduction in discounted lifetime cost of 42.0% and 43.4% relative to the BS and BSC systems, respectively.

The results of this study show that the SMR-MR-SG could be a direct replacement for an industrial boiler system. The SMR-MR-SG can offer significantly reduced cost and energy use while completely eliminating CO<sub>2</sub> emissions. The author intends to continue the development of this technology in the near future, targeting commercialization as an end goal.

## **5.1. Recommendations for Future Work**

Future work will involve experimental validation of assumed thermodynamic parameters and increased detail in the thermodynamic model to understand the effect of operating conditions.

### **5.1.1. SMR-MR-SG Cycle Variants**

There are several interesting variants to the proposed SMR-MR-SG system that were not investigated fully in this study. The topics listed would constitute meaningful future work. To start, there are several ways to capture CO<sub>2</sub> from the retentate stream:

- Cryogenic CO<sub>2</sub> separation, as in this study. CSU combines high capital expense with simple and effective operation and low energy penalties, but energy cost increases quickly with decreasing CO<sub>2</sub> concentration.
- Burn retentate to remove CH<sub>4</sub> and H<sub>2</sub>, recover waste heat, condense water, and end up with a high purity CO<sub>2</sub> stream that may require little or no CO<sub>2</sub> capture technology.
- Separate CO<sub>2</sub> from retentate via chemical adsorption.
- Separate CO<sub>2</sub> through a membrane (different than the H<sub>2</sub> membrane). This is relatively unproven technology and likely expensive, but could offer very simple and inexpensive operation [8].

Any or all these technologies could be combined with cooling and or compression to create compressed or liquefied CO<sub>2</sub> for sale or export. The CO<sub>2</sub> production could also be used in a process where it is directly needed. For example, a brewing plant may need large amounts of steam for brewing and building heating in addition to CO<sub>2</sub> for carbonation.

Another area of interest is the amount and composition of sweep gas. Two potential variations in sweep gas are to:

- Use air for sweep gas instead of steam, especially if the permeate will be burned as in this system. Spallina et al. performed work on this concept [53], but it has not been applied to a steam generation application.
- Increase the flow rate of sweep gas dramatically. This would greatly increase the driving force for H<sub>2</sub> permeation through the membrane, at the expense of using more heat to superheat more sweep gas. However, if heat is recovered efficiently as in this study, then the downside may be insignificant.

Hydrogen capture is an interesting parameter: the intuitive thought process is that it would be optimized at 100% such that no hydrogen is left on the retentate side. However, there are diminishing returns in flow rate of hydrogen per membrane surface area, as additional surface area adds to the system's capital cost. This suggests that, if un-permeated hydrogen gas is recycled, the optimal hydrogen capture is a finite number less than 100%. Methane conversion may also be optimized at some value below 100% with recycled retentate gas. With the working thermodynamic and technoeconomic model developed in this study, it would be interesting to perform an optimization of the system's lifetime cost. The optimization should be based on independent variables including both steam to carbon ratios, methane conversion efficiency,

hydrogen capture efficiency, reformer temperature, feed pressure, and permeate pressure. This would require a significantly more detailed model to execute properly.

### **5.1.2. Summary**

This study lays the groundwork for a potentially lucrative future technology as a direct replacement for industrial boilers. Several items should be addressed to help transition this study towards proof of concept and commercialization:

- A small-scale test facility should be designed and operated to validate the key assumptions of the thermodynamic model.
- More detailed should be added to the thermodynamic model, including pressure losses, detailed heat exchanger models, and more realistic heat losses.
- A plate and frame configuration membrane reactor should be built and tested to validate scaling costs and thermodynamic parameters of the reactor.
- The variations of the thermodynamic cycle discussed in section 5.1.1 should be modeled and optimized.
- A high-fidelity sensitivity analysis should be conducted to identify any high-influence thermodynamic parameters that were not identified in this study.

## REFERENCES

- [1] United States Environmental Protection Agency (EPA), 2017, “Global Greenhouse Gas Emissions Data.”
- [2] International Energy Agency (IEA), 2018, *CO<sub>2</sub> Emissions from Fuel Combustion*.
- [3] Lawrence Livermore National Laboratory, and United States Department of Energy (DoE), 2015, “Carbon Flow Charts,” LLNL Flow Charts [Online]. Available: <https://flowcharts.llnl.gov/commodities/carbon>.
- [4] U.S. EIA, 2018, *Annual Energy Outlook 2018 with Projections to 2050*.
- [5] U.S. Energy Information Administration, 2018, “U.S. Natural Gas Prices” [Online]. Available: [https://www.eia.gov/dnav/ng/ng\\_pri\\_sum\\_dc\\_u\\_nus\\_a.htm](https://www.eia.gov/dnav/ng/ng_pri_sum_dc_u_nus_a.htm). [Accessed: 08-Feb-2019].
- [6] 2015, “The Way Forward: Second-Best Solutions,” Econ.
- [7] Sharma, R., Kumar, A., and Upadhyay, R. K., 2017, “Performance Comparison of Methanol Steam Reforming Integrated to Pd-Ag Membrane: Membrane Reformer vs. Membrane Separator,” *Sep. Purif. Technol.*, **183**, pp. 194–203.
- [8] Ribeirinha, P., Abdollahzadeh, M., Boaventura, M., and Mendes, A., 2017, “H<sub>2</sub> Production with Low Carbon Content via MSR in Packed Bed Membrane Reactors for High-Temperature Polymeric Electrolyte Membrane Fuel Cell,” *Appl. Energy*, **188**, pp. 409–419.
- [9] Tribioli, L., Cozzolino, R., and Chiappini, D., 2017, “Technical Assessment of Different Operating Conditions of an On-Board Autothermal Reformer for Fuel Cell Vehicles,” *Energies*, **10**(839), pp. 1–17.
- [10] “Hydrogen Production: Natural Gas Reforming,” *Fuel Cell Technol. Off.*
- [11] Nakajima, T., Kume, T., Ikeda, Y., Shiraki, M., Kurokawa, H., Iseki, T., Kajitani, M., Tanaka, H., Hikosaka, H., Takagi, Y., and Ito, M., 2015, “Effect of Concentration Polarization on Hydrogen Production Performance of Ceramic-Support Pd Membrane Module,” *Int. J. Hydrogen Energy*, **40**, pp. 11451–11456.
- [12] Anzelmo, B., 2016, *On-Board Hydrogen Production from Natural Gas via a Metallic Pd-Based Membrane Reactor*.
- [13] Song, C., Liu, Q., Ji, N., Kansha, Y., and Tsutsumi, A., 2015, “Optimization of Steam Methane Reforming Coupled with Pressure Swing Adsorption Hydrogen Production Process by Heat Integration,” *Appl. Energy*, **154**, pp. 392–401.
- [14] Iulianelli, A., Liguori, S., Wilcox, J., and Basile, A., 2016, “Advances on Methane Steam Reforming to Produce Hydrogen through Membrane Reactors Technology: A Review,” *Catal. Rev.*, **58**(1), pp. 1–35.
- [15] Solsvik, J., and Jakobsen, H. A., 2017, “On the Modeling of One-Dimensional Membrane Reactors: Application to Hydrogen Production in Fixed Packed Bed,” *Fuel*, **202**, pp. 595–612.
- [16] Uehara, I., 2008, “Separation and Purification of Hydrogen,” *Energy carriers Convers. Syst. with Emphas. Hydrog.*, **1**, pp. 268–282.
- [17] Barelli, L., Bidini, G., Gallorini, F., and Servili, S., 2008, “Hydrogen Production through Sorption-Enhanced Steam Methane Reforming and Membrane Technology: A Review,” *Energy*, **33**, pp. 554–570.
- [18] Zaragoza Martin, F., Dijkstra, J. W., Boon, J., and Meuldijk, J., 2011, “Energy Procedia A Membrane Reformer with Permeate Side Combustion for CO<sub>2</sub> Capture: Modeling and

- Design,” *Energy Procedia*, **4**, pp. 707–714.
- [19] Murrura, M. A., Cerbelli, S., and Annesini, M. C., 2017, “Modelling and Optimization of Hydrogen Yield in Membrane Steam Reforming Reactors,” *Can. J. Chem. Eng.*, **95**, pp. 1676–1682.
- [20] Johnsen, K., Ryu, H. J., Grace, J. R., and Lim, C. J., 2006, “Sorption-Enhanced Steam Reforming of Methane in a Fluidized Bed Reactor with Dolomite as CO<sub>2</sub>-Acceptor,” *Chem. Eng. Sci.*, **61**, pp. 1195–1202.
- [21] Adris, A.-E. M., 1994, “A Fluidized Bed Membrane Reactor for Steam Methane Reforming: Experimental Verification and Model Validation,” University of British Columbia.
- [22] Sjardin, M., Damen, K., and Faaij, A., 2006, “Techno-Economic Prospects of Membrane Reactors in a Future Hydrogen-Driven Transportation Sector,” *Energy*, **31**, pp. 2523–2555.
- [23] Wilcox, J., 2012, *Carbon Capture*, Springer Science & Business Media.
- [24] Adhikari, S., and Fernando, S., 2006, “Hydrogen Membrane Separation Techniques,” *Ind. Eng. Chem. Res.*, **45**(3), pp. 875–881.
- [25] Conde, J. J., Maroño, M., and Sánchez-Hervás, J. M., 2017, “Pd-Based Membranes for Hydrogen Separation: Review of Alloying Elements and Their Influence on Membrane Properties,” *Sep. Purif. Rev.*, **46**(2), pp. 152–177.
- [26] Catalano, J., Giacinti Baschetti, M., and Sarti, G. C., 2009, “Influence of the Gas Phase Resistance on Hydrogen Flux through Thin Palladium–silver Membranes,” *J. Memb. Sci.*, **339**(1–2), pp. 57–67.
- [27] Chen, Y., Wang, Y., Xu, H., and Xiong, G., 2008, “Efficient Production of Hydrogen from Natural Gas Steam Reforming in Palladium Membrane Reactor,” *Appl. Catal. B Environ.*, **81**(3–4), pp. 283–294.
- [28] Patel, K. S., and Sunol, A. K., 2007, “Modeling and Simulation of Methane Steam Reforming in a Thermally Coupled Membrane Reactor,” *Int. J. Hydrogen Energy*, **32**(13), pp. 2344–2358.
- [29] Anzelmo, B., Wilcox, J., and Liguori, S., 2017, “Natural Gas Steam Reforming Reaction at Low Temperature and Pressure Conditions for Hydrogen Production via Pd/PSS Membrane Reactor,” *J. Memb. Sci.*, **522**, pp. 343–350.
- [30] Brown, L. F., 2001, *A Comparative Study of Fuels for On-Board Hydrogen Production for Fuel-Cell-Powered Automobiles*.
- [31] Rostrup-Nielsen, J. R., 2001, “Conversion of Hydrocarbons and Alcohols for Fuel Cells,” *Phys. Chem. Chem. Phys.*, **3**, pp. 283–288.
- [32] Burchart-Korol, D., Korol, J., and Czaplicka-Kolarz, K., 2016, “Life Cycle Assessment of Heat Production from Underground Coal Gasification,” *Int. J. Life Cycle Assess.*, **21**(10), pp. 1391–1403.
- [33] Malerød-Fjeld, H., Clark, D., Yuste-Tirados, I., Zanón, R., Catalán-Martinez, D., Beeaff, D., Morejudo, S. H., Vestre, P. K., Norby, T., Haugrud, R., Serra, J. M., and Kjølseth, C., 2017, “Thermo-Electrochemical Production of Compressed Hydrogen from Methane with near-Zero Energy Loss,” *Nat. Energy*, **2**, pp. 923–931.
- [34] Manzolini, G., Dijkstra, J. W., Macchi, E., and Jansen, D., 2006, “Technical Economic Evaluation of a System for Electricity Production with CO<sub>2</sub> Capture Using a Membrane Reformer with Permeate Side Combustion,” *ASME Turbo Expo 2006: Power for Land, Sea, and Air*.
- [35] Leimert, J. M., Dillig, M., and Karl, J., 2018, “Hydrogen Production from Solid Feedstock by Using a Nickel Membrane Reformer,” *J. Memb. Sci.*, **548**, pp. 11–21.

- [36] Miller, J. B., Morreale, B. D., and Smith, M. W., 2014, “Pd-Alloy Membranes for Hydrogen Separation,” *Reactor and Process Design in Sustainable Energy Technology*, Elsevier B.V., pp. 135–161.
- [37] Jiwanuruk, T., Putivisitak, S., Vas-Umnuay, P., Bumroongsakulsawat, P., Cheng, C. K., and Assabumrungrat, S., 2017, “Modeling of Thermally-Coupled Monolithic Membrane Reformer for Vehicular Hydrogen Production,” *Int. J. Hydrogen Energy*, **42**, pp. 26308–26319.
- [38] Iaquaniello, G., Giacobbe, F., Morico, B., Cosenza, S., and Farace, A., 2008, “Membrane Reforming in Converting Natural Gas to Hydrogen: Production Costs, Part II,” **33**, pp. 6595–6601.
- [39] De Falco, M., Salladini, A., Palo, E., and Iaquaniello, G., 2015, “Pd-Alloy Membrane Reactor for Natural Gas Steam Reforming: An Innovative Process Design for the Capture of CO<sub>2</sub>,” *Ind. Eng. Chem. Res.*, **54**, pp. 6950–6958.
- [40] 2005, *Characterization of the U.S. Industrial/Commercial Boiler Population*.
- [41] 2018, “Converting Natural Gas Prices in Dollars per Ccf or Mcf to Dollars per Btu or Therm,” U.S. Energy Inf. Adm. [Online]. Available: <https://www.eia.gov/tools/faqs/faq.php?id=45&t=8>. [Accessed: 23-Jan-2019].
- [42] Steinberg, L., 2012, “How Much Electricity Does New York Use?,” Leonard Steinb. Team [Online]. Available: <http://theleonardsteinbergteam.com/how-much-electricity-does-new-york-use/>.
- [43] Kian, K., Woodall, C., Wilcox, J., Liguori, S., Kian, K., Woodall, C. M., Wilcox, J., and Liguori, S., 2018, “Performance of Pd-Based Membranes and Effects of Various Gas Mixtures on H<sub>2</sub> Permeation,” *Environments*, **5**(12), p. 128.
- [44] Falco, M. De, Marrelli, L., and Iaquaniello, G., 2011, *Membrane Reactors for Hydrogen Production Processes*, Springer.
- [45] Schjøberg, I., Calo, E., Dijk, E. van, Ersöz, A., Fernandez, E. O., Hulteberg, C., Lieftink, D., Nelsson, C., Saint-Just, J., Silversand, F., Stauss, R., and Yasuda, I., 2011, *IEA HIA Task 23: Small Scale Reformers for On-Site Hydrogen Supply*.
- [46] Rostrup-Nielsen, J. R., and Rostrup-Nielsen, T., 2004, *Large-Scale Hydrogen Production*.
- [47] Kurokawa, H., Shirasaki, Y., and Yasuda, I., 2011, “Energy-Efficient Distributed Carbon Capture in Hydrogen Production from Natural Gas,” *Energy Procedia*, **4**, pp. 674–680.
- [48] Gallucci, F., Fernandez, E., Corengia, P., and van Sint Annaland, M., 2013, “Recent Advances on Membranes and Membrane Reactors for Hydrogen Production,” *Chem. Eng. Sci.*, **92**, pp. 40–66.
- [49] Murmura, M. A., Cerbelli, S., and Annesini, M. C., 2017, “Designing the Optimal Geometry of a Membrane Reactor for Hydrogen Production from a Pre-Reformed Gas Mixture Based on the Extent of the Reaction Boundary Layer,” *Chem. Eng. Process. Process Intensif.*, **120**, pp. 148–160.
- [50] Roses, L., Manzolini, G., Campanari, S., De Wit, E., and Walter, M., 2013, “Techno-Economic Assessment of Membrane Reactor Technologies for Pure Hydrogen Production for Fuel Cell Vehicle Fleets,” *Energy and Fuels*, **27**(8), pp. 4423–4431.
- [51] Prasad, P., and Elnashaie, S. S. E. H., 2004, “Novel Circulating Fluidized-Bed Membrane Reformer Using Carbon Dioxide Sequestration,” *Ind. Eng. Chem. Res.*, **43**, pp. 494–501.
- [52] Chen, Z., Po, F., Grace, J. R., Lim, C. J., Mahecha-Botero, A., Rakib, M., Shirasaki, Y., and Yasuda, I., 2008, “Sorbent-Enhanced/Membrane-Assisted Steam-Methane Reforming,” *Chem. Eng. Sci.*, **63**, pp. 170–182.

- [53] Spallina, V., Pandolfo, D., Battistella, A., Romano, M. C., Van, M., Annaland, S., and Gallucci, F., 2016, “Techno-Economic Assessment of Membrane Assisted Fluidized Bed Reactors for Pure H<sub>2</sub> Production with CO<sub>2</sub> Capture,” *Energy Convers. Manag.*, **120**, pp. 257–273.
- [54] Kim, D., Kellogg, A., Livaich, E., and Wilhite, B. A., 2009, “Towards an Integrated Ceramic Micro-Membrane Network: Electroless-Plated Palladium Membranes in Cordierite Supports,” *J. Memb. Sci.*, **340**(1–2), pp. 109–116.
- [55] Martínez, I., Romano, M. C., Chiesa, P., Grasa, G., and Murillo, R., 2013, “Hydrogen Production through Sorption Enhanced Steam Reforming of Natural Gas: Thermodynamic Plant Assessment,” *Int. J. Hydrogen Energy*, **38**, pp. 15180–15199.
- [56] Boeltken, T., Wunsch, A., Gietzelt, T., Pfeifer, P., and Dittmeyer, R., 2014, “Ultra-Compact Microstructured Methane Steam Reformer with Integrated Palladium Membrane for on-Site Production of Pure Hydrogen: Experimental Demonstration,” *Int. J. Hydrogen Energy*, **39**, pp. 18058–18068.
- [57] Chein, R.-Y., Chen, Y.-C., Chang, C.-M., and Chung, J. N., 2013, “Experimental Study on the Performance of Hydrogen Production from Miniature Methanol-steam Reformer Integrated with Swiss-Roll Type Combustor for PEMFC,” *Appl. Energy*, **105**, pp. 86–98.
- [58] Patrascu, M., and Sheintuch, M., 2015, “On-Site Pure Hydrogen Production by Methane Steam Reforming in High Flux Membrane Reactor: Experimental Validation, Model Predictions and Membrane Inhibition,” *Chem. Eng. J.*, **262**, pp. 862–874.
- [59] Jordal, K., Bredesen, R., Kvamsdal, H. M., and Bolland, O., 2004, “Integration of H<sub>2</sub>-Separating Membrane Technology in Gas Turbine Processes for CO<sub>2</sub> Capture,” *Energy*, **29**, pp. 1269–1278.
- [60] Bredesen, R., and Klette, H., 2000, “Method of Manufacturing Thin Metal Membranes,” pp. 1–6.
- [61] Pex, P. P. A. C., Delft, Y. C. van, Correia, L. A., Veen, H. M. van, Jansen, D., and Dijkstra, J. W., 2006, “Palladium Alloy Membranes for Energy Efficient Membrane REactor,” *Netherlands’ Catalysis and Chemistry Conference*, Noordwijkerhout, The Netherlands, pp. 1–11.
- [62] Sanusi, Y. S., Mokheimer, E. M. A., and Habib, M. A., 2017, “Thermo-Economic Analysis of Integrated Membrane-SMR ITM-Oxy-Combustion Hydrogen and Power Production Plant,” *Appl. Energy*, **204**, pp. 626–640.
- [63] Barba, D., Giacobbe, F., De Cesaris, A., Farace, A., Iaquaniello, G., and Pipino, A., 2008, “Membrane Reforming in Converting Natural Gas to Hydrogen (Part One),” *Int. J. Hydrogen Energy*, **33**, pp. 3700–3709.
- [64] De Falco, M., Piemonte, V., Di Paola, L., and Basile, A., 2014, “Methane Membrane Steam Reforming: Heat Duty Assessment,” *Int. J. Hydrogen Energy*, **39**(9), pp. 4761–4770.
- [65] Dunn, S., 2002, “Hydrogen Futures: Toward a Sustainable Energy System,” *Int. J. Hydrogen Energy*, **27**, pp. 235–264.
- [66] Cleaver Brooks, 2010, *Boiler Efficiency Guide*, Thomasville, GA.
- [67] Office of Energy Efficiency & Renewable Energy, 2019, “Purchasing Energy-Efficient Commercial Boilers,” *Fed. Energy Manag. Progr.*, (July 2016) [Online]. Available: <https://www.energy.gov/eere/femp/purchasing-energy-efficient-commercial-boilers>. [Accessed: 02-Jun-2019].
- [68] U.S. Department of Energy, 2012, *Benchmark the Fuel Cost of Steam Generation*.
- [69] International Energy Administration Energy Technology Systems Analysis Programme

- (IEA ETSAP), 2010, “Industrial Combustion Boilers,” *Energy Technol. Netw.*, (May), pp. 1–5.
- [70] US Environmental Protection Agency, 2013, “Fact Sheet: CHP as a Boiler Replacement Opportunity,” pp. 1–6.
- [71] Gallucci, F., Paturzo, L., Famà, A., and Basile, A., 2004, “Experimental Study of the Methane Steam Reforming Reaction in a Dense Pd/Ag Membrane Reactor,” *Ind. Eng. Chem. Res.*, **43**(4), pp. 928–933.
- [72] Shigarov, A., Kirillov, V., and Landgraf, I., 2014, “Computational Study of Pd-Membrane CH<sub>4</sub> Steam Reformer with Fixed Catalyst Bed: Searching for a Way to Increase Membrane Efficiency,” *Int. J. Hydrogen Energy*, **39**, pp. 20072–20093.
- [73] Mokheimer, E. M. A., Ibrar Hussain, M., Ahmed, S., Habib, M. A., and Al-Qutub, A. A., 2014, “On the Modeling of Steam Methane Reforming,” *J. Energy Resour. Technol.*
- [74] Sheintuch, M., 2015, “Pure Hydrogen Production in a Membrane Reformer: Demonstration, Macro-Scale and Atomic Scale Modeling,” *Chem. Eng. J.*
- [75] Vigneault, A., and Grace, J. R., 2015, “Hydrogen Production in Multi-Channel Membrane Reactor via Steam Methane Reforming and Methane Catalytic Combustion,” *Int. J. Hydrogen Energy*.
- [76] Eveloy, V., 2012, “Numerical Analysis of an Internal Methane Reforming Solid Oxide Fuel Cell with Fuel Recycling,” *Appl. Energy*, **93**, pp. 107–115.
- [77] Huang, Y. M., Xu, J. H., Ling, W., Li, Y., Zhang, X. X., Dai, Z. K., Sui, Y., and Zhao, H. L., 2015, “Efficacy of the Wen Dan Decoction, a Chinese Herbal Formula, for Metabolic Syndrome,” *Altern. Ther. Health Med.*, **21**(4), pp. 54–67.
- [78] Boyd, B., 2010, *Guidelines for Estimating Unmetered Industrial Water Use*.
- [79] U.S. Department of Labor, “CPI Inflation Calculator” [Online]. Available: <https://data.bls.gov/cgi-bin/cpicalc.pl?cost1=1&year1=198701&year2=201801>. [Accessed: 08-Feb-2019].
- [80] Lieberman, N. P., and Lieberman, E. T., 2009, *Working Guide to Process Equipment*.
- [81] Advanced Manufacturing Office, *Improving Steam System Performance : A Sourcebook for Industry Second Edition*.
- [82] Harrell, G., and Ph, D., 2001, *Steam System Survey Guide*.
- [83] Abu-Zahra, M. R. M., Niederer, J. P. M., Feron, P. H. M., and Versteeg, G. F., 2007, “CO<sub>2</sub> Capture from Power Plants,” *Int. J. Greenh. Gas Control*, **1**(2), pp. 135–142.
- [84] Brennan, D., 1998, *Process Industry Economics: An International Perspective*.
- [85] Perry, R. H., 1997, *Chemical Engineers’ Handbook*, McGraw-Hill.
- [86] Brown, T., *Engineering Economics and Economic Design for Process Engineers*, CRC Press.
- [87] Remer, D. S., and Chai, L. H., 1990, “Design Cost Factors for Scaling-Up Engineering Equipment,” *Chem. Eng. Prog.*, **86**(8), pp. 77–82.
- [88] Brundett, G. W., 1987, “Economics,” *Handbook of Dehumidification Technology*, Butterworths, Essex, Great Britain, pp. 202–214.
- [89] “British Pound to US Dollar Spot Exchange Rates for 1987 from the Bank of England” [Online]. Available: <https://www.poundsterlinglive.com/bank-of-england-spot/historical-spot-exchange-rates/gbp/GBP-to-USD-1987>. [Accessed: 08-Feb-2019].
- [90] Incropera, F. P., Dewitt, D. P., Bergman, T. L., and Lavine, A. S., 2017, *Fundamentals of Heat and Mass Transfer*, John Wiley and Sons.
- [91] Xu, G., Liang, F., Yang, Y., Hu, Y., Zhang, K., and Liu, W., 2014, “An Improved CO<sub>2</sub>

- Separation and Purification System Based on Cryogenic Separation and Distillation Theory,” *Energies*, **7**, pp. 3484–3502.
- [92] Liguori, S., Iulianelli, A., Dalena, F., Pinacci, P., Drago, F., Broglia, M., Huang, Y., and Basile, A., 2014, “Performance and Long-Term Stability of Pd/PSS and Pd/Al<sub>2</sub>O<sub>3</sub> Membranes for Hydrogen Separation,” *Membranes (Basel)*, **4**(1), pp. 143–162.
- [93] Roses, L., Gallucci, F., Manzolini, G., and van Sint Annaland, M., 2013, “Experimental Study of Steam Methane Reforming in a Pd-Based Fluidized Bed Membrane Reactor,” *Chem. Eng. J.*, **222**, pp. 307–320.
- [94] Peters, T. A., Stange, M., and Bredesen, R., 2011, “On the High Pressure Performance of Thin Supported Pd-23%Ag Membranes-Evidence of Ultrahigh Hydrogen Flux after Air Treatment,” *J. Memb. Sci.*, **378**(1–2), pp. 28–34.
- [95] Cengel, Y. A., and Boles, M. A., 2015, *Thermodynamics: An Engineering Approach*, McGraw Hill.
- [96] Chiesa, P., Campanari, S., and Manzolini, G., 2011, “CO<sub>2</sub> Cryogenic Separation from Combined Cycles Integrated with Molten Carbonate Fuel Cells,” *Int. J. Hydrogen Energy*, **36**, pp. 10355–10365.
- [97] Hatlevik, Ø., Gade, S. K., Keeling, M. K., Thoen, P. M., Davidson, A. P., and Way, J. D., 2010, “Palladium and Palladium Alloy Membranes for Hydrogen Separation and Production: History, Fabrication Strategies, and Current Performance,” *Sep. Purif. Technol.*, **73**(1), pp. 59–64.
- [98] Money Metals LLC, 2019, “Palladium Price Charts: Check Live & Historical Bullion Prices Today” [Online]. Available: <https://www.moneymetals.com/precious-metals-charts/palladium-price>. [Accessed: 08-Feb-2019].
- [99] Acquaviva, J., 2009, *High-Performance, Durable, Palladium Alloy Membrane for Hydrogen Separation and Purification*, New York, NY.
- [100] Emerson, S., Dardas, Z., Hebert, R., Janowsky, G., Magdefrau, N., She, Y., Wittenzellner, J., and Technologies, U., 2011, *Advanced Palladium Membrane Scale-up for Hydrogen Separation*, East Hartford, CT.
- [101] Couper, J. R., Emeritus, D. S., Ralph, T., Hertz, D. W., Manager, B. S., Loading, F., Practices, V., Smith, F. L., Ph, D., Principal, M. E., and Associates, W. C., 2008, “Process Economics,” *Perry’s Chemical Engineers’ Handbook*.
- [102] Myers, D. B., Ariff, G. D., James, B. D., Lettow, J. S., Thomas, C. E. S., and Kuhn, R. C., 2002, “Cost and Performance Comparison Of Stationary Hydrogen Fueling Appliances,” *U.S. DOE Hydrogen Program Review*, pp. 1–8.
- [103] Jiangzhou, S., Wang, R. Z., Lu, Y. Z., Xu, Y. X., and Wu, J. Y., 2005, “Experimental Study on Locomotive Driver Cabin Adsorption Air Conditioning Prototype Machine,” *Energy Convers. Manag.*, **46**(9–10), pp. 1655–1665.
- [104] International Gas Union (IGU), 2012, *Natural Gas Conversion Guide*.
- [105] U.S. Energy Information Administration, 2019, *Electric Power Monthly with Data for November 2018*.
- [106] Global CCS Institute, 2019, *The CO<sub>2</sub> Market*.
- [107] Luckow, P., Stanton, E. A., Fields, S., Ong, W., Biewald, B., Jackson, S., and Fisher, J., 2016, *Spring 2016 National Carbon Dioxide Price Forecast*, Cambridge, MA.
- [108] North China Electric Power University, and North China Electric Power University, 2014, *People’s Republic of China: Study on Carbon Capture and Storage in Natural Gas-Based Power Plants*.

- [109] Saeys, M., Quah, M. C. G., Agrawal, R., Farooq, S., Karimi, I. A., and Vasudevan, S., 2016, “Energy Penalty Estimates for CO<sub>2</sub> Capture: Comparison between Fuel Types and Capture-Combustion Modes,” *Energy*, **103**, pp. 709–714.
- [110] Petrakopoulou, F., and Tsatsaronis, G., 2012, “Production of Hydrogen-Rich Fuels for Pre-Combustion Carbon Capture in Power Plants: A Thermodynamic Assessment,” *Int. J. Hydrogen Energy*, **37**(9), pp. 7554–7564.
- [111] Gür, T. M., 2017, “Perspective—Low-Carbon Electricity Is Great: What about ‘Less-Carbon’?,” *J. Electrochem. Soc.*, **164**(14), pp. F1587–F1590.
- [112] Soltani, R., Rosen, M. A., and Dincer, I., 2014, “Assessment of CO<sub>2</sub> Capture Options from Various Points in Steam Methane Reforming for Hydrogen Production,” *Int. J. Hydrogen Energy*, **39**(35), pp. 20266–20275.
- [113] Jou, C. J. G., Lee, C. li, Tsai, C. H., Wang, H. P., and Lin, M. L., 2008, “Enhancing the Performance of a High-Pressure Cogeneration Boiler with Waste Hydrogen-Rich Fuel,” *Int. J. Hydrogen Energy*, **33**(20), pp. 5806–5810.
- [114] Nordhaus, W. D., 2017, “Revisiting the Social Cost of Carbon,” *Proceedings of the National Academy of Sciences*, pp. 1518–1523.
- [115] Wu, X. D., Guo, J. L., and Chen, G. Q., 2018, “The Striking Amount of Carbon Emissions by the Construction Stage of Coal-Fired Power Generation System in China,” *Energy Policy*, **117**(July 2017), pp. 358–369.
- [116] Voses Software, 2007, “ModelRisk.”
- [117] Kim, S. M., and Mudawar, I., 2013, “Universal Approach to Predicting Saturated Flow Boiling Heat Transfer in Mini/Micro-Channels – Part II. Two-Phase Heat Transfer Coefficient,” *Int. J. Heat Mass Transf.*, **64**, pp. 1239–1256.
- [118] Kim, S. M., and Mudawar, I., 2012, “Flow Condensation in Parallel Micro-Channels - Part 2: Heat Transfer Results and Correlation Technique,” *Int. J. Heat Mass Transf.*, **55**(4), pp. 984–994.

## **APPENDIX A. Representative Calculation**

The purpose of this appendix is to verify the results obtained using Engineering Equation Solver (EES). EES was used as the primary tool for the thermodynamic and technoeconomic analyses discussed in Chapter 3. This calculation will step through the process, equations, and assumptions required to completely model the steam generation cycle shown in Figure 3-1.

**Table A-1:** State point descriptions for integrated steam methane reformer and steam generation system.

<b>State Point</b>	<b>Location</b>	<b>State Point</b>	<b>Location</b>
1	Natural gas (CH <sub>4</sub> ) inlet	18	Ambient retentate
2	Mixed recycled and input fuel gases	19	Supercooled CO <sub>2</sub>
3	Preheated fuel gases	20	Supercooled, compressed CO <sub>2</sub>
4	Makeup liquid water supply	21	Recycled fuel gas
5	Liquid water supply to pump	22	Permeate
6	Water pump outlet	23	Boiler air supply
7	Preheated water boiler feed	24	Boiler combustion exhaust (BCE)
8	Boiler steam output	25	BCE after HE 1
9	Steam export	26	BCE after HE 2
10	Reaction steam	27	BCE after HE 3
11	Sweep steam	28	BCE after HE 4
12	Superheated sweep steam	29	BCE after HE 5
13	Mixed fuel gases and reaction steam	30	Ambient BCE
14	Superheated MR feed	31	Condensed water from BCE
15	Reformed feed, before H <sub>2</sub> separation	32	Condensed water from retentate
16	Retentate	33	Condensate return from export steam
17	Retentate after HE 5		

The goal of the thermodynamic state points calculation was to fully define each state in Table A-1. Specifically, it defined the molar flow rate, mole fraction of each species, and flow of enthalpy. The flow of enthalpy interdepends on the energy balance calculations in section A.2A.2, but flow of enthalpy was calculated in this section to maintain organization. Table A-2 defines the several variations in enthalpy definitions.

There were many inputs from literature and assumptions for both the thermodynamic and technoeconomic analysis. Table 3-1 lists the input parameters to the thermodynamic model. Table 3-5 and Table 3-6 list the input parameters to the technoeconomic model. The calculations of the thermodynamic model are listed in Table A-3.

The goal of the energy balance was to define temperature, pressure, quality (if two-phase), and flow enthalpy of each state. It also defined the heat duty of each heat exchanger, the energy flows in and out of the system, and associated efficiencies. The hand calculations for the energy balance are given in Table A-4.

The goal of the capital and operation cost calculation was to supply costs to the cash flow analysis. Table A-5 lists the hand calculations that verify the calculations in Engineering Equation Solver. The cash flow analysis defined the important parameters of payback and period and net present benefit between the SMR and boiler systems. Table A-6 lists hand calculations to verify the cash flow analysis calculations.

**Table A-2:** Definition of enthalpy terms used in calculations.

<b>Symbol</b>	<b>Description</b>	<b>Units</b>
$h$	Specific, sensible enthalpy	$\text{kJ mol}^{-1}$
$h_f$	Specific enthalpy of formation	$\text{kJ mol}^{-1}$
$\dot{H}$	Flow of sensible enthalpy	kW
$\dot{H}_{sf}$	Flow of enthalpy, including sensible and formation	kW

## A.1. Thermodynamic State Points Calculation

**Table A-3:** Hand calculations versus EES results to verify thermodynamic state points.

Parameter	Equation	Evaluated	EES Calc. Value	Hand Calc. Value	Units
Molar flow 1, CH <sub>4</sub>	$\dot{n}_{1,\text{CH}_4} + \dot{n}_{21,\text{CH}_4} = \dot{n}_{2,\text{CH}_4}$	$\dot{n}_{1,\text{CH}_4} + 0.00051 = 0.00146$	0.00095	0.00095	kmol s <sup>-1</sup>
Enthalpy 1	$\dot{H}_1 = \dot{H}_{1,\text{H}_2} + \dot{H}_{1,\text{CH}_4} + \dot{H}_{1,\text{H}_2\text{O}} + \dot{H}_{1,\text{CO}_2} + \dot{H}_{1,\text{N}_2} + \dot{H}_{1,\text{O}_2}$	$\dot{H}_1 = 0 + (-71.5) + 0 + 0 + 0 + 0$	-71.5	-71.4	kW
Enthalpy 1, CH <sub>4</sub>	$\dot{H}_{1,\text{H}_2} = (\dot{n}_{1,\text{total}})(y_{1,\text{H}_2})(h_{1,\text{H}_2} + h_{f1,\text{H}_2})$	$\dot{H}_{1,\text{H}_2} = (0.00095)(1)(-607.6 - 74,595)$	-71.5	-71.4	kW
Mass flow NG input	$\dot{m}_{\text{NG,input}} = (\dot{n}_{1,\text{CH}_4})(M_{\text{CH}_4})$	$\dot{m}_{\text{NG,input}} = (0.00095)(16.04)$	0.01525	0.01524	kg s <sup>-1</sup>
Total molar flow 2	$\dot{n}_{2,\text{total}} = \dot{n}_{2,\text{H}_2} + \dot{n}_{2,\text{CH}_4} + \dot{n}_{2,\text{H}_2\text{O}} + \dot{n}_{2,\text{CO}_2} + \dot{n}_{2,\text{N}_2} + \dot{n}_{2,\text{O}_2}$	$\dot{n}_{2,\text{total}} = (0.00042) + (0.00146) + 0 + (0.00011) + 0 + 0$	0199	0.0199	kmol s <sup>-1</sup>
Mole fractions 2	$y_{2,\text{H}_2} = \frac{\dot{n}_{2,\text{H}_2}}{\dot{n}_{2,\text{total}}}$	$y_{2,\text{H}_2} = \frac{0.00042}{0.00199}$	0.212	0.211	--
“ ”	$y_{2,\text{CH}_4} = \frac{\dot{n}_{2,\text{CH}_4}}{\dot{n}_{2,\text{total}}}$	$y_{2,\text{CH}_4} = \frac{0.00146}{0.00199}$	0.735	0.734	--
“ ”	$y_{2,\text{CO}_2} = \frac{\dot{n}_{2,\text{CO}_2}}{\dot{n}_{2,\text{total}}}$	$y_{2,\text{CO}_2} = \frac{0.00011}{0.00199}$	0.053	0.055	--
Enthalpy 2	$\dot{H}_i = \dot{H}_{i,\text{H}_2} + \dot{H}_{i,\text{CH}_4} + \dot{H}_{i,\text{H}_2\text{O}} + \dot{H}_{i,\text{CO}_2} + \dot{H}_{i,\text{N}_2} + \dot{H}_{i,\text{O}_2}$	$\dot{H}_i = 3.2 - 109.9 + 0 - 41.5 + 0 + 0$	-148.3	-148.2	kW
Enthalpy 2, H <sub>2</sub>	$\dot{H}_{i,\text{H}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2})(h_{i,\text{H}_2} + h_{fi,\text{H}_2})$	$\dot{H}_{i,\text{H}_2} = (0.00199)(0.212)(7,640 + 0)$	3.2	3.2	kW
Enthalpy 2, CH <sub>4</sub>	$\dot{H}_{i,\text{CH}_4} = (\dot{n}_{i,\text{total}})(y_{i,\text{CH}_4})(h_{i,\text{CH}_4} + h_{fi,\text{CH}_4})$	$\dot{H}_{i,\text{CH}_4} = (0.00199)(0.735)(-540 - 74,595)$	-109.9	-109.9	kW
Enthalpy 2, CO <sub>2</sub>	$\dot{H}_{i,\text{CO}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{CO}_2})(h_{i,\text{CO}_2} + h_{fi,\text{CO}_2})$	$\dot{H}_{i,\text{CO}_2} = (0.00199)(0.053)(-403.4 - 393,486)$	-41.5	-41.5	kW
Total molar flow 3	$\dot{n}_{i,\text{total}} = \dot{n}_{i,\text{H}_2} + \dot{n}_{i,\text{CH}_4} + \dot{n}_{i,\text{H}_2\text{O}} + \dot{n}_{i,\text{CO}_2} + \dot{n}_{i,\text{N}_2} + \dot{n}_{i,\text{O}_2}$	$\dot{n}_{i,\text{total}} = (0.00042) + (0.00146) + 0 + (0.00011) + 0 + 0$	0.00199	0.00199	kmol s <sup>-1</sup>

Enthalpy 3	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 5.55 - 100.00 + 0 - 41.12 + 0 + 0$	-134.3	-134.2	kW
Enthalpy 3, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{f,i,H_2})$	$\dot{H}_{i,H_2} = (0.002007)(0.212)(13,044 + 0)$	5.5	5.5	kW
Enthalpy 3, CH <sub>4</sub>	$\dot{H}_{i,CH_4} = (\dot{n}_{i,total})(y_{i,CH_4})(h_{i,CH_4} + h_{f,i,CH_4})$	$\dot{H}_{i,CH_4} = (0.002007)(0.735)(6,900 - 74,595)$	-99.0	-99.0	kW
Enthalpy 3, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{f,i,CO_2})$	$\dot{H}_{i,CO_2} = (0.002007)(0.053)(6,885 - 393,486)$	-40.8	-40.8	kW
Molar flow 4, H <sub>2</sub> O	$\dot{n}_{4,H_2O} + \dot{n}_{31,H_2O} + \dot{n}_{32,H_2O} = \dot{n}_{5,H_2O}$	$\dot{n}_{4,H_2O} + (0.00527) + (0.00249) = (0.02315)$	0.01539	0.01539	kmol s <sup>-1</sup>
Enthalpy 4	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 4,353.4 + 0 + 0 + 0$	-4,353.4	-4,352.2	kW
Enthalpy 4, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.01539)(1)(3,020 - 285,813)$	-4,353.4	-4,352.2	kW
Mass flow 4	$\dot{m}_{water,supply} = (\dot{n}_{4,H_2O})(M_{H_2O})$	$\dot{m}_{water,supply} = (0.01539)(18.02)$	0.2773	0.2773	kg s <sup>-1</sup>
Enthalpy 5	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 6,545.7 + 0 + 0 + 0$	-6,545.7	-6,546.7	kW
Enthalpy 5, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.02315)(1)(3,020 - 285,813)$	-6,545.7	-6,546.7	kW
Enthalpy 6	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 6,545.2 + 0 + 0 + 0$	-6,545.2	-6,546.1	kW
Enthalpy 6, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.02315)(1)(3,042 - 285,813)$	-6,545.2	-6,546.1	kW
Temperature 7	$T_7 = T_{sat}(Water, P = P_7)$	$T_7 = T_{sat}(Water, P = 15 \text{ bar})$	198.3	198.3	°C
Enthalpy 7	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 6,054.8 + 0 + 0 + 0$	-6,054.8	-6,055.8	kW
Enthalpy 7, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.02315)(1)(24,226 - 285,813)$	-6,054.8	-6,055.8	kW
Molar flow 8, H <sub>2</sub> O	$\dot{n}_{8,H_2O} = \dot{n}_{9,H_2O} + \dot{n}_{10,H_2O} + \dot{n}_{11,H_2O}$	$\dot{n}_{8,H_2O} = 0.0173 + 0.004388 + 0.001463$	0.02315	0.02315	kmol s <sup>-1</sup>
Enthalpy 8	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 5,421.8 + 0 + 0 + 0$	-5,421.8	-5,422.6	kW
Enthalpy 8, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.02315)(1)(51,577 - 285,813)$	-5,421.8	-5,422.6	kW
Molar flow 9, H <sub>2</sub> O	$\dot{n}_{9,H_2O} = \frac{\dot{m}_{steam,gen}}{M_{H_2O}}$	$\dot{n}_{9,H_2O} = \frac{0.3116}{18.02}$	0.01730	0.01730	kmol s <sup>-1</sup>
Enthalpy 9	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 4051.3 + 0 + 0 + 0$	-4,051.3	-4,052.3	kW

Enthalpy 9, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.01730)(1)(51,577 - 285,813)$	-4,051.3	-4,052.3	kW
Enthalpy 10	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,027.9 + 0 + 0 + 0$	-1,027.9	-1,028.3	kW
Enthalpy 10, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.00439)(1)(51,577 - 285,813)$	-1,027.9	-1,028.3	kW
Enthalpy 11	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 341.1 + 0 + 0 + 0$	-341.1	-340.5	kW
Enthalpy 11, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.00146)(1)(52,622 - 285,813)$	-341.1	-340.5	kW
Molar flow 12, H <sub>2</sub> O	$\dot{n}_{12,H_2O} = (SC_{ratio,sweep})(\dot{n}_{14,CH_4})$	$\dot{n}_{12,H_2O} = (1)(0.00146)$	0.00146	0.00146	kmol s <sup>-1</sup>
Enthalpy 12	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 330.3 + 0 + 0 + 0$	-330.3	-329.7	kW
Enthalpy 12, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.00146)(1)(59,975 - 285,813)$	-330.3	-329.7	kW
Molar flow 13	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = (0.00042) + (0.00146) + (0.00439) + (0.00011) + 0 + 0$	0.00638	0.00638	kmol s <sup>-1</sup>
Mole fractions 13	$y_{i,H_2} = \frac{\dot{n}_{i,H_2}}{\dot{n}_{i,total}}$	$y_{i,H_2} = \frac{0.00042}{0.00638}$	0.066	0.066	--
“ ”	$y_{i,CH_4} = \frac{\dot{n}_{i,CH_4}}{\dot{n}_{i,total}}$	$y_{i,CH_4} = \frac{0.00146}{0.00638}$	0.229	0.229	--
“ ”	$y_{i,H_2O} = \frac{\dot{n}_{i,H_2O}}{\dot{n}_{i,total}}$	$y_{i,H_2O} = \frac{0.00439}{0.00638}$	0.688	0.688	--
“ ”	$y_{i,CO_2} = \frac{\dot{n}_{i,CO_2}}{\dot{n}_{i,total}}$	$y_{i,CO_2} = \frac{0.00011}{0.00638}$	0.017	0.017	--
Enthalpy 13	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 5.5 - 98.8 - 41.9 - 1,026.4 + 0 + 0$	-1,160.3	-1,161.6	kW
Enthalpy 13, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{f,i,H_2})$	$\dot{H}_{i,H_2} = (0.00638)(0.066)(13,023 + 0)$	5.5	5.5	kW
Enthalpy 13, CH <sub>4</sub>	$\dot{H}_{i,CH_4} = (\dot{n}_{i,total})(y_{i,CH_4})(h_{i,CH_4} + h_{f,i,CH_4})$	$\dot{H}_{i,CH_4} = (0.00638)(0.229)(6,973 - 74,595)$	-98.8	-98.8	kW
Enthalpy 13, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.00638)(0.688)(51,984 - 285,813)$	-1,026.4	-1,026.4	kW
Enthalpy 13, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{f,i,CO_2})$	$\dot{H}_{i,CO_2} = (0.00638)(0.017)(7,117 - 393,486)$	-41.9	-41.9	kW

Molar flow 14, CH <sub>4</sub>	$(\dot{n}_{14,CH_4})(4)(\eta_{CH_4,conv}) + \dot{n}_{14,H_2} = \dot{n}_{15,H_2}$	$(\dot{n}_{14,CH_4})(4)(0.65) + (0.00042) = (0.00423)$	0.00146	0.00147	kmol s <sup>-1</sup>
Molar flow 14, H <sub>2</sub> O	$\dot{n}_{14,H_2O} = (SC_{ratio,reaction})(\dot{n}_{14,CH_4})$	$\dot{n}_{14,H_2O} = (3)(0.00146)$	0.00439	0.00438	kmol s <sup>-1</sup>
Enthalpy 14	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 5.5 - 98.8 - 41.9 - 1,026.4 + 0 + 0$	-1,107.8	-1,109.1	kW
Enthalpy 14, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{f,i,H_2})$	$\dot{H}_{i,H_2} = (0.00638)(0.066)(18,886+0)$	8.0	8.0	kW
Enthalpy 14, CH <sub>4</sub>	$\dot{H}_{i,CH_4} = (\dot{n}_{i,total})(y_{i,CH_4})(h_{i,CH_4} + h_{f,i,CH_4})$	$\dot{H}_{i,CH_4} = (0.00638)(0.229)(17,160 - 74,595)$	-83.9	-83.9	kW
Enthalpy 14, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{f,i,H_2O})$	$\dot{H}_{i,H_2O} = (0.00638)(0.688)(59,763 - 285,813)$	-992.2	-992.2	kW
Enthalpy 14, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{f,i,CO_2})$	$\dot{H}_{i,CO_2} = (0.00638)(0.017)(16,434 - 393,486)$	-40.9	-40.9	kW
Molar flow 15	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = (0.00051) + (0.00423) + (0.00249) + (0.00106) + 0 + 0$	0.00828	0.00829	kmol s <sup>-1</sup>
Molar flow 15, H <sub>2</sub>	$\dot{n}_{15,CH_4} = \dot{n}_{14,CH_4} (1 - \eta_{CH_4,conversion})$	$\dot{n}_{15,CH_4} = (0.00146)(1 - 0.65)$	0.00051	0.00051	kmol s <sup>-1</sup>
Molar flow 15, CH <sub>4</sub>	$(\dot{n}_{15,H_2})(\eta_{H_2,recov}) = \dot{n}_{22,H_2}$	$(\dot{n}_{15,H_2})(0.90) = 0.00380$	0.00423	0.00422	kmol s <sup>-1</sup>
Molar flow 15, H <sub>2</sub> O	$\dot{n}_{15,H_2O} = \dot{n}_{14,H_2O} - (2)(\eta_{CH_4,conv})(\dot{n}_{14,CH_4})$	$\dot{n}_{15,H_2O} = (0.00439) - (2)(0.65)(0.00146)$	0.00249	0.00249	kmol s <sup>-1</sup>
Molar flow 15, CO <sub>2</sub>	$\dot{n}_{15,CO_2} = \dot{n}_{14,CO_2} + (1)(\eta_{CH_4,conv})(\dot{n}_{14,CH_4})$	$\dot{n}_{15,CO_2} = (0.00011) + (1)(0.65)(0.00146)$	0.00106	0.00106	kmol s <sup>-1</sup>
Mole fractions 15	$y_{i,H_2} = \frac{\dot{n}_{i,H_2}}{\dot{n}_{i,total}}$	$y_{i,H_2} = \frac{0.00423}{0.00828}$	0.510	0.511	--
“ ”	$y_{i,CH_4} = \frac{\dot{n}_{i,CH_4}}{\dot{n}_{i,total}}$	$y_{i,CH_4} = \frac{0.00051}{0.00828}$	0.062	0.062	--
“ ”	$y_{i,H_2O} = \frac{\dot{n}_{i,H_2O}}{\dot{n}_{i,total}}$	$y_{i,H_2O} = \frac{0.00249}{0.00828}$	0.300	0.301	--
“ ”	$y_{i,CO_2} = \frac{\dot{n}_{i,CO_2}}{\dot{n}_{i,total}}$	$y_{i,CO_2} = \frac{0.00106}{0.00828}$	0.128	0.128	--
Enthalpy 15	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 79.8 - 29.5 - 561.1 - 399.6 + 0 + 0$	-909.6	-910.5	kW
Enthalpy 15, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{f,i,H_2})$	$\dot{H}_{i,H_2} = (0.00828)(0.510)(18,897+0)$	79.8	79.8	kW

Enthalpy 15, CH <sub>4</sub>	$\dot{H}_{i,\text{CH}_4} = (\dot{n}_{i,\text{total}})(y_{i,\text{CH}_4})(h_{i,\text{CH}_4} + h_{f,i,\text{CH}_4})$	$\dot{H}_{i,\text{CH}_4} = (0.00828)(0.062)(17,166 - 74,595)$	-29.5	-29.5	kW
Enthalpy 15, H <sub>2</sub> O	$\dot{H}_{i,\text{H}_2\text{O}} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2\text{O}})(h_{i,\text{H}_2\text{O}} + h_{f,i,\text{H}_2\text{O}})$	$\dot{H}_{i,\text{H}_2\text{O}} = (0.00828)(0.300)(59,911 - 285,813)$	-561.1	-561.1	kW
Enthalpy 15, CO <sub>2</sub>	$\dot{H}_{i,\text{CO}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{CO}_2})(h_{i,\text{CO}_2} + h_{f,i,\text{CO}_2})$	$\dot{H}_{i,\text{CO}_2} = (0.00828)(0.128)(16,421 - 393,486)$	-399.6	-399.6	kW
Molar flow 16	$\dot{n}_{i,\text{total}} = \dot{n}_{i,\text{H}_2} + \dot{n}_{i,\text{CH}_4} + \dot{n}_{i,\text{H}_2\text{O}} + \dot{n}_{i,\text{CO}_2} + \dot{n}_{i,\text{N}_2} + \dot{n}_{i,\text{O}_2}$	$\dot{n}_{i,\text{total}} = (0.00042) + (0.00051) + (0.00249) + (0.00106) + 0 + 0$	0.00448	0.00448	kmol s <sup>-1</sup>
Molar flow 16, H <sub>2</sub>	$\dot{n}_{16,\text{H}_2} = \dot{n}_{15,\text{H}_2} - \dot{n}_{22,\text{H}_2}$	$\dot{n}_{16,\text{H}_2} = 0.00423 - 0.00380$	0.00042	0.00043	kmol s <sup>-1</sup>
Mole fractions 16	$y_{i,\text{H}_2} = \frac{\dot{n}_{i,\text{H}_2}}{\dot{n}_{i,\text{total}}}$	$y_{i,\text{H}_2} = \frac{0.00042}{0.00448}$	0.094	0.094	--
“ ”	$y_{i,\text{CH}_4} = \frac{\dot{n}_{i,\text{CH}_4}}{\dot{n}_{i,\text{total}}}$	$y_{i,\text{CH}_4} = \frac{0.00051}{0.00448}$	0.114	0.114	--
“ ”	$y_{i,\text{H}_2\text{O}} = \frac{\dot{n}_{i,\text{H}_2\text{O}}}{\dot{n}_{i,\text{total}}}$	$y_{i,\text{H}_2\text{O}} = \frac{0.00249}{0.00448}$	0.555	0.556	--
“ ”	$y_{i,\text{CO}_2} = \frac{\dot{n}_{i,\text{CO}_2}}{\dot{n}_{i,\text{total}}}$	$y_{i,\text{CO}_2} = \frac{0.00106}{0.00448}$	0.236	0.237	--
Enthalpy 16	$\dot{H}_i = \dot{H}_{i,\text{H}_2} + \dot{H}_{i,\text{CH}_4} + \dot{H}_{i,\text{H}_2\text{O}} + \dot{H}_{i,\text{CO}_2} + \dot{H}_{i,\text{N}_2} + \dot{H}_{i,\text{O}_2}$	$\dot{H}_i = 8.0 - 29.3 - 561.9 - 398.7 + 0 + 0$	-981.7	-982.0	kW
Enthalpy 16, H <sub>2</sub>	$\dot{H}_{i,\text{H}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2})(h_{i,\text{H}_2} + h_{f,i,\text{H}_2})$	$\dot{H}_{i,\text{H}_2} = (0.00448)(0.094)(18,887 + 0)$	8.0	8.0	kW
Enthalpy 16, CH <sub>4</sub>	$\dot{H}_{i,\text{CH}_4} = (\dot{n}_{i,\text{total}})(y_{i,\text{CH}_4})(h_{i,\text{CH}_4} + h_{f,i,\text{CH}_4})$	$\dot{H}_{i,\text{CH}_4} = (0.00448)(0.114)(17,164 - 74,595)$	-29.3	-29.3	kW
Enthalpy 16, H <sub>2</sub> O	$\dot{H}_{i,\text{H}_2\text{O}} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2\text{O}})(h_{i,\text{H}_2\text{O}} + h_{f,i,\text{H}_2\text{O}})$	$\dot{H}_{i,\text{H}_2\text{O}} = (0.00448)(0.555)(59,814 - 285,813)$	-561.9	-561.9	kW
Enthalpy 16, CO <sub>2</sub>	$\dot{H}_{i,\text{CO}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{CO}_2})(h_{i,\text{CO}_2} + h_{f,i,\text{CO}_2})$	$\dot{H}_{i,\text{CO}_2} = (0.00448)(0.236)(16,410 - 393,486)$	-398.7	-398.7	kW
Temperature 17	$T_{17} = T_6 + CAT_{\text{HE}}$	$T_{17} = 15 + 5$	20	20	°C
Enthalpy 17	$\dot{H}_i = \dot{H}_{i,\text{H}_2} + \dot{H}_{i,\text{CH}_4} + \dot{H}_{i,\text{H}_2\text{O}} + \dot{H}_{i,\text{CO}_2} + \dot{H}_{i,\text{N}_2} + \dot{H}_{i,\text{O}_2}$	$\dot{H}_i = 303 - 38.2 - 702.2 - 416.4 + 0 + 0$	-1,153.3	-1,153.5	kW
Enthalpy 17, H <sub>2</sub>	$\dot{H}_{i,\text{H}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2})(h_{i,\text{H}_2} + h_{f,i,\text{H}_2})$	$\dot{H}_{i,\text{H}_2} = (0.00448)(0.094)(7,782 + 0)$	3.3	3.3	kW
Enthalpy 17, CH <sub>4</sub>	$\dot{H}_{i,\text{CH}_4} = (\dot{n}_{i,\text{total}})(y_{i,\text{CH}_4})(h_{i,\text{CH}_4} + h_{f,i,\text{CH}_4})$	$\dot{H}_{i,\text{CH}_4} = (0.00448)(0.114)(-205.5 - 74,595)$	-38.2	-38.2	kW

Enthalpy 17, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.00448)(0.555)(3408 - 285,813)$	-702.2	-702.2	kW
Enthalpy 17, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00448)(0.236)(-336.1 - 393,486)$	-416.4	-416.4	kW
Molar flow 18	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = (0.00042) + (0.00051) + 0 + (0.00106) + 0 + 0$	0.00199	0.00199	kmol s <sup>-1</sup>
Mole fractions 18	$y_{i,H_2} = \frac{\dot{n}_{i,H_2}}{\dot{n}_{i,total}}$	$y_{i,H_2} = \frac{0.00042}{0.00199}$	0.212	0.211	--
“ ”	$y_{i,CH_4} = \frac{\dot{n}_{i,CH_4}}{\dot{n}_{i,total}}$	$y_{i,CH_4} = \frac{0.00051}{0.00199}$	0.257	0.256	--
“ ”	$y_{i,CO_2} = \frac{\dot{n}_{i,CO_2}}{\dot{n}_{i,total}}$	$y_{i,CO_2} = \frac{0.00106}{0.00199}$	0.531	0.533	--
Enthalpy 18	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 3.3 - 38.2 + 0 - 416.4 + 0 + 0$	-451.6	-451.0	kW
Enthalpy 18, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{fi,H_2})$	$\dot{H}_{i,H_2} = (0.00199)(0.212)(7,928 + 0)$	3.3	3.3	kW
Enthalpy 18, CH <sub>4</sub>	$\dot{H}_{i,CH_4} = (\dot{n}_{i,total})(y_{i,CH_4})(h_{i,CH_4} + h_{fi,CH_4})$	$\dot{H}_{i,CH_4} = (0.00199)(0.257)(-60.29 - 74,595)$	-38.2	-38.2	kW
Enthalpy 18, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00199)(0.531)(-334.3 - 393,486)$	-416.1	-416.1	kW
Molar flow 19, CO <sub>2</sub>	$\dot{n}_{19,CO_2} = (\eta_{CO_2,sep})(\dot{n}_{18,CO_2})$	$\dot{n}_{19,CO_2} = (0.90)(0.00106)$	0.00095	0.00095	kmol s <sup>-1</sup>
Enthalpy 19	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 - 392.5 + 0 + 0$	-392.5	-392.2	kW
Enthalpy 19, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00095)(1)(-19,319 - 393,486)$	-392.5	-392.2	kW
Enthalpy 20	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 - 392.1 + 0 + 0$	-392.1	-392.1	kW
Enthalpy 20, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00095)(1)(-19,237 - 393,486)$	-392.1	-392.1	kW
Mass flow, CO <sub>2</sub> export	$\dot{m}_{CO_2,export} = (\dot{n}_{20,CO_2})(M_{CO_2})$	$\dot{m}_{CO_2,export} = (0.00095)(44.01)$	0.04184	0.04184	kg s <sup>-1</sup>
Molar flow 21	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = 0.00042 + 0.00051 + 0 + 0.00011 + 0 + 0$	0.00104	0.00104	kmol s <sup>-1</sup>
Molar flow 21, CO <sub>2</sub>	$\dot{n}_{21,CO_2} = \dot{n}_{18,CO_2} - \dot{n}_{19,CO_2}$	$\dot{n}_{21,CO_2} = 0.00106 - 0.00095$	0.00011	0.00011	kmol s <sup>-1</sup>
Enthalpy 21	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 - 392.1 + 0 + 0$	-76.8	-77.0	kW

Enthalpy 21, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{fi,H_2})$	$\dot{H}_{i,H_2} = (0.00199)(0.212)(7,928 + 0)$	3.2	3.2	kW
Enthalpy 21, CH <sub>4</sub>	$\dot{H}_{i,CH_4} = (\dot{n}_{i,total})(y_{i,CH_4})(h_{i,CH_4} + h_{fi,CH_4})$	$\dot{H}_{i,CH_4} = (0.00199)(0.257)(-60.29 - 74,595)$	-38.4	-38.4	kW
Enthalpy 21, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00199)(0.531)(-334.3 - 393,486)$	-41.8	-41.8	kW
Molar flow 22	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = 0.00380 + 0 + 0.00146 + 0 + 0 + 0$	0.00527	0.00526	kmol s <sup>-1</sup>
Enthalpy 22	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 - 392.1 + 0 + 0$	-258.5	-258.9	kW
Enthalpy 22, H <sub>2</sub>	$\dot{H}_{i,H_2} = (\dot{n}_{i,total})(y_{i,H_2})(h_{i,H_2} + h_{fi,H_2})$	$\dot{H}_{i,H_2} = (0.00527)(0.722)(18,887 + 0)$	71.9	71.9	kW
Enthalpy 22, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.00527)(0.278)(60,011 - 285,813)$	-330.8	-330.8	kW
Molar flow 23	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = 0 + 0 + 0 + 0 + 0.00715 + 0.00190$	0.00905	0.00905	kmol s <sup>-1</sup>
Molar flow 23, O <sub>2</sub>	$\dot{n}_{23,O_2} = (0.5)(\dot{n}_{22,H_2})$	$\dot{n}_{23,O_2} = (0.5)(0.00380)$	0.00190	0.00190	kmol s <sup>-1</sup>
Molar flow 23, N <sub>2</sub>	$\dot{n}_{23,N_2} = \frac{y_{23,N_2}}{y_{23,O_2}}(\dot{n}_{23,O_2})$	$\dot{n}_{23,N_2} = \frac{0.79}{0.21}(0.00190)$	0.00715	0.00715	kmol s <sup>-1</sup>
Enthalpy 23	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 + 0 + 122.6 + 0.0$	122.1	122.6	kW
Enthalpy 23, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.00199)(0.212)(7,928 + 0)$	122.6	122.6	kW
Enthalpy 23, O <sub>2</sub>	$\dot{H}_{i,O_2} = (\dot{n}_{i,total})(y_{i,O_2})(h_{i,O_2} + h_{fi,O_2})$	$\dot{H}_{i,O_2} = (0.00199)(0.257)(-60.29 - 0)$	0.0	0.0	kW
Molar flow 24	$\dot{n}_{i,total} = \dot{n}_{i,H_2} + \dot{n}_{i,CH_4} + \dot{n}_{i,H_2O} + \dot{n}_{i,CO_2} + \dot{n}_{i,N_2} + \dot{n}_{i,O_2}$	$\dot{n}_{i,total} = 0 + 0 + 0.00527 + 0 + 0.00715 + 0$	0.01242	0.01242	kmol s <sup>-1</sup>
Molar flow 24, H <sub>2</sub> O	$\dot{n}_{24,H_2O} = (1)(\dot{n}_{22,H_2}) + \dot{n}_{22,H_2O}$	$\dot{n}_{24,H_2O} = (1)(0.00380) + 0.00146$	0.00527	0.00526	kmol s <sup>-1</sup>
Mole fractions 24	$y_{i,H_2O} = \frac{\dot{n}_{i,H_2O}}{\dot{n}_{i,total}}$	$y_{i,H_2O} = \frac{0.00527}{0.01242}$	0.424	0.424	--
“ ”	$y_{i,N_2} = \frac{\dot{n}_{i,N_2}}{\dot{n}_{i,total}}$	$y_{i,N_2} = \frac{0.00715}{0.01242}$	0.576	0.576	--
Enthalpy 24	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,090.2 + 0 + 320.9 + 0.0$	-769.3	-769.4	kW
Enthalpy 24, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(78,781 - 285,813)$	-1,090.2	-1,090.2	kW

Enthalpy 24, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(44,853 + 0)$	320.9	320.9	kW
Enthalpy 25	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,183.2 + 0 + 215.9 + 0$	-967.3	-967.3	kW
Enthalpy 25, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(61,132 - 285,813)$	-1,183.2	-1,183.2	kW
Enthalpy 25, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(30,174 + 0)$	215.9	215.9	kW
Temperature 26	$T_{26} = T_{14} + CAT$	$T_{26} = 400 + 5$	405	405	°C
Enthalpy 26	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,188.1 + 0 + 210.1 + 0$	-978.0	-978.1	kW
Enthalpy 26, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(60,192 - 285,813)$	-1,188.1	-1,188.1	kW
Enthalpy 26, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(29,362 + 0)$	210.1	210.1	kW
Enthalpy 27	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,212.2 + 0 + 181.6 + 0$	-1,030.5	-1,030.6	kW
Enthalpy 27, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(55,627 - 285,813)$	-1,212.2	-1,212.2	kW
Enthalpy 27, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(25,384 + 0)$	181.6	181.6	kW
Enthalpy 28	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,218.6 + 0 + 174.0 + 0$	-1,044.5	-1,044.6	kW
Enthalpy 28, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(54,414 - 285,813)$	-1,218.6	-1,218.6	kW
Enthalpy 28, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(24,319 + 0)$	174.0	174.0	kW
Enthalpy 29	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - x + 0 + x + 0$	-1,363.4	-1,363.5	kW
Enthalpy 29, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(3,396 - 285,813)$	-1,487.2	-1,487.2	kW
Enthalpy 29, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(17,302 + 0)$	123.8	123.8	kW
Enthalpy 30	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 + 0 + 122.6 + 0$	122.7	122.6	kW
Enthalpy 30, N <sub>2</sub>	$\dot{H}_{i,N_2} = (\dot{n}_{i,total})(y_{i,N_2})(h_{i,N_2} + h_{fi,N_2})$	$\dot{H}_{i,N_2} = (0.01242)(0.576)(17,152 + 0)$	122.6	122.6	kW
Enthalpy 31	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,490.3 + 0 + 0 + 0$	-1,489.1	-1,490.3	kW
Enthalpy 31, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(3,020 - 285,813)$	-1,490.3	-1,490.3	kW

Enthalpy 32	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 1,490.3 + 0 + 0 + 0$	-703.2	-704.2	kW
Enthalpy 32, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01242)(0.424)(3,020 - 285,813)$	-704.2	-704.2	kW

## A.2. Energy Balance Calculation

**Table A-4:** Hand calculations versus EES results to verify energy balance parameters.

Parameter	Equation	Evaluated	EES Calc. Value	Hand Calc. Value	Units
Ambient enthalpy 9	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 4,892.3 + 0 + 0 + 0$	-4,891.1	-4,892.3	kW
Ambient enthalpy 9, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.01730)(1)(3,020 - 285,813)$	-4,892.3	-4,892.3	kW
Heat to export steam	$\dot{Q}_{steam,export} = \dot{H}_9 - \dot{H}_{9,amb}$	$\dot{Q}_{steam,export} = (-4,051.3) - (-4,891.1)$	839.8	839.8	kW
Enthalpy of NG, available	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 - 71.2 + 0 + 0 + 0 - 0.7$	-72.0	-72.1	kW
“ “, CH <sub>4</sub>	$\dot{H}_{i,CH_4} = (\dot{n}_{i,total})(y_{i,CH_4})(h_{i,CH_4} + h_{fi,CH_4})$	$\dot{H}_{i,CH_4} = (0.00285)(0.333)(-438.4 - 74.595)$	-71.2	-71.2	kW
“ “, O <sub>2</sub>	$\dot{H}_{i,O_2} = (\dot{n}_{i,total})(y_{i,O_2})(h_{i,O_2} + h_{fi,O_2})$	$\dot{H}_{i,O_2} = (0.00285)(0.333)(-369 + 0)$	-0.7	-0.7	kW
Enthalpy of NG, combusted	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 - 537.6 - 373.9 + 0 + 0$	-912.2	-911.5	kW
“ “, H <sub>2</sub> O	$\dot{H}_{i,H_2O} = (\dot{n}_{i,total})(y_{i,H_2O})(h_{i,H_2O} + h_{fi,H_2O})$	$\dot{H}_{i,H_2O} = (0.00285)(0.667)(3,030 - 285,813)$	-537.6	-537.6	kW
“ “, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00285)(0.333)(-531.7 - 393,486)$	-373.9	-373.9	kW
Heat of NG in	$\dot{Q}_{NG,in} = \dot{H}_{NG,in} - \dot{H}_{NG,out}$	$\dot{Q}_{NG,in} = (-72.0) - (-912.2)$	840.2	840.2	kW
Electricity input	$\dot{W}_{elec} = \dot{W}_{CO_2,comp,in} + \dot{W}_{CO_2,cryo,in} + \dot{W}_{pump,in}$	$\dot{W}_{elec} = 0.09 + 17.78 + 0.61$	18.48	18.48	kW
Ambient enthalpy 20	$\dot{H}_i = \dot{H}_{i,H_2} + \dot{H}_{i,CH_4} + \dot{H}_{i,H_2O} + \dot{H}_{i,CO_2} + \dot{H}_{i,N_2} + \dot{H}_{i,O_2}$	$\dot{H}_i = 0 + 0 + 0 - 374.5 + 0 + 0$	-374.5	-374.2	kW
Ambient enthalpy 20, CO <sub>2</sub>	$\dot{H}_{i,CO_2} = (\dot{n}_{i,total})(y_{i,CO_2})(h_{i,CO_2} + h_{fi,CO_2})$	$\dot{H}_{i,CO_2} = (0.00199)(0.531)(-334.3 - 393,486)$	-374.5	-374.2	kW
Heat of CO <sub>2</sub> export	$\dot{Q}_{CO_2,export} = \dot{H}_{20} - \dot{H}_{20,amb}$	$\dot{Q}_{CO_2,export} = (-392.4) - (-374.5)$	-17.9	-17.9	kW
Efficiency, overall system	$\eta_{overall,system} = \frac{\dot{Q}_{steam,export}}{\dot{Q}_{NG,in} + \dot{W}_{elec,in}}$	$\eta_{overall,system} = \frac{839.8}{840.2 + 18.48}$	0.9781	0.97801	--

Efficiency, overall boiler	$\eta_{\text{overall,boiler}} = \frac{\dot{Q}_{\text{steam,export}} +  \dot{Q}_{\text{CO}_2,\text{export}} }{\dot{Q}_{\text{NG,in}} + \dot{W}_{\text{elec,in}}}$	$\eta_{\text{overall,boiler}} = \frac{839.8 +  -17.9 }{840.2 + 18.48}$	0.9989	0.99886	--
Enthalpy 11, before pressure drop	$\dot{H}_i = \dot{H}_{i,\text{H}_2} + \dot{H}_{i,\text{CH}_4} + \dot{H}_{i,\text{H}_2\text{O}} + \dot{H}_{i,\text{CO}_2} + \dot{H}_{i,\text{N}_2} + \dot{H}_{i,\text{O}_2}$	$\dot{H}_{11,\text{highP}} = 0 + 0 - 341.1 + 0 + 0 + 0$	-342.6	-342.0	kW
Enthalpy 11, H <sub>2</sub> O, before pressure drop	$\dot{H}_{i,\text{H}_2\text{O}} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2\text{O}})(h_{i,\text{H}_2\text{O}} + h_{\text{fi},\text{H}_2\text{O}})$	$\dot{H}_{i,\text{H}_2\text{O}} = (0.00146)(1)(51,577 - 285,813)$	-342.6	-342.0	kW
Heat lost in pressure drop of 11	$\dot{Q}_{11,\Delta P} = \dot{H}_{11,\text{highP}} - \dot{H}_{11}$	$\dot{Q}_{11,\Delta P} = (-342.6) - (-341.1)$	-1.53	-1.5	kW
Boiler heat to steam	$\dot{Q}_{\text{boiler,steam}} = \dot{H}_8 - \dot{H}_7$	$\dot{Q}_{\text{boiler,steam}} = (-5,421.8) - (-6,054.8)$	633.02	633.00	kW
Boiler input (fuel) heat	$(\dot{Q}_{\text{boiler,input}})(\eta_{\text{boiler}}) = \dot{Q}_{\text{boiler,steam}}$	$(\dot{Q}_{\text{boiler,input}})(0.5146) = 633.02$	1,230.12	1,230.12	kW
Boiler input (fuel) heat	$\dot{Q}_{\text{boiler,input}} = \dot{H}_{22} + \dot{H}_{23} - \dot{H}_{24,\text{amb}}$	$1,230.12 = \dot{H}_{22} + (122.1) - (-1,366.4)$	-258.5	-258.38	kW
Ambient enthalpy 24	$\dot{H}_i = \dot{H}_{i,\text{H}_2} + \dot{H}_{i,\text{CH}_4} + \dot{H}_{i,\text{H}_2\text{O}} + \dot{H}_{i,\text{CO}_2} + \dot{H}_{i,\text{N}_2} + \dot{H}_{i,\text{O}_2}$	$\dot{H}_i = 0 + 0 - 1,488.0 + 0 + 122.6 + 0$	-1,366.4	-1,365.4	kW
Ambient enthalpy 24, H <sub>2</sub> O	$\dot{H}_{i,\text{H}_2\text{O}} = (\dot{n}_{i,\text{total}})(y_{i,\text{H}_2\text{O}})(h_{i,\text{H}_2\text{O}} + h_{\text{fi},\text{H}_2\text{O}})$	$\dot{H}_{i,\text{H}_2\text{O}} = (0.01730)(1)(3,020 - 285,813)$	-1,488.0	-1,488.0	kW
Ambient enthalpy 24, N <sub>2</sub>	$\dot{H}_{i,\text{N}_2} = (\dot{n}_{i,\text{total}})(y_{i,\text{N}_2})(h_{i,\text{N}_2} + h_{\text{fi},\text{N}_2})$	$\dot{H}_{i,\text{N}_2} = (0.01242)(0.576)(24,319 + 0)$	122.6	122.6	kW
Boiler heat to steam	$\dot{Q}_{\text{boiler,steam}} = \dot{H}_{22} + \dot{H}_{23} - \dot{H}_{24}$	$\dot{Q}_{\text{boiler,steam}} = (-258.5) + (122.1) - (-769.3)$	633.02	632.9	kW
Boiler heat to exhaust	$\dot{Q}_{\text{boiler,exh}} = \dot{Q}_{\text{boiler,input}} - \dot{Q}_{\text{boiler,steam}}$	$\dot{Q}_{\text{boiler,exh}} = (1,230.12) - (633.02)$	597.1	597.1	kW
Heat exchanger 1, cold side	$\dot{Q}_{\text{HE1}} = \dot{H}_{22} + \dot{H}_{16} - \dot{H}_{14} - \dot{H}_{12}$	$\dot{Q}_{\text{HE1}} = (-258.5) + (-981.7) - (-1,107.8) - (-330.3)$	197.9	197.9	kW
Heat exchanger 1, hot side	$\dot{Q}_{\text{HE1}} = \dot{H}_{24} - \dot{H}_{25}$	$\dot{Q}_{\text{HE1}} = (-769.3) - (-967.3)$	197.9	198	kW
Heat exchanger 2, cold side	$\dot{Q}_{\text{HE2}} = \dot{H}_{12} - \dot{H}_{11}$	$\dot{Q}_{\text{HE2}} = (-330.3) - (-341.1)$	10.75	10.8	kW

Heat exchanger 2, hot side	$\dot{Q}_{HE2} = \dot{H}_{25} - \dot{H}_{26}$	$\dot{Q}_{HE2} = (-967.3) - (-978.0)$	10.75	10.7	kW
Heat exchanger 3, cold side	$\dot{Q}_{HE3} = \dot{H}_{14} - \dot{H}_{13}$	$\dot{Q}_{HE3} = (-1,107.8) - (-1,160.3)$	52.5	52.5	kW
Heat exchanger 3, hot side	$\dot{Q}_{HE3} = \dot{H}_{26} - \dot{H}_{27}$	$\dot{Q}_{HE3} = (-978.0) - (-1,030.5)$	52.5	52.5	kW
Heat exchanger 4, cold side	$\dot{Q}_{HE4} = \dot{H}_3 - \dot{H}_2$	$\dot{Q}_{HE4} = (-134.3) - (-148.3)$	13.99	14.0	kW
Heat exchanger 4, hot side	$\dot{Q}_{HE4} = \dot{H}_{27} - \dot{H}_{28}$	$\dot{Q}_{HE4} = (-1,030.5) - (-1,044.5)$	13.99	14.0	kW
Heat exchanger 5, cold side	$\dot{Q}_{HE5} = \dot{H}_7 - \dot{H}_6$	$\dot{Q}_{HE5} = (-6,054.8) - (-6,545.2)$	490.4	490.4	kW
Heat exchanger 5, retentate	$\dot{Q}_{HE5,ret} = \dot{H}_{16} - \dot{H}_{17}$	$\dot{Q}_{HE5,ret} = (-981.7) - (-1,153.3)$	171.5	171.6	kW
Heat exchanger 5, boiler exhaust	$\dot{Q}_{HE5,exh} = \dot{H}_{28} - \dot{H}_{29}$	$\dot{Q}_{HE5,exh} = (-1,044.5) - (-1,363.4)$	318.9	318.9	kW
Heat exchanger 5, hot side	$\dot{Q}_{HE5} = \dot{Q}_{HE5,ret} + \dot{Q}_{HE5,exh}$	$\dot{Q}_{HE5} = 171.5 + 318.9$	490.4	490.4	kW
Heat exchanger 6	$\dot{Q}_{HE6} = \dot{H}_{18} + \dot{H}_{32} - \dot{H}_{17}$	$\dot{Q}_{HE6} = (-451.6) + (-703.2) - (-1,153.3)$	-1.552	-1.5	kW
Heat exchanger 7	$\dot{Q}_{HE7} = \dot{H}_{30} + \dot{H}_{31} - \dot{H}_{29}$	$\dot{Q}_{HE7} = (122.7) + (-1,489.1) - (-1,363.4)$	-3.056	-3.0	kW
Work, CO <sub>2</sub> compressor, to fluid	$\dot{W}_{CO_2,comp,out} = \dot{H}_{20} - \dot{H}_{19}$	$\dot{W}_{CO_2,comp,out} = (-392.4) - (-392.5)$	0.078	0.1	kW
Work, CO <sub>2</sub> compressor, electricity in	$(\dot{W}_{CO_2,comp,in})(\eta_{CO_2,comp}) = \dot{W}_{CO_2,comp,out}$	$(\dot{W}_{CO_2,comp,in})(0.85) = 0.078$	0.0914	0.092	kW
Work, CO <sub>2</sub> cryo, to fluid	$\dot{W}_{CO_2,cryo,out} = \dot{H}_{18} - \dot{H}_{19} - \dot{H}_{21}$	$\dot{W}_{CO_2,cryo,in} = (-451.6) - (-392.5) - (-76.8)$	17.78	17.7	kW

Work, CO <sub>2</sub> cryo, electricity in	$\dot{W}_{\text{CO}_2, \text{cryo}, \text{in}} = (425 \text{ kJ kg}^{-1})(\dot{n}_{19, \text{CO}_2})(M_{\text{CO}_2})$	$\dot{W}_{\text{CO}_2, \text{cryo}, \text{out}} = (425)(0.00095)(44.01)$	17.78	17.77	kW
Work, water pump, to fluid	$\dot{W}_{\text{pump}, \text{out}} = \dot{H}_6 - \dot{H}_5$	$\dot{W}_{\text{pump}, \text{out}} = (-6,545.2) - (-6,545.7)$	0.5171	0.5	kW
Work, water pump, electricity in	$(\dot{W}_{\text{pump}, \text{in}})(\eta_{\text{pump}}) = \dot{W}_{\text{pump}, \text{out}}$	$(\dot{W}_{\text{pump}, \text{in}})(0.85) = 0.5171$	0.6084	0.6084	kW

### A.3. Capital and Operating Cost Calculation

**Table A-5:** Hand calculations versus EES results to verify capital and operating costs.

Parameter	Equation	Evaluated	EES Calc. Value	Hand Calc. Value	Units
Membrane permeance	$K_{\text{mem}} = (6.48 \times 10^{-3} \text{ mol m}^{-2} \text{ s}^{-1} \text{ Pa}^{-0.5}) \left( \frac{2.8 \times 10^{-6} \text{ m}}{t_{\text{mem}}} \right)$	$K_{\text{mem}} = (6.48 \times 10^{-3}) \left( \frac{2.8 \times 10^{-6}}{2.8 \times 10^{-6}} \right)$	6.48x10 <sup>-3</sup>	6.48x10 <sup>-3</sup>	mol m <sup>-2</sup> s <sup>-1</sup> Pa <sup>-0.5</sup>
Retentate H <sub>2</sub> partial pressure	$P_{\text{H}_2, \text{ret}} = (P_{15})(y_{15, \text{H}_2}) \left( \text{bar} \frac{100,000 \text{ Pa}}{\text{bar}} \right)$	$P_{\text{H}_2, \text{ret}} = (15)(0.510)(100,000)$	765,456	765,000	Pa
Permeate H <sub>2</sub> partial pressure	$P_{\text{H}_2, \text{per}} = (P_{22})(y_{22, \text{H}_2}) \left( \text{bar} \frac{100,000 \text{ Pa}}{\text{bar}} \right)$	$P_{\text{H}_2, \text{per}} = (2)(0.722)(100,000)$	144,444	144,400	Pa
Membrane surface area	$\dot{n}_{22, \text{H}_2} \left( \frac{\text{kmol}}{\text{s}} \frac{1000 \text{ mol}}{\text{kmol}} \right) = (K_{\text{mem}})(A_{\text{mem}}) \left( P_{\text{H}_2, \text{ret}}^{0.5} - P_{\text{H}_2, \text{per}}^{0.5} \right)$	$(0.00380)(1000) = (6.48 \times 10^{-6})(A_{\text{mem}}) \left( 765,456^{0.5} - 144,444^{0.5} \right)$	1.186	1.185	m <sup>2</sup>
Cost, HE1, membrane	$C_{\text{HE1}, \text{membrane}} = (\$1,076)(A_{\text{membrane}})$	$C_{\text{HE1}, \text{membrane}} = (1,076)(1.186)$	1,276	1,276	\$
Mass flow 22, H <sub>2</sub>	$\dot{m}_{22, \text{H}_2} = (\dot{n}_{22, \text{H}_2})(M_{\text{H}_2})$	$\dot{m}_{22, \text{H}_2} = (0.00380)(2.002)$	0.007667	0.00761	kg s <sup>-1</sup>
Cost, HE1, reactor	$C_{\text{HE1}, \text{reactor}} = (\$14,100) \left( \frac{\dot{m}_{22, \text{H}_2} \frac{3600 \text{ s}}{\text{h}}}{4.79 \frac{\text{kg}}{\text{h}}} \right)^{0.7}$	$C_{\text{HE1}, \text{reactor}} = (14,100) \left( \frac{(0.007667)(3600)}{4.79} \right)^{0.7}$	48,043	48,043	\$
Cost, HE1, total	$C_{\text{HE1}, \text{total}} = C_{\text{HE1}, \text{membrane}} + C_{\text{HE1}, \text{reactor}}$	$C_{\text{HE1}, \text{total}} = 12,76 + 48,043$	49,319	49,319	\$
Cost HE2	$C_{\text{HE2}} = (\$462) \left( A_{\text{ht}, \text{HE2}} \frac{10.76 \text{ ft}^2}{\text{m}^2} \right)^{0.5}$	$C_{\text{HE2}} = (\$462) (22.73 \cdot 10.76)^{0.5}$	7,226	7,225	\$

Cost HE3	$C_{HE,i} = (\$462) \left( A_{ht,HE,i} \frac{10.76 \text{ ft}^2}{\text{m}^2} \right)^{0.5}$	$C_{HE,i} = (\$462) (22.5 \cdot 10.76)^{0.5}$	7,190	7,188	\$
Cost HE4	$C_{HE,i} = (\$462) \left( A_{ht,HE,i} \frac{10.76 \text{ ft}^2}{\text{m}^2} \right)^{0.5}$	$C_{HE,i} = (\$462) (13.17 \cdot 10.76)^{0.5}$	5,501	5,500	\$
Cost HE5, preheating	$C_{HE,i} = (\$462) \left( A_{ht,HE,i} \frac{10.76 \text{ ft}^2}{\text{m}^2} \right)^{0.5}$	$C_{HE,i} = (\$462) (12.21 \cdot 10.76)^{0.5}$	5,297	5,295	\$
Cost HE5, boiling	$C_{HE,i} = (\$462) \left( A_{ht,HE,i} \frac{10.76 \text{ ft}^2}{\text{m}^2} \right)^{0.5}$	$C_{HE,i} = (\$462) (9.975 \cdot 10.76)^{0.5}$	4,787	4,786	\$
Cost HE5	$C_{HE5,total} = (1.5) (C_{HE5,preheat} + C_{HE5,boil})$	$C_{HE5,total} = (1.5) (5,297 + 4,787)$	15,126	15,126	\$
Cost, water pump	$C_{\text{pump}} = (\$1,200) \left( \frac{\dot{V}_{5,H_2O}}{90 \frac{L}{h}} \right)^{0.7}$	$C_{\text{pump}} = (1,200) \left( \frac{1,503}{90} \right)^{0.7}$	8,610	8,612	\$
Volumetric flow, water pump	$\dot{V}_{5,H_2O} = (\dot{n}_{5,H_2O}) (vol_{\text{water}}) \left( \frac{1000 L}{\text{m}^3} \cdot \frac{3600 s}{h} \right)$	$\dot{V}_{5,H_2O} = (0.02315) (0.01803) (1000 \cdot 3600)$	1,503	1,503	L h <sup>-1</sup>
Cost, CO <sub>2</sub> compressor	$C_{CO_2,comp} = (\$3,000) \left( \frac{\dot{W}_{CO_2,comp,in}}{6 \text{ kW}} \right)^{0.7}$	$C_{CO_2,comp} = (3,000) \left( \frac{0.0914}{6} \right)^{0.7}$	160	160	\$
Cost, condenser, HE6	$C_{HE6} = (\$3.75 \cdot 213) \left(  \dot{Q}_{HE6}  \right)^{0.38}$	$C_{HE6} = (3.75) (213) (1.552)^{0.38}$	939.9	944.0	\$
Cost, condenser, HE7	$C_{HE7} = (\$3.75 \cdot 213) \left(  \dot{Q}_{HE7}  \right)^{0.38}$	$C_{HE7} = (3.75) (213) (3.056)^{0.38}$	1,221	1,221	\$
Cost, boiler	$C_{\text{boiler,SMR system}} = (\$44,000) \left( \frac{\dot{Q}_{\text{boiler,input}}}{2000 \text{ kW}} \right)^{0.67}$	$C_{\text{boiler,SMR system}} = (44,000) \left( \frac{1,230.12}{2,000} \right)^{0.67}$	31,771	31,771	\$
Cost, CO <sub>2</sub> cryo separator	$C_{CO_2,cryo} = (\$475,000) \left( \frac{\dot{m}_{CO_2,export,SMR}}{0.6 \frac{\text{ton}}{h}} \right)^{0.7}$	$C_{CO_2,cryo} = (475,000) \left( \frac{0.116}{0.6} \right)^{0.7}$	193,262	193,225	\$
Mass flow, CO <sub>2</sub> export, SMR	$\dot{m}_{CO_2,export,SMR} = \left( \dot{m}_{CO_2,export,SMR} \right) \left( \frac{3600 s}{h} \frac{\text{ton}}{907.2 \text{ kg}} \right)$	$\dot{m}_{CO_2,export,SMR} = (0.04184) \left( \frac{3600}{907.2} \right)$	0.166	0.166	ton h <sup>-1</sup>
Capital expense, SMR system	$CapEx_{SMR} = \sum_{i=1}^7 C_{HE,i} + C_{\text{boiler,SMR}} + C_{CO_2,comp} + C_{CO_2,cryo} + C_{\text{pump}}$	$CapEx_{SMR} = 49,319 + 7,226 + 7,190 + 5,501 + 11,203 + 944 + 1,221 + 31,771 + 160 + 193,262 + 8,610$	316,408	316,407	\$
Operating Time	$t_{\text{operating}} = (F_{\text{load}}) (8760 \frac{h}{yr})$	$t_{\text{operating}} = (0.905) (8760 \frac{h}{yr})$	7,928	7928	\$

Operating expense, NG, boiler system	$OpEx_{boiler,NG} = (\dot{m}_{boiler,NG}) \left( \frac{kg}{s} \frac{3600 s}{h} \right) (t_{operating}) (price_{NG})$	$OpEx_{boiler,NG} = (0.01847)(3600)(7928)(0.2083)$	109,820	109,805	\$ yr <sup>-1</sup>
Operating expense, carbon tax, boiler system	$OpEx_{boiler,CO_2} = (\dot{m}_{boiler,CO_2,exh}) \left( \frac{kg}{yr} \frac{0.00110231 kg}{ton} \right) (Tax_{carbon})$	$OpEx_{boiler,CO_2} = (527,165)(0.00110231)(50.5)$	29,346	29,346	\$ yr <sup>-1</sup>
Operating expense, water, boiler system	$OpEx_{boiler,water} = (\dot{m}_{boiler,water}) \left( \frac{kg}{s} \frac{3600 s}{h} \right) (t_{operating}) (price_{water})$	$OpEx_{boiler,water} = (0.3116) \left( \frac{kg}{s} \frac{3600 s}{h} \right) (7928)(0.002282)$	20,294	20,295	\$ yr <sup>-1</sup>
O&M, SMR	$O\&M_{SMR} = (0.05) CapEx_{SMR}$	$O\&M_{SMR} = (0.05)(316,408)$	15,820	15,820	\$
Revenue, cCO <sub>2</sub> , SMR	$Rev_{SMR,CO_2} = (\dot{m}_{SMR,CO_2,export}) (t_{operating}) (Price_{cCO_2})$	$Rev_{SMR,CO_2} = (0.166)(7,928)(20)$	26,328	26,321	\$ yr <sup>-1</sup>
Operating expense, NG, SMR	$OpEx_{SMR,NG} = (\dot{m}_{SMR,NG}) \left( \frac{kg}{s} \frac{3600 s}{h} \right) (t_{operating}) (price_{NG})$	$OpEx_{SMR,NG} = (0.01525)(3600)(7,928)(0.2083)$	90,962	90,662	\$ yr <sup>-1</sup>
Operating expense, water, SMR	$OpEx_{SMR,water} = (\dot{m}_{SMR,water}) \left( \frac{kg}{s} \frac{3600 s}{h} \right) (t_{operating}) (price_{water})$	$OpEx_{SMR,water} = (0.2773)(3600)(7,928)(0.002282)$	18,063	18,061	\$ yr <sup>-1</sup>
Operating expense, electricity, SMR	$OpEx_{SMR,elec} = (\dot{W}_{SMR,elec}) (t_{operating}) (price_{elec})$	$OpEx_{SMR,elec} = (18.48)(7,928)(0.0688)$	10,081	10,079.8	\$ yr <sup>-1</sup>

#### A.4. Cash Flow Analysis Calculation

**Table A-6:** Hand calculations versus EES results to verify cash flow analysis results.

Parameter	Equation	Evaluated	EES Calc. Value	Hand Calc. Value	Units
FV, boiler, year 0	$FV_{0,boiler} = -CapEx_{boiler,total}$	$FV_{0,boiler} = -118,250$	-118,250	-118,250	\$
FV, boiler, year 1	$FV_{1,boiler} = Rev_{steam} - OpEx_{boiler,O\&M} - OpEx_{boiler,NG} - OpEx_{boiler,CO_2} - OpEx_{boiler,water}$	$FV_{1,boiler} = 200,000 - 21,280 - 109,820 - 29,346 - 20,294$	19,261	19,260	\$

PV, boiler, year 1	$PV_n = \frac{FV_n}{(1+irr)^n}$	$PV_{1,boiler} = \frac{19,261}{(1+0.12)^1}$	17,197	17,197	\$
FV, boiler, year 2	$FV_{2,boiler} = Rev_{steam} - OpEx_{boiler,O\&M} - OpEx_{boiler,NG} - OpEx_{boiler,CO_2} - OpEx_{boiler,water}$	$FV_{2,boiler} = 200,000 - 21,280 - 109,820 - 29,346 - 20,294$	19,261	19,260	\$
PV, boiler, year 2	$PV_n = \frac{FV_n}{(1+irr)^n}$	$PV_{2,boiler} = \frac{19,261}{(1+0.12)^2}$	15,354	15,354	\$
NPV boiler	$NPV = \sum_{n=0}^{lifespan} PV_n$	Omitted for brevity	25,616	25,616	\$
FV, SMR, year 0	$FV_{0,SMR} = -CapEx_{SMR,total}$	$FV_{0,boiler} = -320,330$	-320,330	-320,330	\$
FV, SMR, year 1	$FV_{1,SMR} = Rev_{steam} + Rev_{cCO_2} - OpEx_{SMR,O\&M} - OpEx_{SMR,NG} - OpEx_{SMR,water} - OpEx_{SMR,elec}$	$FV_{1,SMR} = 200,000 + 26,328 - 16,017 - 90,692 - 18,063 - 10,081$	91,475	91,475	\$
PV, SMR, year 1	$PV_n = \frac{FV_n}{(1+irr)^n}$	$PV_{1,boiler} = \frac{91,475}{(1+0.12)^1}$	81,674	81,674	\$
FV, SMR, year 2	$FV_{2,SMR} = Rev_{steam} + Rev_{cCO_2} - OpEx_{SMR,O\&M} - OpEx_{SMR,NG} - OpEx_{SMR,water} - OpEx_{SMR,elec}$	$FV_{2,SMR} = 200,000 + 26,328 - 16,017 - 90,692 - 18,063 - 10,081$	91,475	91,475	\$
PV, SMR, year 2	$PV_n = \frac{FV_n}{(1+irr)^n}$	$PV_{2,boiler} = \frac{19,261}{(1+0.12)^2}$	72,923	72,923	\$
NPV SMR	$NPV = \sum_{n=0}^{lifespan} PV_n$	Omitted for brevity	362,936	362,937	\$
NPB	$NPB = NPV_{SMR} - NPV_{boiler}$	$NPB = 362,936 - 25,616$	337,320	337,320	\$
Payback Period	Solve for $n$ such that $NPV_{SMR} = NPV_{boiler}$	Solve for $n$ such that $NPV_{SMR} = NPV_{boiler}$	1.96	1.96	yr

## APPENDIX B. Heat Exchanger Sizing

### B.1. Single Phase

There were several assumptions made in the heat exchanger modeling process. The heat exchangers were modeled as carbon steel, shell and tube type. They were considered adiabatic to the surroundings. The cold fluid was in the shell and the hot fluid in the tubes. The heat transfer and flow were modeled as a single tube-in-tube cross flow heat exchanger, with tube outer diameters of 10 and 4 inches. Fluid properties were evaluated at the average of the inlet and outlet temperatures. Fluid properties (molar mass, density, dynamic viscosity, thermal conductivity, Prandtl number, and specific heat) were calculated as the weighted average by mole fraction of up to six individual fluids ( $H_2$ ,  $CH_4$ ,  $H_2O$ ,  $CO_2$ ,  $N_2$ , and  $O_2$ ). Tube conductivity was calculated at the same average temperature. The absolute roughness of the tubes was assumed to be 0.04 mm.

First, the heat capacity rate of each fluid was calculated using Equations (B.1) and (B.2):

$$C_{\text{cold}} = C_{p,\text{cold}} \cdot \dot{n}_{\text{cold}} \quad (\text{B.1})$$

$$C_{\text{hot}} = C_{p,\text{hot}} \cdot \dot{n}_{\text{hot}} \quad (\text{B.2})$$

Choosing the smaller of the two heat capacity rates as  $C_{\text{min}}$ , the heat capacity ratio was defined by Equation (B.3):

$$C_r = \frac{C_{\text{min}}}{C_{\text{max}}} \quad (\text{B.3})$$

The thermal resistance of the hot fluid was calculated next. The hydraulic diameter was calculated by Equation (B.4):

$$D_{h,\text{hot}} = ID_{\text{tube}} \quad (\text{B.4})$$

where  $ID$  stands for inner diameter. The cross sectional area was calculated from hydraulic diameter by Equation (B.5):

$$A_{c,hot} = \frac{\pi}{4} D_{h,hot}^2 \quad (B.5)$$

The velocity of the fluid was calculated with Equation (B.6):

$$u_{hot} = \frac{\dot{n}_{hot}}{\rho_{hot} \cdot A_{c,hot}} \quad (B.6)$$

The Reynolds number was calculated with Equation (B.7):

$$Re_{hot} = \frac{M_{hot} \cdot \rho_{hot} \cdot v_{hot} \cdot D_{h,hot}}{\mu_{hot}} \quad (B.7)$$

The Nusselt number was calculated next as a function of Reynolds number, Prandtl number, tube absolute surface roughness, and hydraulic diameter. First, the Darcy friction factor for internal flow in a circular tube was calculated using Equations (B.8) through (B.10):

$$A = \left[ 2.2088 + 2.2457 \cdot \ln \left( \frac{\delta_{tube}}{D_{h,hot}} + \frac{42.683}{Re_{hot}^{0.9}} \right) \right]^{16} \quad (B.8)$$

$$B = \left[ \frac{37,350}{Re_{hot}^{0.9}} \right]^{16} \quad (B.9)$$

$$f = 8 \cdot \left[ \left( \frac{8}{Re_{hot}} \right)^{12} + \frac{1}{(A+B)^{1.5}} \right]^{1/12} \quad (B.10)$$

The Nusselt number was calculated using the Churchill correlation, by Equations (B.11) through (B.14):

$$Nu_i = 3.657 \quad (B.11)$$

$$Nu_o = 4.8 \quad (B.12)$$

$$Nu_t = Nu_o + \frac{0.079 \cdot Re_{hot} \cdot \left(\frac{f}{8}\right)^{0.5} \cdot Pr_{hot}}{(1 + Pr_{hot}^{0.8})^{5/6}} \quad (B.13)$$

$$Nu_{churchhill} = \left[ Nu_1^{10} + \left[ \frac{\exp\left(\frac{2200 - Re}{365}\right)}{Nu_1^2} + \frac{1}{Nu_1^2} \right]^{-5} \right]^{0.1} \quad (B.14)$$

The convection coefficient was calculated using Equation (B.15):

$$ht_{hot} = \frac{Nu_{hot} \cdot k_{hot}}{D_{h,hot}} \quad (B.15)$$

The heat transfer area was calculated by Equation (B.16):

$$A_{ht,hot} = \pi \cdot D_{h,hot} \cdot L_{tube} \quad (B.16)$$

At this point,  $L_{tube}$  was not a known value; the entire set of heat exchanger sizing calculations was solved simultaneously in EES. The convective thermal resistance from the hot fluid to the inner wall of the tube was calculated by Equation (B.17):

$$R_{convec,hot} = \frac{1}{ht_{hot} \cdot A_{ht,hot}} \quad (B.17)$$

The conductive thermal resistance through the tube wall was calculated by Equation (B.18):

$$R_{conduc,wall} = \frac{\ln\left(\frac{OD_{tube}}{ID_{tube}}\right)}{2\pi \cdot L_{tube} \cdot k_{tube}} \quad (B.18)$$

The convective thermal resistance for the cold fluid was calculated in the same way as the hot fluid, with two exceptions for geometry. The hydraulic diameter and cross section area of the cold fluid was calculated by Equations (B.19) and (B.20):

$$D_{h,cold} = ID_{shell} - OD_{tube} \quad (B.19)$$

$$A_{c,cold} = \frac{\pi}{4} \cdot (ID_{shell}^2 - OD_{tube}^2) \quad (B.20)$$

Again, the shell in tube geometry was modeled as tube-in-tube for the heat transfer geometry and flow calculations. Effectively, the cross-sectional area between the outer diameter of the tubes and the shell was treated as a circular annulus. The overall heat transfer coefficient,  $U$ , was calculated using Equation (B.21):

$$U \cdot A_{ht,hot} = \frac{1}{R_{convec,hot} + R_{conduc,wall} + R_{convec,cold}} \quad (B.21)$$

Note that these equations were solved in Engineering Equation Solver, so the equations did not have to be written as solved explicitly for the variable being calculated. The heat duty of the heat exchanger was already calculated from the thermodynamic section, calculated from the difference in enthalpy of the fluids. Thus, the effectiveness of the heat exchanger could be solved for in Equation (B.22):

$$\dot{Q}_{HE} = \varepsilon \cdot C_{min} \cdot (T_{hot,in} - T_{cold,in}) \quad (B.22)$$

The number of transfer units per shell pass ( $NTU_1$ ) was solved for using Equations (B.23) through (B.26):

$$F = \left( \frac{\varepsilon \cdot C_r - 1}{\varepsilon - 1} \right)^{\left( \frac{1}{N_{shell,passes}} \right)} \quad (B.23)$$

$$\varepsilon_1 = \left( \frac{F - 1}{F - C_r} \right) \quad (B.24)$$

$$E = \frac{\frac{2}{\varepsilon_1} - (1 + C_r)}{(1 + C_r^2)^{1/2}} \quad (B.25)$$

$$NTU_1 = -(1 + C_r^2)^{-1/2} \cdot \ln \left( \frac{E - 1}{E + 1} \right) \quad (B.26)$$

The total number of transfer units was calculated using Equation (B.27):

$$NTU = n_{\text{shell,passes}} \cdot NTU_1 \quad (\text{B.27})$$

Using the definition of  $NTU$ , the overall heat transfer area (and thus  $L_{\text{tube}}$ ) was solved for iteratively by Equation (B.28):

$$NTU = U \cdot \frac{A_{\text{ht,hot}}}{C_{\text{min}}} \quad (\text{B.28})$$

## B.2. Two Phase

The method of section B.1 was applied for heat exchangers 1 through 4. Heat exchanger 5 was more complicated for two reasons: it involved flow boiling, and it used three fluids (instead of two). Heat exchanger 5 was split up into two sections: preheating liquid water to saturation temperature, and boiling from saturated liquid to two-phase with  $0 < X < 1$ . The preheating section of heat exchanger 5 was modeled in the same way as heat exchangers 1 through 4.

The boiling section of heat exchanger 5 was more complicated. The same assumptions about geometry were made as with the previous heat exchangers. The hydraulic diameters and cross-sectional areas were calculated in the same way as before. The heat transfer correlations used in the sizing of the boiling section of the heat exchanger were from Kim and Mudawar [117]. In order to accurately capture the behavior of flow boiling, the heat exchanger was discretized into  $N$  sections using Equations (B.29) and (B.30):

$$\Delta X = \frac{X_{\text{cold,out}} - X_{\text{cold,in}}}{N} \quad (\text{B.29})$$

$$\Delta T_{\text{hot}} = \frac{T_{\text{hot,in}} - T_{\text{hot,out}}}{N} \quad (\text{B.30})$$

The first discretized section was the hot fluid entry (highest temperature) and cold fluid exit (highest quality). The boundary conditions were initialized by Equations (B.31) and (B.32):

$$T_{0,\text{hot}} = T_{\text{hot,in}} \quad (\text{B.31})$$

$$X_{0,\text{cold}} = X_{\text{cold,out}} \quad (\text{B.32})$$

The following (Equations (B.33) through (B.79)) occurred within a duplicated loop, where  $i$  represents the section of heat exchanger. Fluid properties were evaluated separately in each section of the heat exchanger. First, the known conditions were set by Equations (B.33) and (B.34):

$$T_{i,\text{cold}} = T_{\text{cold}} \quad (\text{B.33})$$

$$X_{i,\text{cold}} = X_{0,\text{cold}} - i \cdot \Delta X \quad (\text{B.34})$$

The convection coefficient of the boiling (“cold”) fluid was calculated using the Kim and Mudawar correlation as a function of temperature, quality, molar flow rate, and hydraulic diameter [117,118]. Several fluid properties were calculated for both the saturated liquid (subscript *liq*) and saturated vapor (subscript *gas*). The mass flux was calculated using Equations (B.35) and (B.37):

$$A_c = \frac{\pi}{4} D_h^2 \quad (\text{B.35})$$

$$\dot{m} = M \cdot \dot{n} \quad (\text{B.36})$$

$$\dot{G} = \frac{\dot{m}}{A_c} \quad (\text{B.37})$$

The Reynolds number of liquid and vapor were calculated using Equations (B.38) and (B.39):

$$Re_{\text{liq}} = \frac{\dot{G} \cdot (1 - X) \cdot D_h}{\mu_{\text{liq}}} \quad (\text{B.38})$$

$$Re_{\text{gas}} = \frac{\dot{G} \cdot X \cdot D_h}{\mu_{\text{gas}}} \quad (\text{B.39})$$

The fanning friction factor was calculated depending on the Reynolds number. The same equations apply to both liquid and vapor, but were calculated separately for each, using Equations (B.40) through (B.42):

$$f = 16 \cdot Re^{-1} \text{ for } Re < 2,000 \quad (\text{B.40})$$

$$f = 0.079 \cdot Re^{-0.25} \text{ for } 2,000 \leq Re < 20,000 \quad (\text{B.41})$$

$$f = 0.046 \cdot Re^{-0.2} \text{ for } Re \geq 20,000 \quad (\text{B.42})$$

The frictional pressure drop of the liquid and vapor were calculated using Equations (B.43) and (B.44):

$$\left( \frac{dp}{dz} \right)_{\text{liq}} = \frac{-2 \cdot f_{\text{liq}} \cdot \frac{v_{\text{liq}}}{M_{\text{liq}}} \cdot \dot{G}^2 \cdot (1-X)^2}{D_h} \quad (\text{B.43})$$

$$\left( \frac{dp}{dz} \right)_{\text{gas}} = \frac{-2 \cdot f_{\text{gas}} \cdot \frac{v_{\text{gas}}}{M_{\text{gas}}} \cdot \dot{G}^2 \cdot X^2}{D_h} \quad (\text{B.44})$$

The next step was to calculate total frictional pressure drop of the fluid by Equation (B.45):

$$\left( \frac{dP}{dz} \right)_F = \left( \frac{dP}{dz} \right)_{\text{liq}} \phi_{\text{liq}}^2 \quad (\text{B.45})$$

where  $\phi_{\text{liq}}$  is given by Equation (B.46):

$$\phi_{\text{liq}}^2 = 1 + \frac{C}{X_{\text{LM}}} + \frac{1}{X_{\text{LM}}^2} \quad (\text{B.46})$$

The symbol  $X_{\text{LM}}$  is a Lockhart-Martinelli parameter and should not be confused with fluid quality,  $X$ . The Lockhart-Martinelli parameter  $X_{\text{LM}}$  was calculated by Equation (B.47):

$$X_{\text{LM}}^2 = \frac{\left( \frac{dP}{dz} \right)_{\text{liq}}}{\left( \frac{dP}{dz} \right)_{\text{gas}}} \quad (\text{B.47})$$

Another Lockhart-Martinelli parameter was calculated based on liquid and vapor Reynolds numbers, by Equations (B.48) through (B.51):

$$C_{nb} = 0.39 \cdot Re_{fo}^{0.03} \cdot Su_{go}^{0.10} \cdot \left( \frac{\rho_{liq}}{\rho_{gas}} \right)^{0.35} \quad \text{for } Re_{liq} \geq 2,000 \text{ and } Re_{gas} \geq 2,000 \quad (B.48)$$

$$C_{nb} = 8.7e-4 \cdot Re_{fo}^{0.17} \cdot Su_{go}^{0.50} \cdot \left( \frac{\rho_{liq}}{\rho_{gas}} \right)^{0.14} \quad \text{for } Re_{liq} \geq 2,000 \text{ and } Re_{gas} < 2,000 \quad (B.49)$$

$$C_{nb} = 0.0015 \cdot Re_{fo}^{0.59} \cdot Su_{go}^{0.19} \cdot \left( \frac{\rho_{liq}}{\rho_{gas}} \right)^{0.36} \quad \text{for } Re_{liq} < 2,000 \text{ and } Re_{gas} \geq 2,000 \quad (B.50)$$

$$C_{nb} = 3.5e-5 \cdot Re_{fo}^{0.44} \cdot Su_{go}^{0.50} \cdot \left( \frac{\rho_{liq}}{\rho_{gas}} \right)^{0.48} \quad \text{for } Re_{liq} < 2,000 \text{ and } Re_{gas} < 2,000 \quad (B.51)$$

Based on the non-boiling parameter,  $C_{nb}$ , the parameter  $C$  was calculated using Equations (B.52) and (B.53):

$$C = C_{nb} \cdot \left[ 1 + 60 \cdot We_{fo}^{0.32} \cdot \left( Bo \cdot \frac{P_H}{P_W} \right)^{0.78} \right] \quad \text{for } Re_{liq} \geq 2,000 \quad (B.52)$$

$$C = C_{nb} \cdot \left[ 1 + 530 \cdot We_{fo}^{0.52} \cdot \left( Bo \cdot \frac{P_H}{P_W} \right)^{1.09} \right] \quad \text{for } Re_{liq} < 2,000 \quad (B.53)$$

In Equations (B.52) and (B.53),  $P_H$  is the heated perimeter of the channel and  $P_F$  is the wetted perimeter of the channel.  $Bo$  is the boiling number, given by Equation (B.54):

$$Bo = \frac{q_H''}{\dot{G} \cdot h_{fg}} \quad (B.54)$$

$We_{fo}$  is the Weber number for liquid, given by Equation (B.55):

$$We_{fo} = \frac{\dot{G}^2 \cdot D_h}{\rho_{liq} \cdot \sigma} \quad (B.55)$$

The turbulent-turbulent Martinelli parameter,  $X_{tt}$ , was calculated using Equation (B.56):

$$X_{tt} = \left( \frac{\mu_{liq}}{\mu_{gas}} \right)^{0.1} \left( \frac{1-X}{X} \right)^{0.9} \left( \frac{\rho_{gas}}{\rho_{liq}} \right) \quad (B.56)$$

The modified Weber number was calculated depending on the liquid Reynolds number by Equations (B.57) and (B.58):

$$We^* = 2.45 \cdot \frac{Re_{gas}^{0.64}}{Su_{go}^{0.3} \cdot (1 + 1.09 \cdot X_{tt}^{0.039})^{0.4}} \quad \text{for } Re_{liq} \leq 1,250 \quad (B.57)$$

$$We^* = \frac{0.85 \cdot Re_{gas}^{0.79} \cdot X_{tt}^{0.157}}{Su_{go}^{0.3} \cdot (1 + 1.09 \cdot X_{tt}^{0.039})^{0.4}} \cdot \left[ \left( \frac{\mu_{gas}}{\mu_{liq}} \right)^2 \cdot \frac{v_{gas}}{v_{liq}} \right]^{0.084} \quad \text{for } Re_{liq} > 1,250 \quad (B.58)$$

Finally, the convection coefficient was calculated using Equations (B.59) and (B.60):

$$ht_{boil} = \frac{k_{liq}}{D_h} \cdot 0.048 \cdot Re_{liq}^{0.69} \cdot Pr_{liq}^{0.34} \cdot \frac{\phi_g}{X_{tt}} \quad \text{for } We^* > (7 \cdot X_{tt}^{0.2}) \quad (B.59)$$

$$ht_{boil} = \left[ \left( 0.048 \cdot Re_{liq}^{0.69} \cdot Pr_{liq}^{0.34} \cdot \frac{\phi_g}{X_{tt}} \right)^2 + \left( 3.2 \times 10^{-7} \cdot Re_{liq}^{-0.38} \cdot Su_{go}^{1.39} \right)^2 \right]^{0.5} \quad (B.60)$$

for  $We^* \leq (7 \cdot X_{tt}^{0.2})$

After calculating the convection coefficient, the heat exchanger model was resumed with the new convection coefficient set in Equation (B.61):

$$ht_{i,cold} = ht_{boil} \quad (B.61)$$

The heat transfer surface area was calculated by Equation (B.62):

$$A_{i,ht,cold} = \pi \cdot OD_{tube} \cdot L_{i,tube} \quad (B.62)$$

Again, the length of the tube segment  $L_{i,tube}$  is not known if solving this set of equations linearly; the heat exchanger modeling equations, including each discretized segment, are solved

simultaneously as a set. The thermal resistance of the cold fluid was calculated with Equation (B.63):

$$R_{i,\text{convec,cold}} = \frac{1}{ht_{i,\text{cold}} \cdot A_{i,\text{ht,cold}}} \quad (\text{B.63})$$

The thermal resistance to conduction through the tube wall was calculated with Equation (B.64):

$$R_{i,\text{conduc,wall}} = \frac{\ln\left(\frac{OD_{\text{tube}}}{ID_{\text{tube}}}\right)}{2\pi \cdot L_{i,\text{tube}} \cdot k_{\text{tube}}} \quad (\text{B.64})$$

The average temperature of the hot fluid *in the current segment* was calculated with Equation (B.65):

$$T_{i,\text{avg,hot}} = \frac{T_{i,\text{hot}} + T_{i-1,\text{hot}}}{2} \quad (\text{B.65})$$

This average segment temperature was used to evaluate properties of the hot fluid in each segment separately. The velocity of the hot fluid was calculated with Equation (B.66):

$$u_{i,\text{hot}} = \frac{\dot{n}_{\text{hot}}}{\rho_{i,\text{hot}} \cdot A_{c,\text{hot}}} \quad (\text{B.66})$$

The Reynolds number of the hot fluid was calculated with Equation (B.67):

$$Re_{i,\text{hot}} = \frac{M_{i,\text{hot}} \cdot \rho_{i,\text{hot}} \cdot v_{i,\text{hot}} \cdot D_{h,\text{hot}}}{\mu_{i,\text{hot}}} \quad (\text{B.67})$$

$M_{i,\text{hot}}$ , the molar mass of the hot fluid in the current segment, is constant. The subscript  $i$  was added because all fluid properties were evaluated together in each loop iteration. The Nusselt number was calculated using Equations (B.11) to (B.14). The convection coefficient was calculated using Equation (B.68):

$$ht_{i,\text{hot}} = \frac{Nu_{i,\text{hot}} \cdot k_{i,\text{hot}}}{D_{h,\text{hot}}} \quad (\text{B.68})$$

The heat transfer area was calculated using Equation (B.69):

$$A_{i,ht,hot} = \pi \cdot D_{h,hot} \cdot L_{i,tube} \quad (B.69)$$

The convective thermal resistance of the hot fluid was calculated using Equation (B.70):

$$R_{i,convec,hot} = \frac{1}{ht_{i,hot} \cdot A_{i,ht,hot}} \quad (B.70)$$

Beginning the epsilon-NTU method, the total thermal resistance between fluids was calculated using Equation (B.71):

$$R_{i,total} = R_{i,convec,cold} + R_{i,conduc,wall} + R_{i,convec,hot} \quad (B.71)$$

The overall heat transfer coefficient was calculated using Equation (B.72):

$$U_i \cdot A_{i,ht,hot} = \frac{1}{R_{i,total}} \quad (B.72)$$

The heat capacity rate of the hot fluid was calculated using Equation (B.73):

$$C_{i,hot} = C_{i,min} = \dot{n}_{hot} \cdot Cp_{i,hot} \quad (B.73)$$

The heat capacity rate of the hot fluid is the minimum because the heat capacity rate of a phase-change fluid is effectively infinite. It follows that the heat capacity ratio is equal to zero, shown in Equation (B.74):

$$C_{i,r} = \frac{C_{i,min}}{C_{i,max}} = \frac{C_{i,hot}}{\infty} = 0 \quad (B.74)$$

The number of transfer units ( $NTU$ ) was calculated using Equation (B.75):

$$NTU_i = \frac{U_i \cdot A_{i,ht,hot}}{C_{i,hot}} \quad (B.75)$$

The effectiveness of the segment was calculated using Equation (B.76):

$$\varepsilon_i = 1 - \exp(-NTU_i) \quad (B.76)$$

Finally, the following three equations allow the system to be solved simultaneously. They set the heat transfer in a given segment equal to: Equation (B.77): enthalpy difference due to hot fluid's temperature change; Equation (B.78): enthalpy difference due to cold fluid's change in quality; and Equation (B.79): heat transfer predicted by the epsilon-NTU method.

$$\dot{Q}_i = \dot{n}_{\text{hot}} \cdot C_{p,i,\text{hot}} \cdot (T_{i-1,\text{hot}} - T_{i,\text{hot}}) \quad (\text{B.77})$$

$$\dot{Q}_i = \dot{n}_{\text{cold}} \cdot \Delta h_{\text{fg,cold}} \cdot (X_{i-1,\text{cold}} - X_{i,\text{cold}}) \quad (\text{B.78})$$

$$\dot{Q}_i = \varepsilon_i \cdot C_{i,\text{hot}} \cdot (T_{i-1,\text{hot}} - T_{\text{cold}}) \quad (\text{B.79})$$

After the set of equations for the segments was calculated, the sum of the heat transfer area was calculated using Equation (B.80):

$$A_{\text{ht,hot,total}} = \sum_{i=1}^N A_{i,\text{ht,hot}} \quad (\text{B.80})$$